

ROME RUSSELL, GA, USA

WMO: 723200

Lat: 34.348N

Lon: 85.161W

Elev: 195

StdP: 99.01

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 93801

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.0	(c) -4.8	(d) -15.0	(e) 1.0	(f) -2.8	(g) -12.6	(h) 1.3	(i) -0.6	(j) 8.5	(k) 4.8	(l) 7.7	(m) 5.5	(n) 1.7	(o) 340	(p) 0.374

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.4	35.4	23.6	34.1	23.3	32.9	23.3	25.7	31.6	25.1	31.1	24.6	30.2	2.8	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.1	19.4	27.6	23.6	18.8	27.2	22.9	18.1	26.8	79.8	31.7	77.4	31.2	75.2	30.2	27.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 7.3	(b) 6.2	(c) 5.4	(e) -10.2	(f) 37.2	(g) 2.3	(h) 1.9	(i) -11.8	(j) 38.5	(k) -13.2	(l) 39.6	(m) -14.5	(n) 40.6	(o) -16.2	(p) 42.0		
(a) 7.3	(b) 6.2	(c) 5.4	(e) -11.1	(f) 26.7	(g) 2.3	(h) 0.6	(i) -12.7	(j) 27.1	(k) -14.1	(l) 27.5	(m) -15.4	(n) 27.9	(o) -17.1	(p) 28.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.6	5.6	7.8	11.8	16.5	20.9	25.0	26.6	26.4	23.2	17.0	10.9	7.3
	DBStd	8.48	5.47	5.06	4.71	4.01	3.39	2.33	1.91	1.97	3.16	4.38	4.52	4.77
	HDD10.0	450	159	93	36	3	0	0	0	0	0	3	42	113
	HDD18.3	1648	396	296	207	81	17	1	0	0	4	78	228	342
	CDD10.0	2870	22	32	92	197	339	449	516	509	396	219	68	30
	CDD18.3	1026	0	1	4	25	97	200	258	251	150	36	3	1
	CDH23.3	9821	1	7	65	322	951	1871	2496	2410	1345	328	25	1
	CDH26.7	4266	0	0	7	71	333	852	1193	1157	569	80	3	0
Wind	WSAvg	1.8	2.2	2.2	2.4	2.2	1.7	1.5	1.5	1.4	1.5	1.7	1.8	2.0
Precipitation	PrecAvg	1339	127	109	184	135	107	91	107	94	114	73	93	127
	PrecMax	1741	205	285	407	290	260	164	177	215	287	174	159	342
	PrecMin	1064	56	16	38	26	23	14	34	25	29	0	34	29
	PrecStd	209	41	65	91	69	59	48	45	54	64	54	39	70
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.0	24.1	27.7	30.7	33.4	36.0	37.0	37.2	35.7	31.4	26.4	22.5
		MCWB	15.6	16.9	17.1	19.5	22.2	23.3	24.1	23.7	21.8	21.4	17.4	17.2
	2%	DB	19.0	21.2	25.2	28.6	31.7	34.1	35.1	35.4	33.7	28.7	23.0	19.9
		MCWB	14.6	14.9	16.3	18.4	21.3	22.8	24.3	23.8	21.8	19.9	15.6	16.3
	5%	DB	17.1	18.9	23.0	27.1	30.1	32.8	33.7	33.8	32.1	27.0	21.3	17.6
		MCWB	13.4	13.7	15.0	17.5	20.9	22.9	24.2	23.5	22.0	18.8	15.4	14.0
	10%	DB	14.7	16.8	20.7	25.1	28.5	31.5	32.4	32.4	30.1	24.9	19.0	15.5
		MCWB	11.3	11.7	13.4	16.8	20.3	22.7	24.0	23.4	21.6	18.1	14.4	12.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.6	18.8	18.9	21.3	24.0	25.8	26.6	26.2	24.7	23.9	20.7	19.2
		MCDB	19.8	22.1	24.6	27.7	29.6	31.4	32.0	32.7	30.0	27.9	22.8	20.8
	2%	WB	15.8	17.0	17.6	20.1	23.0	25.0	25.8	25.5	24.0	21.9	18.5	16.9
		MCDB	18.2	20.1	23.1	25.7	29.0	30.9	31.6	31.7	29.4	26.3	21.6	18.9
	5%	WB	14.1	15.1	16.4	19.0	22.3	24.3	25.3	25.0	23.3	20.7	16.9	14.9
		MCDB	16.7	17.7	21.0	24.4	27.9	30.1	31.4	30.8	28.3	24.4	19.7	16.9
	10%	WB	11.9	12.8	15.1	18.0	21.4	23.7	24.8	24.4	22.6	19.5	15.2	12.7
		MCDB	14.1	15.6	19.3	23.0	26.6	29.1	30.4	29.8	27.3	23.2	18.3	14.8
Mean Daily Temperature Range	5% DB	MDBR	11.3	11.9	12.8	13.8	13.0	11.9	11.4	11.7	12.4	13.5	13.2	10.8
		MCDBR	13.8	14.8	16.3	16.5	15.0	14.3	13.3	14.0	15.0	15.2	15.8	13.2
		MCWBR	9.6	9.5	8.6	7.6	6.3	5.1	4.4	4.5	5.3	7.2	9.4	9.4
	5% WB	MCDBR	11.0	11.9	12.9	12.9	12.2	11.5	11.4	11.4	10.8	11.2	11.1	10.6
	MCWBR	8.6	9.1	7.7	6.8	5.6	4.8	4.4	4.3	4.5	6.0	7.9	8.5	
Clear-Sky Solar Irradiance	taub	0.320	0.323	0.360	0.398	0.457	0.490	0.543	0.538	0.429	0.378	0.346	0.321	
	taud	2.502	2.489	2.410	2.295	2.168	2.115	1.982	1.981	2.277	2.409	2.438	2.517	
	Ebn at Noon	890	927	913	889	836	806	760	756	831	851	848	867	
	Edh at Noon	84	95	111	131	150	158	180	177	126	102	89	79	
All-Sky Solar Radiation	RadAvg	2.54	3.07	4.19	5.39	5.94	6.19	5.87	5.48	4.72	3.92	2.86	2.15	
	RadStd	0.18	0.40	0.37	0.35	0.47	0.47	0.41	0.30	0.45	0.49	0.32	0.22	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (39 neighbors)	+0.47	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+144	+103

Nomenclature: See separate page