

BRUNSWICK 23 S, GA, USA

WMO: 723210

Lat: 30.8078N

Lon: 81.4596W

Elev: 25

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 63856

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 31.0	(c) 34.5	(d) 18.6	(e) 14.1	(f) 39.8	(g) 23.1	(h) 17.5	(i) 40.8	(j) 11.7	(k) 47.6	(l) 10.6	(m) 48.7	(n) 2.5	(o) N/A	(p) 0.295

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 13.1	(c) 92.2	(d) 77.4	(e) 89.9	(f) 77.7	(g) 88.1	(h) 77.6	(i) 80.3	(j) 87.7	(k) 79.6	(l) 87.0	(m) 78.9	(n) 86.0	(o) 4.8	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.2	146.5	84.8	77.4	142.7	84.1	76.9	140.1	83.5	43.7	87.8	43.0	87.3	42.3	86.2	83.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 10.0	(b) 8.6	(c) 7.7	(e) 25.5	(f) 96.5	(g) 2.4	(h) 2.0	(i) 23.8	(j) 97.9	(k) 22.5	(l) 99.1	(m) 21.1	(n) 100.3	(o) 19.4	(p) 101.7		
(a) 10.0	(b) 8.6	(c) 7.7	(e) 23.1	(f) 81.7	(g) 3.4	(h) 0.8	(i) 20.7	(j) 82.2	(k) 18.7	(l) 82.7	(m) 16.8	(n) 83.2	(o) 14.3	(p) 83.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	68.2	52.6	55.4	59.9	66.9	73.7	79.5	81.1	81.2	78.4	70.6	60.9	56.9
	DBStd	12.00	9.01	8.46	7.80	5.77	4.49	3.04	2.52	2.43	3.06	6.68	7.45	8.29
	HDD50	175	81	40	15	0	0	0	0	0	0	0	8	31
	HDD65	1375	390	282	190	47	3	0	0	0	0	29	163	271
	CDD50	6802	161	190	322	506	736	885	965	967	852	639	335	244
	CDD65	2529	6	13	33	102	274	435	500	502	402	203	40	19
	CDH74	21481	13	54	154	448	1765	3960	4993	5047	3595	1301	114	37
	CDH80	6387	0	3	25	72	351	1260	1787	1735	960	188	6	0
Wind	WSAvg	3.5	3.5	3.6	4.0	4.1	3.9	3.4	3.1	3.0	3.3	3.2	3.2	3.2
Precipitation	PrecAvg	49.7	3.3	3.0	3.7	2.5	2.1	6.2	5.1	5.9	7.0	5.9	1.8	2.9
	PrecMax	67.3	9.1	9.6	8.3	5.6	5.2	11.3	10.5	17.4	13.5	13.5	4.2	10.2
	PrecMin	31.2	0.3	0.8	0.5	0.6	0.6	1.5	2.4	2.5	3.1	0.3	0.2	0.7
	PrecStd	10.1	2.2	2.2	2.3	1.5	1.3	2.7	2.4	3.1	3.1	4.1	1.1	2.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.1	79.8	83.9	86.9	91.4	94.7	94.9	94.9	90.8	86.6	80.4	78.2
		MCWB	67.2	67.0	66.3	69.3	73.6	77.4	77.7	77.6	77.0	75.7	71.6	70.6
	2%	DB	71.2	75.2	78.1	81.7	86.9	91.1	91.7	91.2	87.7	84.1	77.3	74.3
		MCWB	63.7	66.1	65.8	69.5	71.9	77.1	78.1	78.1	77.0	74.6	69.8	68.5
	5%	DB	68.3	71.1	74.5	78.4	83.4	88.2	89.4	88.8	86.3	82.2	74.6	71.2
		MCWB	62.6	64.3	64.9	69.1	73.0	77.0	78.3	78.8	76.5	73.8	68.9	66.6
	10%	DB	65.5	67.8	71.3	76.3	81.3	86.1	87.5	87.2	85.0	80.2	72.3	68.5
		MCWB	61.1	62.5	63.5	68.0	72.5	76.6	78.1	78.7	75.9	72.8	67.2	65.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.0	69.8	69.9	74.3	77.0	80.4	81.1	81.4	79.7	78.6	75.1	71.9
		MCDB	73.5	76.4	76.7	79.3	85.0	88.4	89.0	88.4	86.1	82.8	79.0	76.1
	2%	WB	66.0	67.9	68.4	72.6	75.6	79.3	80.2	80.3	78.7	77.1	73.0	69.9
		MCDB	70.0	73.6	74.9	77.7	82.1	87.3	88.1	87.4	85.2	81.5	75.7	73.1
	5%	WB	63.9	65.8	67.0	71.3	74.7	78.3	79.4	79.7	78.0	75.8	70.7	68.1
		MCDB	67.0	70.6	73.0	76.3	80.9	85.9	87.3	86.8	84.4	80.4	73.6	70.8
	10%	WB	61.6	63.8	65.5	69.9	73.8	77.5	78.6	79.0	77.2	74.5	68.4	66.0
		MCDB	64.3	67.5	70.5	74.8	79.7	84.7	86.0	85.7	83.5	79.2	72.0	68.7
Mean Daily Temperature Range	5% DB	MDBR	17.7	18.1	17.8	16.7	14.9	14.2	14.0	13.1	12.7	15.5	17.4	17.1
		MCDBR	19.0	20.0	20.7	18.4	17.8	17.3	16.2	15.4	14.6	14.9	17.8	17.7
		MCWBR	13.0	11.6	10.5	8.6	7.8	7.6	7.1	6.7	6.8	7.8	10.6	11.9
	5% WB	MCDBR	16.8	16.6	16.8	14.0	13.5	15.4	15.0	14.1	13.2	12.3	13.5	16.0
		MCWBR	12.8	11.2	9.6	8.5	7.0	7.5	7.0	6.9	6.6	7.1	9.3	11.6
Clear-Sky Solar Irradiance	taub	0.338	0.347	0.373	0.399	0.441	0.488	0.512	0.496	0.429	0.400	0.360	0.348	
	taud	2.532	2.510	2.452	2.371	2.288	2.214	2.155	2.203	2.388	2.432	2.498	2.529	
	Ebn at Noon	283	291	289	284	271	257	250	253	268	268	272	273	
	Edh at Noon	28	30	35	39	43	46	48	46	36	33	28	26	
All-Sky Solar Radiation	RadAvg	971	1166	1534	1890	2039	1931	1928	1773	1507	1325	1065	868	
	RadStd	65	132	143	117	117	132	120	112	127	120	62	73	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (30 neighbors)	+0.85	+1.37	N/A	N/A	N/A	N/A	N/A	-31	-124	+292	+211

Nomenclature: See separate page