

GOLDEN TRIANGLE, MS, USA

WMO: 723307

Lat: 33.450N

Lon: 88.583W

Elev: 264

StdP: 14.56

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 53893

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.3	24.8	9.2	8.9	25.3	13.1	10.8	29.0	21.2	54.7	18.9	51.6	4.9	350	0.388

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.1	96.6	77.6	93.3	77.1	91.4	76.7	80.4	91.1	79.4	90.4	78.4	88.6	5.2	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.4	144.1	85.7	76.3	138.5	84.8	75.2	133.6	83.8	44.1	90.9	43.0	90.8	42.0	89.0	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.9	15.7	13.0	12.5	98.6	4.4	3.3	9.3	101.0	6.7	103.0	4.3	104.9	1.1	107.3		
(5)			11.1	82.3	4.3	1.5	8.1	83.3	5.6	84.2	3.2	85.0	0.1	86.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.6	44.1	49.4	55.0	62.8	71.9	77.7	80.9	80.6	75.5	64.7	53.3	45.9		
	DBStd	15.21	10.86	10.15	8.91	7.44	5.85	4.03	3.07	3.50	6.16	8.39	8.79	9.46		
	HDD50	689	249	121	54	4	0	0	0	0	0	4	65	192		
	HDD65	2631	650	443	323	127	15	0	0	0	7	111	362	593		
	CDD50	5641	67	106	209	388	678	832	959	949	764	459	164	66		
	CDD65	2112	3	8	14	61	229	382	494	484	321	102	12	2		
	CDH74	19971	7	37	139	543	2084	3528	4856	4791	2987	919	75	5		
	CDH80	8872	0	2	17	96	729	1555	2393	2435	1354	282	9	0		
(14) Wind	WSAvg	5.7	7.0	7.1	7.2	6.6	5.2	4.4	3.8	3.8	4.9	5.5	6.0	6.6		
(15) Precipitation	PrecAvg	56.0	5.5	5.6	5.1	4.8	4.2	4.4	4.5	4.4	3.6	3.8	4.6	5.3		
	PrecMax	76.4	10.9	11.1	7.8	13.5	11.1	10.3	9.6	8.3	10.9	10.9	8.7	11.1		
	PrecMin	34.0	3.0	1.5	0.4	2.5	1.1	1.4	1.1	0.9	0.4	0.2	1.9	1.3		
	PrecStd	9.4	2.1	2.6	1.8	2.6	2.6	2.4	2.3	2.1	2.4	2.7	1.9	2.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.4	78.9	81.9	85.9	91.3	95.2	98.7	99.9	97.2	90.6	81.3	72.5		
		MCWB	63.1	66.1	65.2	70.1	73.5	77.2	78.8	76.9	75.5	74.3	67.3	64.0		
	2%	DB	69.8	73.3	78.6	82.5	89.5	92.6	95.3	96.8	93.3	86.0	75.4	68.3		
		MCWB	61.2	63.8	62.6	67.6	73.8	76.3	78.9	77.3	75.4	72.1	64.2	61.8		
	5%	DB	65.6	69.8	73.5	80.7	87.5	90.5	93.0	93.2	90.8	82.5	72.3	64.2		
		MCWB	60.0	61.4	61.2	66.2	72.6	75.9	78.2	77.2	74.9	68.8	63.2	59.2		
	10%	DB	62.2	65.4	70.3	77.2	84.2	88.5	91.0	90.9	88.3	79.8	68.6	61.4		
		MCWB	56.8	59.2	59.9	64.1	71.3	75.4	77.9	76.7	73.7	67.5	62.0	55.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.1	69.2	69.5	72.8	77.6	80.4	82.3	81.9	79.0	76.7	71.1	67.0		
		MCDB	71.8	75.3	75.8	81.9	87.0	90.1	92.8	92.4	90.7	86.3	77.1	71.3		
	2%	WB	63.3	66.4	66.6	70.5	75.7	78.9	80.7	80.3	77.6	74.8	68.5	63.8		
		MCDB	66.2	71.5	74.0	79.2	85.3	88.7	91.2	91.4	89.0	82.6	73.3	65.6		
	5%	WB	60.8	63.5	63.9	68.9	74.3	77.8	79.7	79.1	76.6	72.6	65.9	60.6		
		MCDB	64.7	68.0	70.5	76.7	83.5	87.3	90.8	90.0	87.4	79.2	70.3	63.9		
	10%	WB	57.0	60.0	61.7	67.0	72.9	76.7	78.7	78.0	75.3	70.2	62.9	57.2		
		MCDB	61.4	64.5	67.5	74.1	81.3	85.6	89.1	88.1	85.2	75.8	66.7	61.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	19.6	20.2	21.8	22.8	21.7	20.0	20.1	21.5	22.5	23.2	21.7	19.4		
		MCDBR	23.2	22.8	26.0	24.6	23.0	22.6	22.8	24.3	24.5	25.4	25.9	22.3		
		MCWBR	15.7	14.4	14.3	12.3	9.9	9.6	9.1	9.2	9.6	12.2	15.5	16.3		
	5% WB	MCDBR	19.2	19.5	21.5	19.5	19.4	19.5	20.9	20.8	21.0	18.9	20.0	18.2		
		MCWBR	14.9	14.0	14.3	11.3	9.4	9.4	9.2	9.1	9.0	9.8	14.5	15.0		
(40) Clear-Sky Solar Irradiance	taub		0.321	0.327	0.363	0.396	0.429	0.478	0.512	0.512	0.435	0.368	0.341	0.318		
	taud		2.516	2.496	2.418	2.321	2.271	2.153	2.091	2.087	2.292	2.455	2.473	2.540		
	Ebn at Noon		284	294	290	283	273	259	249	247	263	275	273	279		
	Edh at Noon		27	30	35	41	43	48	51	51	40	31	28	25		
(44) All-Sky Solar Radiation	RadAvg		834	992	1359	1725	1912	2017	1938	1779	1572	1284	943	713		
	RadStd		71	140	127	127	134	145	106	122	131	166	95	69		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (28 neighbors)	+0.74	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+234	+158

Nomenclature: See separate page