

GOLDEN TRIANGLE, MS, USA

WMO: 723307

Lat: 33.450N

Lon: 88.583W

Elev: 81

StdP: 100.36

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 53893

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.5	-4.0	-12.6	1.3	-3.7	-10.5	1.5	-1.6	9.5	12.6	8.5	10.9	2.2	350	0.388

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	35.9	25.3	34.1	25.1	33.0	24.8	26.9	32.9	26.3	32.4	25.8	31.5	2.3	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.2	20.6	29.9	24.6	19.8	29.3	24.0	19.1	28.8	84.7	32.7	82.1	32.7	79.7	31.7	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.0	7.0	5.8	-10.9	37.0	2.4	1.9	-12.6	38.3	-14.0	39.4	-15.4	40.5	-17.2	41.8
			-11.6	27.9	2.4	0.8	-13.3	28.5	-14.7	29.0	-16.0	29.4	-17.7	30.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.5	6.7	9.7	12.8	17.1	22.2	25.4	27.2	27.0	24.1	18.2	11.8	7.7
	DBStd	8.45	6.03	5.64	4.95	4.13	3.25	2.24	1.71	1.94	3.42	4.66	4.89	5.26
	HDD10.0	383	138	67	30	2	0	0	0	0	2	36	107	(8)
	HDD18.3	1462	361	246	179	71	8	0	0	0	4	62	201	329
	CDD10.0	3134	37	59	116	216	377	462	533	527	424	255	91	37
	CDD18.3	1173	2	4	8	34	127	212	274	269	178	57	7	1
	CDH23.3	11095	4	21	77	302	1158	1960	2698	2662	1659	511	42	3
	CDH26.7	4929	0	1	9	53	405	864	1329	1353	752	157	5	0
(14) Wind	WSAvg	2.5	3.1	3.2	3.2	3.0	2.3	2.0	1.7	1.7	2.2	2.5	2.7	2.9
(15) Precipitation	PrecAvg	1422	140	143	130	123	106	112	114	111	91	96	118	135
	PrecMax	1940	276	282	198	344	282	261	244	210	278	278	222	283
	PrecMin	863	76	39	11	64	27	35	27	22	10	5	48	34
	PrecStd	240	53	65	45	66	65	61	59	54	60	68	49	59
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.0	26.1	27.7	30.0	32.9	35.1	37.1	37.7	36.2	32.6	27.4	22.5
		MCWB	17.3	19.0	18.5	21.2	23.1	25.1	26.0	24.9	24.2	23.5	19.6	17.8
	2%	DB	21.0	22.9	25.9	28.1	32.0	33.7	35.1	36.0	34.0	30.0	24.1	20.2
		MCWB	16.2	17.7	17.0	19.8	23.2	24.6	26.1	25.2	24.1	22.3	17.9	16.6
	5%	DB	18.6	21.0	23.1	27.0	30.8	32.5	33.9	34.0	32.7	28.0	22.4	17.9
		MCWB	15.5	16.3	16.2	19.0	22.5	24.4	25.7	25.1	23.8	20.5	17.3	15.1
	10%	DB	16.8	18.6	21.3	25.1	29.0	31.4	32.8	32.7	31.3	26.5	20.3	16.3
		MCWB	13.8	15.1	15.5	17.8	21.8	24.1	25.5	24.8	23.1	19.7	16.7	13.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.9	20.7	20.8	22.7	25.4	26.9	27.9	27.7	26.1	24.8	21.7	19.5
		MCDB	22.1	24.0	24.3	27.7	30.5	32.3	33.8	33.6	32.6	30.1	25.0	21.8
	2%	WB	17.4	19.1	19.2	21.4	24.3	26.1	27.1	26.8	25.3	23.8	20.3	17.7
		MCDB	19.0	21.9	23.3	26.2	29.6	31.5	32.9	33.0	31.7	28.1	22.9	18.7
	5%	WB	16.0	17.5	17.7	20.5	23.5	25.4	26.5	26.1	24.8	22.6	18.9	15.9
		MCDB	18.2	20.0	21.4	24.9	28.6	30.7	32.6	32.2	30.8	26.2	21.3	17.7
	10%	WB	13.9	15.6	16.5	19.4	22.7	24.8	25.9	25.6	24.1	21.2	17.2	14.0
		MCDB	16.4	18.0	19.7	23.4	27.4	29.8	31.7	31.2	29.5	24.3	19.3	16.2
(35) Mean Daily Temperature Range	5% DB	MDBR	10.9	11.2	12.1	12.7	12.1	11.1	11.2	12.0	12.5	12.9	12.1	10.8
		MCDBR	12.9	12.7	14.4	13.7	12.8	12.6	12.7	13.5	13.6	14.1	14.4	12.4
	5% WB	MCWBR	8.7	8.0	7.9	6.8	5.5	5.3	5.0	5.1	5.4	6.8	8.6	9.1
		MCDWR	10.7	10.8	12.0	10.8	10.8	10.9	11.6	11.6	11.7	10.5	11.1	10.1
(40) Clear-Sky Solar Irradiance	taub	0.321	0.327	0.363	0.396	0.429	0.478	0.512	0.512	0.435	0.368	0.341	0.318	(40)
		taud	2.516	2.496	2.418	2.321	2.271	2.153	2.091	2.087	2.292	2.455	2.473	2.540
	Ebn at Noon	895	926	914	893	862	816	786	779	829	867	862	879	(42)
		Edh at Noon	84	95	111	128	136	152	161	160	125	98	87	78
(44) All-Sky Solar Radiation	RadAvg	2.63	3.13	4.29	5.44	6.03	6.36	6.11	5.61	4.96	4.05	2.97	2.25	(44)
	RadStd	0.22	0.44	0.40	0.40	0.42	0.46	0.34	0.39	0.41	0.52	0.30	0.22	(45)

Historical Trends

		Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(m)
(47) Regional (28 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.41	N/A	N/A	N/A	N/A	N/A	N/A	+130
									+88

Nomenclature: See separate page