

LITTLE ROCK CLINTON, AR, USA

WMO: 723403

Lat: 34.727N

Lon: 92.239W

Elev: 79

StdP: 100.38

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13963

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.6	-4.5	-15.0	1.0	-3.1	-12.4	1.3	-2.1	10.6	7.3	9.3	9.4	3.6	50	0.440

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.2	36.9	25.0	35.3	25.0	34.1	24.8	26.8	33.2	26.3	32.6	25.7	31.8	4.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.1	20.4	29.5	24.6	19.8	29.2	24.0	19.1	28.7	84.0	33.1	81.6	32.6	79.5	31.9	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.8	7.9	7.1	-10.1	38.8	2.0	2.4	-11.5	40.6	-12.7	42.0	-13.9	43.4	-15.3	45.1
			-11.2	27.8	1.9	0.8	-12.5	28.3	-13.7	28.8	-14.7	29.2	-16.1	29.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	17.4	5.7	7.7	12.3	17.3	21.9	26.4	28.1	27.9	24.2	17.9	11.6	6.9	(6)
		DBStd	9.13	5.79	5.63	5.33	4.26	3.61	2.55	2.42	2.54	3.42	4.43	4.79	5.22	
		HDD10.0	465	158	101	37	3	1	0	0	0	2	37	126		
		HDD18.3	1601	393	298	198	68	12	0	0	3	64	208	356		
		CDD10.0	3153	24	37	108	221	370	491	562	556	427	245	84	29	
		CDD18.3	1249	1	1	10	36	124	241	303	297	180	49	5	1	
		CDH23.3	12904	2	8	74	293	1027	2528	3505	3350	1669	416	30	2	
		CDH26.7	5825	0	0	7	54	331	1156	1749	1689	718	119	2	0	
(14)	Wind	WSAvg	3.2	3.6	3.6	3.9	3.8	3.2	2.8	2.7	2.5	2.6	2.7	3.1	3.3	(14)
(15)	Precipitation	PrecAvg	1279	98	93	135	135	129	85	92	71	85	114	118	130	(15)
(16)		PrecMax	2073	217	212	314	302	341	187	240	173	210	390	306	292	(16)
(17)		PrecMin	921	9	32	53	44	29	26	19	6	14	13	25	18	(17)
(18)		PrecStd	256	48	38	64	71	65	43	52	43	49	79	73	59	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	22.9	24.5	27.7	29.9	32.9	36.6	38.7	39.4	36.7	31.7	26.6	22.9		(19)
(20)		0.4% MCWB	17.3	17.7	18.2	20.7	23.0	24.5	25.2	25.0	23.7	21.5	19.5	18.2		(20)
(21)		2% DB	20.2	21.9	25.6	28.3	31.4	34.9	36.7	37.2	34.3	29.8	23.8	20.2		(21)
(22)		2% MCWB	16.1	16.4	17.6	19.5	22.5	24.8	25.4	25.1	23.9	21.2	17.8	16.5		(22)
(23)		5% DB	17.9	19.6	23.2	26.7	30.1	33.5	35.1	35.4	32.6	27.8	21.7	18.0		(23)
(24)		5% MCWB	14.4	14.9	16.3	18.8	22.1	24.3	25.5	25.0	23.4	20.0	17.4	14.9		(24)
(25)		10% DB	15.2	17.3	21.0	24.9	28.6	32.3	33.8	33.9	31.0	25.6	19.6	15.5		(25)
(26)		10% MCWB	11.3	13.1	15.3	18.1	21.7	24.0	25.3	24.7	22.5	19.2	15.2	12.2		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	18.8	19.4	20.3	23.0	25.5	26.8	27.5	27.4	25.8	24.2	21.2	19.5		(27)
(28)		0.4% MCDB	21.7	22.7	25.4	27.1	30.0	33.0	33.8	34.0	32.6	28.6	24.0	21.6		(28)
(29)		2% WB	17.5	18.0	19.0	21.5	24.2	26.0	26.9	26.7	25.1	22.9	19.6	17.7		(29)
(30)		2% MCDB	19.7	20.7	23.6	26.0	28.8	32.1	33.2	33.4	31.3	27.3	22.5	19.7		(30)
(31)		5% WB	15.2	16.1	17.8	20.5	23.5	25.4	26.4	26.1	24.4	21.7	18.1	15.5		(31)
(32)		5% MCDB	17.2	18.8	21.7	24.7	28.1	31.3	32.7	32.6	30.0	25.4	20.8	17.6		(32)
(33)		10% WB	12.0	13.7	16.4	19.5	22.7	24.9	25.8	25.6	23.8	20.6	16.3	12.9		(33)
(34)		10% MCDB	14.3	16.2	20.3	23.4	27.2	30.4	31.8	31.7	28.8	24.0	19.1	14.7		(34)
(35)	Mean Daily Temperature Range	MDBR	10.0	10.4	11.0	11.5	10.6	10.2	10.2	10.7	11.2	11.7	10.8	9.6		(35)
(36)		5% DB MCDBR	13.4	14.1	13.7	13.1	11.9	11.4	11.7	12.6	12.7	13.8	13.0	12.4		(36)
(37)		5% WB MCWBR	9.5	9.3	7.6	6.3	4.8	3.9	3.4	3.6	4.3	6.2	8.3	9.0		(37)
(38)		5% WB MCDBR	11.0	11.8	11.5	10.6	10.1	10.1	10.5	11.0	10.6	10.7	10.8	11.0		(38)
(39)	Clear-Sky Solar Irradiance	taub	0.321	0.329	0.361	0.400	0.429	0.455	0.490	0.485	0.412	0.359	0.335	0.316		(40)
(41)		taud	2.500	2.471	2.410	2.297	2.280	2.221	2.166	2.158	2.348	2.472	2.494	2.523		(41)
(42)		Ebn at Noon	886	918	912	886	861	834	803	799	847	871	861	870		(42)
(43)		Edh at Noon	84	96	111	130	134	142	149	148	117	95	84	78		(43)
(44)	All-Sky Solar Radiation	RadAvg	2.50	2.98	4.13	5.20	5.70	6.43	6.22	5.73	4.92	3.81	2.72	2.20		(44)
(45)		RadStd	0.22	0.42	0.36	0.36	0.44	0.49	0.35	0.42	0.38	0.52	0.30	0.24		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (25 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page