

JONESBORO, AR, USA

WMO: 723407

Lat: 35.831N

Lon: 90.646W

Elev: 262

StdP: 14.56

Time Zone: -6.00 (NAC)

Period: 96-19

WBAN: 03953

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.9	20.7	4.8	7.1	20.5	9.2	8.9	23.5	25.7	57.6	23.8	51.6	7.0	50	0.465

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.9	96.8	76.9	94.2	76.5	92.2	76.2	80.4	90.6	79.3	89.8	78.3	88.2	9.5	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.9	146.3	85.4	76.6	139.9	84.5	75.3	133.9	83.5	44.1	90.6	42.9	89.9	41.8	88.5	90.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.7	19.4	17.4	11.1	100.0	4.3	3.3	8.0	102.3	5.5	104.3	3.0	106.1	-0.1	108.5
			9.5	82.6	4.0	2.0	6.7	84.1	4.3	85.2	2.1	86.4	-0.8	87.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.9	38.7	42.5	50.7	60.9	70.1	78.9	81.2	80.0	73.7	62.1	50.0	41.3	(6)
	DBStd	17.25	10.86	10.12	9.78	8.17	7.15	5.10	4.47	4.62	6.24	8.42	8.89	9.60	(7)
	HDD50	1170	379	252	110	12	0	0	0	0	0	7	108	302	(8)
	HDD65	3461	816	631	451	170	36	0	0	0	9	157	455	736	(9)
	CDD50	5162	28	41	133	340	623	866	966	931	712	383	107	32	(10)
	CDD65	1978	0	1	9	48	194	416	501	466	271	68	4	0	(11)
	CDH74	20219	0	2	56	368	1695	4510	5589	4868	2460	638	33	0	(12)
	CDH80	8905	0	0	4	57	570	2133	2632	2285	1037	185	2	0	(13)
(14) Wind	WSAvg	7.6	8.8	9.1	9.3	9.3	7.8	7.0	6.3	6.0	5.9	6.6	7.5	8.1	(14)
(15) Precipitation	PrecAvg	46.5	3.3	3.6	4.7	5.0	5.0	3.2	2.8	3.1	3.7	3.3	4.7	4.3	(15)
	PrecMax	65.4	8.3	9.1	11.8	11.4	10.0	7.3	6.0	8.5	10.3	15.7	9.8	10.0	(16)
	PrecMin	29.1	0.7	0.3	0.3	1.8	0.6	0.4	0.1	0.0	0.4	0.0	1.2	0.6	(17)
	PrecStd	8.4	2.2	2.3	2.8	2.7	2.4	1.9	1.5	2.3	2.9	3.0	2.4	2.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.8	72.5	79.6	84.4	92.6	98.0	99.7	99.6	96.6	89.2	78.8	70.0	(19)
		MCWB	63.1	64.5	65.2	68.0	73.4	75.7	77.6	77.8	74.1	73.0	65.0	64.1	(20)
	2%	DB	64.4	67.6	75.0	81.4	89.1	95.1	96.1	96.6	92.8	84.9	72.7	64.4	(21)
		MCWB	60.3	61.9	64.2	67.1	72.0	75.8	78.0	77.3	74.5	69.4	62.4	60.3	(22)
	5%	DB	60.9	63.4	70.8	78.7	86.1	92.9	93.4	93.2	90.0	81.2	68.9	61.0	(23)
		MCWB	56.0	57.8	61.1	65.5	70.8	75.1	77.8	76.9	74.0	66.3	61.0	56.8	(24)
	10%	DB	55.4	59.1	66.4	75.0	82.8	90.5	91.2	90.7	86.4	77.0	64.3	56.3	(25)
		MCWB	50.8	53.7	58.7	64.0	69.9	74.5	77.5	76.4	72.4	64.7	58.0	52.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	64.6	66.3	68.1	72.2	77.2	80.6	82.2	81.7	78.9	76.0	69.1	65.4	(27)
		MCDB	67.4	70.1	76.2	80.3	86.4	90.2	91.5	91.7	88.8	85.2	73.9	69.0	(28)
	2%	WB	61.8	62.5	65.4	69.7	75.0	78.6	80.8	80.2	77.3	72.5	65.3	61.8	(29)
		MCDB	64.5	66.1	73.2	77.7	83.8	89.4	90.6	91.0	87.7	80.5	70.5	64.2	(30)
	5%	WB	57.0	59.1	62.8	67.9	73.3	77.4	79.7	79.0	75.7	70.1	62.5	57.5	(31)
		MCDB	59.6	63.0	69.4	75.4	82.2	88.4	89.8	89.7	85.3	76.7	67.0	60.0	(32)
	10%	WB	51.5	54.4	60.1	66.0	71.7	76.2	78.6	77.9	74.3	67.9	59.1	53.1	(33)
		MCDB	54.7	58.1	65.7	73.0	80.2	86.9	88.2	87.6	83.1	74.3	63.7	55.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	15.9	16.6	18.6	19.8	19.8	19.8	17.9	18.8	21.0	21.6	18.5	15.5	(35)
		MCDBR	20.1	21.7	22.7	22.7	22.7	22.7	20.2	21.8	24.6	26.3	23.9	19.9	(36)
		MCWBR	16.5	16.6	14.2	11.9	9.2	7.7	6.9	7.9	9.4	12.4	15.3	16.2	(37)
	5% WB	MCDBR	17.9	20.2	20.2	18.5	18.7	19.6	18.1	18.9	20.4	21.4	19.7	17.9	(38)
		MCWBR	16.3	17.0	14.1	11.7	9.0	7.7	7.4	8.2	8.9	12.3	15.7	16.1	(39)
(40) Clear-Sky Solar Irradiance	taub		0.318	0.325	0.362	0.406	0.444	0.464	0.488	0.479	0.416	0.355	0.327	0.312	(40)
	taud		2.475	2.454	2.380	2.249	2.207	2.159	2.133	2.134	2.304	2.460	2.493	2.507	(41)
	Ebn at Noon		279	291	287	279	268	262	254	254	266	276	274	274	(42)
	Edh at Noon		27	30	36	43	46	48	49	48	38	30	26	24	(43)
(44) All-Sky Solar Radiation	RadAvg		759	936	1291	1646	1839	2084	1998	1833	1548	1186	833	649	(44)
	RadStd		65	123	106	112	132	129	95	114	110	139	88	69	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page