

ARKANSAS INTL, AR, USA

WMO: 723408

Lat: 35.967N

Lon: 89.950W

Elev: 77

StdP: 100.40

Time Zone: -6.00 (NAC)

Period: 82-92

WBAN: 13814

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.3	-8.1	-17.5	0.8	-10.2	-13.9	1.1	-7.1	12.0	0.6	10.8	4.6	4.1	10	0.439

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	36.1	25.8	34.8	25.2	33.6	24.8	27.5	33.2	26.6	32.4	25.8	31.6	2.8	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.9	21.4	31.0	25.0	20.3	30.2	24.2	19.2	29.1	87.4	33.2	83.2	32.6	80.1	31.8	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.2	8.5	7.7	-14.9	37.9	5.1	2.3	-18.5	39.5	-21.5	40.8	-24.4	42.1	-28.0	43.7		
(5)			-15.6	28.4	4.9	1.0	-19.2	29.1	-22.1	29.7	-24.8	30.2	-28.4	30.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.1	2.9	5.8	11.1	15.8	21.4	26.1	27.8	26.7	23.0	16.8	10.7	4.9	(6)
(7)		DBStd	9.80	5.54	5.87	5.45	4.85	3.55	2.93	2.54	2.77	4.41	4.31	5.36	6.69	(7)
(8)		HDD10.0	670	227	138	54	9	0	0	0	0	0	3	57	182	(8)
(9)		HDD18.3	1924	480	351	231	103	13	0	0	0	14	82	233	417	(9)
(10)		CDD10.0	2908	6	21	88	183	354	482	553	517	389	213	78	24	(10)
(11)		CDD18.3	1121	0	0	6	28	109	232	294	259	154	34	4	1	(11)
(12)		CDH23.3	11411	0	1	35	218	847	2444	3431	2783	1405	228	17	1	(12)
(13)		CDH26.7	5041	0	0	3	56	267	1119	1698	1293	560	44	1	0	(13)
(14)	Wind	WSAvg	3.1	3.7	3.8	4.0	3.6	3.1	2.5	2.2	2.0	2.2	2.7	3.5	3.7	(14)
(15)	Precipitation	PrecAvg	1297	105	109	124	130	130	103	109	73	85	102	101	130	(15)
(16)		PrecMax	1640	221	222	275	280	276	199	268	135	171	259	233	321	(16)
(17)		PrecMin	968	43	41	30	34	24	37	21	15	10	0	25	24	(17)
(18)		PrecStd	184	42	48	59	60	61	40	64	42	45	61	54	69	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.1	21.5	26.8	31.2	32.9	37.3	38.6	37.2	35.2	30.1	25.4	21.3	(19)
(20)			MCWB	13.9	16.3	18.6	20.6	23.0	25.9	25.7	26.7	24.0	21.1	18.1	19.1	(20)
(21)		2%	DB	15.7	18.8	24.0	28.1	31.1	35.3	36.3	35.5	33.3	27.8	22.8	18.7	(21)
(22)			MCWB	12.9	14.0	16.8	19.8	22.8	24.8	25.9	25.9	24.2	20.1	17.8	16.7	(22)
(23)		5%	DB	13.4	16.7	21.9	25.9	29.6	33.8	34.9	34.1	32.0	26.0	21.1	16.8	(23)
(24)			MCWB	10.9	13.8	16.7	19.0	22.4	24.2	25.5	25.5	24.2	18.9	17.2	14.8	(24)
(25)		10%	DB	10.9	14.5	19.8	23.6	28.0	32.3	33.7	32.7	30.2	24.0	19.1	14.7	(25)
(26)			MCWB	8.5	11.8	15.6	17.7	21.2	23.6	25.1	25.1	23.2	17.8	15.9	12.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.8	18.3	21.1	22.7	25.5	27.5	28.6	28.8	26.7	23.1	20.3	19.4	(27)
(28)			MCD B	17.1	20.3	25.1	28.9	30.5	34.3	34.1	35.7	31.5	27.4	22.8	21.0	(28)
(29)		2%	WB	13.6	15.9	19.3	21.0	24.4	26.4	27.7	27.4	25.5	21.7	19.0	17.3	(29)
(30)			MCD B	15.1	17.3	21.9	25.4	29.1	33.2	33.1	33.3	31.2	24.9	21.3	18.6	(30)
(31)		5%	WB	11.0	14.3	17.8	20.0	23.4	25.5	26.7	26.5	24.7	20.7	17.8	15.4	(31)
(32)			MCD B	13.1	15.9	20.3	24.2	27.6	31.9	32.3	32.0	30.1	24.2	20.3	16.6	(32)
(33)		10%	WB	8.6	11.8	15.6	18.8	22.5	24.7	25.9	25.7	24.0	19.6	16.3	13.0	(33)
(34)			MCD B	10.8	14.1	19.3	22.8	26.4	30.3	31.7	31.1	28.8	22.9	19.0	14.3	(34)
(35)	Mean Daily Temperature Range	MDBR	8.0	8.6	9.7	10.3	10.0	10.5	10.3	10.4	11.0	11.1	9.1	8.3	(35)	
(36)		5% DB	MCD BR	11.6	11.9	12.0	12.9	11.5	12.3	11.7	11.6	11.8	12.5	11.4	9.7	(36)
(37)			MCWBR	9.6	8.5	7.4	6.9	5.4	4.8	4.1	4.2	5.0	6.4	8.2	8.4	(37)
(38)		5% WB	MCD BR	10.5	9.7	9.6	10.6	9.7	10.5	10.4	10.3	10.4	9.4	10.0	8.8	(38)
(39)			MCWBR	9.6	8.2	7.6	6.3	5.0	4.7	4.4	4.6	5.1	5.5	8.4	8.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.316	0.328	0.366	0.407	0.439	0.456	0.486	0.482	0.417	0.358	0.326	0.315	(40)	
(41)		taud	2.485	2.444	2.370	2.253	2.228	2.183	2.138	2.127	2.303	2.453	2.494	2.498	(41)	
(42)		Ebn at Noon	883	912	901	877	850	832	804	799	837	866	863	859	(42)	
(43)		Edh at Noon	83	97	114	135	141	147	153	152	121	95	82	78	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.36	2.90	4.02	5.18	5.80	6.52	6.29	5.76	4.86	3.73	2.61	2.01	(44)	
(45)		RadStd	0.20	0.38	0.34	0.35	0.42	0.40	0.31	0.33	0.32	0.43	0.27	0.20	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page