

BLYTHEVILLE, AR, USA

WMO: 723409

Lat: 35.940N

Lon: 89.831W

Elev: 255

StdP: 14.56

Time Zone: -6.00 (NAC)

Period: 01-19

WBAN: 53869

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.4	20.7	5.8	7.5	19.7	9.8	9.2	23.7	28.5	43.4	26.3	43.7	10.1	20	0.467

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.0	95.3	77.1	93.3	76.6	91.4	76.1	80.5	90.4	79.5	89.4	78.3	87.7	7.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.0	146.9	86.5	76.7	140.5	85.2	75.5	134.8	84.0	44.3	90.3	43.1	89.3	41.9	87.9	85.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.5	20.8	18.7	10.7	98.7	6.1	2.8	6.2	100.7	2.7	102.3	-0.8	103.8	-5.2	105.8
			9.1	82.9	5.5	1.4	5.1	83.9	1.9	84.8	-1.2	85.6	-5.2	86.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.2	39.0	41.7	51.4	61.6	71.1	79.5	80.8	79.4	73.2	62.2	50.8	42.4	(6)
	DBStd	17.22	11.12	10.73	10.47	8.77	7.46	4.72	4.29	4.77	6.56	8.91	9.44	9.28	(7)
	HDD50	1157	373	276	110	14	0	0	0	0	0	9	102	273	(8)
	HDD65	3402	808	655	433	163	36	0	0	0	12	162	432	701	(9)
	CDD50	5243	31	42	155	363	654	885	955	910	695	388	128	37	(10)
	CDD65	2010	0	1	13	62	224	435	490	445	257	76	7	0	(11)
	CDH74	20198	0	2	74	461	1879	4725	5373	4573	2376	693	41	1	(12)
	CDH80	8529	0	0	7	87	641	2149	2418	2058	959	207	3	0	(13)
(14) Wind	WSAvg	8.3	10.2	10.4	10.4	10.2	8.7	7.5	5.9	5.3	5.9	7.4	8.8	9.3	(14)
(15) Precipitation	PrecAvg	51.1	4.1	4.3	4.9	5.1	5.1	4.1	4.3	2.9	3.3	4.0	4.0	5.1	(15)
	PrecMax	64.6	8.7	8.7	10.8	11.0	10.9	7.8	10.6	5.3	6.7	10.2	9.2	12.6	(16)
	PrecMin	38.1	1.7	1.6	1.2	1.3	0.9	1.5	0.8	0.6	0.4	0.0	1.0	0.9	(17)
	PrecStd	7.2	1.7	1.9	2.3	2.4	2.4	1.6	2.5	1.7	1.8	2.4	2.1	2.7	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.9	73.2	80.8	86.0	91.7	97.4	97.0	98.9	94.9	89.5	79.1	70.2	(19)
		MCWB	63.6	64.6	65.5	68.2	72.5	75.6	78.1	77.7	74.5	72.2	66.1	62.3	(20)
	2%	DB	65.6	68.3	75.4	82.4	89.0	94.4	94.5	95.1	91.7	85.5	73.8	65.1	(21)
		MCWB	61.7	61.6	63.7	66.6	71.3	75.1	78.2	78.4	75.0	70.3	62.8	60.1	(22)
	5%	DB	61.5	63.6	71.8	79.5	86.3	92.4	92.7	92.5	89.3	81.6	70.2	61.3	(23)
		MCWB	56.9	57.1	61.5	65.0	70.3	74.6	77.7	77.8	74.3	67.2	61.0	56.5	(24)
	10%	DB	56.6	59.1	67.9	75.9	83.8	90.3	90.7	90.1	86.1	77.4	66.0	57.1	(25)
		MCWB	51.7	53.5	58.8	64.1	69.7	74.0	77.2	77.3	72.6	65.4	58.7	53.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	64.8	66.4	67.6	71.8	76.0	79.9	82.2	82.6	78.6	75.1	69.4	64.7	(27)
		MCDB	67.8	71.2	75.8	81.0	85.4	91.4	91.7	93.2	89.4	83.8	74.5	69.1	(28)
	2%	WB	62.1	63.0	65.2	69.5	74.3	78.3	80.6	80.9	77.1	72.9	65.8	61.1	(29)
		MCDB	65.2	68.0	73.3	78.5	83.6	89.5	90.2	90.9	87.6	81.8	71.9	64.6	(30)
	5%	WB	58.2	58.9	62.9	67.8	73.1	77.2	79.7	79.6	75.8	70.7	62.9	57.3	(31)
		MCDB	61.1	62.9	70.3	76.1	82.4	87.9	89.5	89.2	85.3	78.3	67.5	60.6	(32)
	10%	WB	52.5	53.9	60.4	65.9	71.8	76.1	78.5	78.2	74.5	68.1	59.7	53.5	(33)
		MCDB	56.0	58.2	66.9	73.8	80.7	86.1	87.6	87.2	83.0	75.0	65.3	56.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	16.1	16.3	18.6	19.4	18.0	18.3	17.0	18.8	21.2	21.5	19.2	15.4	(35)
		MCDBR	19.2	21.4	21.6	21.5	20.3	20.3	18.8	21.3	23.2	24.6	23.2	18.8	(36)
		MCWBR	16.4	16.1	13.3	10.2	8.0	6.7	6.9	8.3	9.3	11.4	14.4	15.0	(37)
	5% WB	MCDBR	17.9	19.0	19.5	18.3	16.8	17.7	17.1	18.4	19.5	20.1	18.6	17.0	(38)
		MCWBR	16.6	15.8	13.0	10.8	7.9	7.2	7.5	8.6	8.6	10.7	14.7	15.1	(39)
(40) Clear-Sky Solar Irradiance	taub		0.316	0.328	0.366	0.406	0.438	0.454	0.485	0.483	0.418	0.358	0.326	0.315	(40)
	taud		2.486	2.442	2.369	2.256	2.230	2.187	2.139	2.126	2.302	2.452	2.492	2.497	(41)
	Ebn at Noon		280	289	286	279	270	265	255	253	266	275	274	272	(42)
	Edh at Noon		26	31	36	43	45	47	49	48	38	30	26	25	(43)
(44) All-Sky Solar Radiation	RadAvg		748	920	1273	1642	1843	2064	1994	1826	1540	1186	829	638	(44)
	RadStd		65	121	108	110	132	128	100	105	101	137	85	62	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page