

TEXARKANA, AR, USA

WMO: 723418

Lat: 33.454N

Lon: 94.007W

Elev: 361

StdP: 14.51

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13977

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.7	26.9	8.9	8.8	29.3	13.1	10.8	33.1	22.9	54.3	20.2	53.9	6.2	60	0.420

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.1	99.2	75.7	96.6	75.8	94.1	75.6	79.2	91.0	78.4	89.9	77.7	89.0	7.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.3	139.1	83.3	75.4	134.7	82.6	74.7	131.7	82.2	42.8	91.0	42.0	90.5	41.2	89.2	83.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.8	16.7	14.8	DB	16.9	101.9	3.5	3.5	14.4	104.5	12.3	106.5	10.3	108.5	7.7	111.1
			WB	15.2	80.7	3.5	1.3	12.7	81.7	10.6	82.4	8.6	83.1	6.1	84.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	64.9	45.5	49.1	56.5	64.4	72.2	79.7	83.1	82.9	76.4	65.7	55.0	47.2
	DBStd	15.53	10.44	10.22	9.28	7.43	6.21	4.10	4.26	4.68	6.19	8.00	9.02	9.62
	HDD50	617	212	131	45	4	0	0	0	0	0	1	51	173
	HDD65	2432	607	452	287	98	17	0	0	0	4	91	318	558
	CDD50	6054	74	105	247	437	689	890	1025	1021	791	489	201	85
	CDD65	2394	4	6	25	81	241	440	560	556	345	114	17	5
	CDH74	24983	6	29	165	593	1976	4542	6677	6608	3377	920	80	10
	CDH80	11565	0	3	17	100	627	2039	3453	3514	1534	271	7	0
Wind	WSAvg	6.8	7.6	7.7	8.1	8.1	7.1	6.1	5.8	5.5	5.4	6.1	6.9	7.1
Precipitation	PrecAvg	50.2	4.2	4.0	4.7	4.4	5.0	4.3	3.3	2.6	4.1	4.8	4.1	4.4
	PrecMax	75.7	9.9	10.4	10.2	10.8	11.2	10.2	9.9	6.6	9.2	17.5	14.1	8.8
	PrecMin	26.6	0.2	0.4	1.9	1.8	0.8	0.7	0.2	0.6	0.7	0.2	0.8	0.4
	PrecStd	12.4	2.3	2.4	2.2	2.3	2.4	2.8	2.5	1.7	2.2	3.8	2.8	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.6	77.8	82.2	86.0	91.6	98.3	101.5	103.4	99.3	90.2	80.9	75.5
		MCWB	62.6	62.9	65.4	69.6	73.2	75.3	75.9	75.1	73.3	70.1	68.7	65.7
	2%	DB	70.3	73.2	78.9	82.9	88.7	94.3	98.5	99.8	94.8	86.3	76.0	71.0
		MCWB	61.5	62.0	64.6	68.3	72.9	75.7	76.4	75.6	73.3	70.1	65.4	63.7
	5%	DB	66.4	69.4	75.1	80.3	86.1	92.0	96.0	97.1	91.5	83.0	72.8	67.1
		MCWB	60.0	61.2	62.7	67.1	72.3	75.7	76.5	75.8	73.0	68.7	64.2	61.4
	10%	DB	62.9	65.6	71.6	77.5	83.6	89.8	93.5	94.4	88.7	79.3	69.7	63.3
		MCWB	56.7	58.4	61.3	65.7	71.3	75.4	76.6	75.6	72.5	67.1	62.6	58.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.9	68.3	69.2	74.0	78.0	80.5	80.3	80.0	78.1	75.4	71.1	68.4
		MCDB	71.3	72.7	77.5	81.1	86.8	90.4	92.8	92.2	87.9	83.1	76.4	72.1
	2%	WB	64.4	65.6	67.3	71.6	76.0	78.9	79.2	78.8	76.8	73.7	68.8	65.8
		MCDB	68.1	70.5	74.2	78.7	84.0	88.8	91.7	91.3	86.7	81.1	73.6	69.7
	5%	WB	61.9	63.1	65.4	70.0	74.7	77.9	78.4	78.0	75.7	72.1	66.5	62.8
		MCDB	65.5	67.7	72.5	77.1	82.5	87.5	90.5	90.2	85.1	78.6	71.0	66.1
	10%	WB	57.5	59.8	63.2	68.3	73.2	76.9	77.7	77.2	74.6	70.3	63.9	59.0
		MCDB	61.9	64.6	70.0	75.1	80.8	86.2	89.6	89.0	83.7	76.2	68.0	62.8
Mean Daily Temperature Range	5% DB	MDBR	18.1	18.3	19.8	20.3	18.4	18.2	19.1	20.2	20.6	20.7	19.2	17.6
		MCDBR	22.4	22.8	22.8	21.7	20.3	20.6	21.7	23.8	23.6	23.3	21.4	21.1
		MCWBR	15.1	14.6	12.3	10.4	8.1	6.8	5.7	6.1	7.2	10.1	12.7	14.7
	5% WB	MCDBR	18.0	19.3	19.6	18.0	17.2	17.9	19.2	19.8	19.0	17.9	18.1	18.2
		MCWBR	14.9	14.9	12.8	10.7	8.2	7.3	6.2	6.3	6.7	9.8	13.6	14.5
Clear-Sky Solar Irradiance	taub	0.326	0.332	0.363	0.392	0.428	0.452	0.472	0.467	0.407	0.360	0.340	0.324	
	taud	2.485	2.476	2.404	2.325	2.288	2.260	2.231	2.234	2.371	2.477	2.485	2.501	
	Ebn at Noon	282	292	289	284	274	266	260	259	272	278	274	276	
	Edh at Noon	28	31	36	40	43	43	44	44	36	30	27	26	
All-Sky Solar Radiation	RadAvg	835	944	1336	1659	1827	2005	1989	1866	1577	1254	899	728	
	RadStd	77	150	112	108	160	182	139	156	141	169	107	90	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (24 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page