

TEXARKANA, AR, USA

WMO: 723418

Lat: 33.454N

Lon: 94.007W

Elev: 110

StdP: 100.01

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13977

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.6	-2.8	-12.8	1.3	-1.5	-10.5	1.5	0.6	10.2	12.4	9.0	12.2	2.8	60	0.420

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	37.3	24.3	35.9	24.3	34.5	24.2	26.2	32.8	25.8	32.2	25.4	31.7	3.2	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.6	19.9	28.5	24.1	19.2	28.1	23.7	18.8	27.9	81.8	32.8	79.9	32.5	78.1	31.8	28.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.4	7.5	6.6	-8.4	38.8	2.0	2.0	-9.8	40.3	-10.9	41.4	-12.1	42.5	-13.5	43.9
			-9.3	27.1	2.0	0.7	-10.7	27.6	-11.9	28.0	-13.0	28.4	-14.4	28.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.3	7.5	9.5	13.6	18.0	22.4	26.5	28.4	28.3	24.6	18.7	12.8	8.4
	DBStd	8.63	5.80	5.68	5.16	4.13	3.45	2.28	2.37	2.60	3.44	4.45	5.01	5.34
	HDD10.0	343	118	73	25	2	0	0	0	0	0	1	28	96
	HDD18.3	1351	337	251	159	54	9	0	0	0	2	51	177	310
	CDD10.0	3363	41	58	137	243	383	494	569	567	439	272	112	47
	CDD18.3	1330	2	3	14	45	134	244	311	309	192	63	9	3
	CDH23.3	13879	3	16	92	329	1098	2523	3709	3671	1876	511	44	6
CDH26.7	6425	0	2	9	56	348	1133	1918	1952	852	151	4	0	
Wind	WSAvg	3.0	3.4	3.5	3.6	3.6	3.2	2.7	2.6	2.4	2.4	2.7	3.1	3.2
Precipitation	PrecAvg	1275	107	102	120	112	128	109	84	66	105	123	103	113
	PrecMax	1923	252	265	258	274	284	260	252	168	234	444	357	224
	PrecMin	675	5	11	48	46	20	17	5	16	19	4	20	11
	PrecStd	316	58	61	57	59	62	70	63	44	56	97	71	51
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.7	25.4	27.9	30.0	33.1	36.8	38.6	39.7	37.4	32.4	27.1	24.2
		MCWB	17.0	17.1	18.6	20.9	22.9	24.1	24.4	23.9	23.0	21.1	20.4	18.7
	2%	DB	21.3	22.9	26.0	28.3	31.5	34.6	37.0	37.7	34.9	30.2	24.5	21.7
		MCWB	16.4	16.7	18.1	20.2	22.7	24.3	24.7	24.2	22.9	21.2	18.6	17.6
	5%	DB	19.1	20.8	24.0	26.8	30.1	33.3	35.5	36.2	33.1	28.3	22.7	19.5
		MCWB	15.6	16.2	17.1	19.5	22.4	24.3	24.7	24.3	22.8	20.4	17.9	16.3
	10%	DB	17.2	18.7	22.0	25.3	28.7	32.1	34.1	34.7	31.5	26.3	20.9	17.4
		MCWB	13.7	14.7	16.3	18.7	21.9	24.1	24.8	24.2	22.5	19.5	17.0	14.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.4	20.2	20.7	23.3	25.6	26.9	26.8	26.7	25.6	24.1	21.7	20.2
		MCDB	21.8	22.6	25.3	27.3	30.4	32.4	33.8	33.4	31.1	28.4	24.7	22.3
	2%	WB	18.0	18.6	19.6	22.0	24.4	26.0	26.2	26.0	24.9	23.2	20.4	18.8
		MCDB	20.1	21.4	23.4	25.9	28.9	31.6	33.2	32.9	30.4	27.3	23.1	20.9
	5%	WB	16.6	17.3	18.6	21.1	23.7	25.5	25.8	25.6	24.3	22.3	19.2	17.1
		MCDB	18.6	19.8	22.5	25.0	28.0	30.9	32.5	32.3	29.5	25.9	21.7	19.0
	10%	WB	14.2	15.5	17.4	20.2	22.9	25.0	25.4	25.1	23.7	21.3	17.7	15.0
		MCDB	16.6	18.1	21.1	23.9	27.1	30.1	32.0	31.7	28.7	24.5	20.0	17.1
Mean Daily Temperature Range	5% DB	MDBR	10.0	10.2	11.0	11.3	10.2	10.1	10.6	11.2	11.5	11.5	10.6	9.8
		MCDBR	12.5	12.7	12.6	12.0	11.3	11.4	12.1	13.2	13.1	12.9	11.9	11.7
		MCWBR	8.4	8.1	6.8	5.8	4.5	3.8	3.2	3.4	4.0	5.6	7.1	8.2
	5% WB	MCDBR	10.0	10.7	10.9	10.0	9.6	9.9	10.7	11.0	10.6	9.9	10.1	10.1
		MCWBR	8.3	8.3	7.1	5.9	4.6	4.1	3.5	3.7	5.5	7.6	8.1	
Clear-Sky Solar Irradiance	taub	0.326	0.332	0.363	0.392	0.428	0.452	0.472	0.467	0.407	0.360	0.340	0.324	
	taud	2.485	2.476	2.404	2.325	2.288	2.260	2.231	2.234	2.371	2.477	2.485	2.501	
	Ebn at Noon	888	920	912	896	863	838	819	818	857	877	864	869	
	Edh at Noon	87	97	113	127	134	137	140	138	115	96	86	81	
All-Sky Solar Radiation	RadAvg	2.63	2.98	4.21	5.23	5.76	6.32	6.27	5.88	4.97	3.95	2.83	2.29	
	RadStd	0.24	0.47	0.35	0.34	0.50	0.57	0.44	0.49	0.44	0.53	0.34	0.28	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (24 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page