

FORT SMITH, AR, USA

WMO: 723440

Lat: 35.333N

Lon: 94.363W

Elev: 137

StdP: 99.69

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13964

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.8	(c) -5.4	(d) -15.2	(e) 1.0	(f) -4.9	(g) -12.7	(h) 1.3	(i) -2.3	(j) 11.1	(k) 6.7	(l) 9.4	(m) 9.5	(n) 3.0	(o) 320	(p) 0.439

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	37.8	24.4	36.1	24.6	34.6	24.5	26.6	33.2	26.0	32.6	25.5	31.9	3.4	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.9	20.3	29.3	24.3	19.5	28.8	23.7	18.9	28.4	83.6	33.2	81.1	32.9	78.8	32.0	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 9.1	(b) 7.9	(c) 7.0	(e) -11.3	(f) 39.4	(g) 2.2	(h) 2.4	(i) -12.9	(j) 41.2	(k) -14.2	(l) 42.6	(m) -15.5	(n) 43.9	(o) -17.1	(p) 45.7		
(a) 9.1	(b) 7.9	(c) 7.0	(e) -12.2	(f) 27.5	(g) 2.0	(h) 0.9	(i) -13.7	(j) 28.1	(k) -14.9	(l) 28.6	(m) -16.0	(n) 29.1	(o) -17.5	(p) 29.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.0	4.8	7.2	11.9	16.9	21.4	26.0	28.3	28.0	23.9	17.7	11.2	6.1
	DBStd	9.35	5.52	5.51	5.29	4.30	3.73	2.72	2.59	2.74	3.74	4.49	4.88	5.06
	HDD10.0	520	178	109	40	4	1	0	0	0	0	2	43	143
	HDD18.3	1702	421	313	207	75	16	0	0	0	5	68	217	381
	CDD10.0	3078	16	31	100	212	355	482	567	559	417	239	79	21
	CDD18.3	1218	1	1	8	32	112	232	308	301	172	47	4	1
	CDH23.3	13207	1	9	94	328	992	2454	3707	3493	1653	433	42	2
	CDH26.7	6252	0	1	14	69	329	1142	1957	1862	738	133	5	0
Wind	WSAvg	3.0	3.4	3.5	3.7	3.6	3.0	2.6	2.4	2.4	2.5	2.7	3.1	3.2
Precipitation	PrecAvg	1165	60	69	107	114	148	105	87	78	105	102	99	90
	PrecMax	1994	166	181	312	243	504	236	264	242	403	315	348	286
	PrecMin	688	6	14	13	14	29	11	0	0	0	0	7	10
	PrecStd	277	39	41	61	58	85	56	71	55	77	73	74	58
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.7	24.6	28.5	30.7	33.5	37.1	40.0	40.2	37.5	32.2	27.2	23.0
		MCWB	16.0	16.0	18.0	20.1	22.9	23.9	23.8	24.1	23.8	21.8	18.9	17.2
	2%	DB	20.2	22.0	26.0	28.6	31.6	35.0	37.6	37.9	34.6	30.1	24.3	20.2
		MCWB	14.7	15.3	17.0	19.0	22.5	24.5	24.6	24.4	23.5	20.9	17.2	15.2
	5%	DB	17.0	19.6	23.7	27.0	30.1	33.6	35.9	36.2	32.9	27.9	22.3	17.2
		MCWB	12.0	13.4	15.8	18.4	21.9	24.0	25.0	24.5	23.2	19.6	16.2	12.7
	10%	DB	13.8	16.9	21.4	25.1	28.5	32.2	34.4	34.5	31.0	25.7	19.8	14.3
		MCWB	9.6	11.4	14.5	17.5	21.3	23.8	24.9	24.4	22.3	18.7	14.5	10.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.8	18.2	19.7	22.2	25.1	26.8	27.5	27.4	26.0	23.9	20.4	18.2
		MCDB	21.4	23.0	26.1	27.7	31.0	33.0	33.1	33.4	32.2	29.6	25.3	21.9
	2%	WB	15.6	16.6	18.3	20.9	23.9	25.8	26.7	26.5	25.1	22.6	18.6	16.1
		MCDB	19.1	20.8	24.5	26.2	29.3	32.2	33.2	33.3	31.5	27.5	22.7	19.8
	5%	WB	12.9	14.5	17.0	20.0	23.0	25.2	26.1	25.8	24.3	21.5	17.2	13.7
		MCDB	15.7	18.1	22.3	25.1	28.2	31.4	32.8	32.5	30.2	25.5	21.1	16.3
	10%	WB	9.9	11.9	15.5	18.8	22.2	24.5	25.6	25.3	23.6	20.2	15.3	11.0
		MCDB	13.5	15.7	19.9	23.7	27.1	30.3	32.0	31.7	28.9	24.1	18.9	13.6
Mean Daily Temperature Range	5% DB	MDBR	11.0	11.4	12.0	12.4	10.9	10.5	10.9	11.5	11.8	12.4	11.9	10.4
		MCDBR	16.0	16.0	15.6	14.7	12.6	11.9	12.9	13.8	13.6	14.5	14.8	14.6
		MCWBR	10.4	10.0	8.2	7.0	5.0	3.9	3.4	3.5	4.4	6.2	8.9	9.8
	5% WB	MCDBR	13.3	13.6	13.1	11.8	10.8	10.8	11.2	11.5	11.4	11.4	12.8	12.3
		MCWBR	9.9	9.7	7.8	6.8	5.1	4.4	3.9	3.8	4.1	5.8	8.9	9.3
Clear-Sky Solar Irradiance	taub	0.315	0.319	0.356	0.392	0.425	0.443	0.464	0.462	0.403	0.355	0.329	0.306	
	taud	2.485	2.483	2.406	2.313	2.283	2.260	2.245	2.224	2.359	2.475	2.500	2.522	
	Ebn at Noon	888	927	914	892	863	844	823	818	854	873	865	877	
	Edh at Noon	84	94	111	128	134	137	138	138	115	94	82	76	
All-Sky Solar Radiation	RadAvg	2.52	2.98	4.07	5.08	5.59	6.34	6.33	5.80	4.94	3.74	2.70	2.17	
	RadStd	0.24	0.41	0.26	0.30	0.51	0.67	0.39	0.38	0.36	0.50	0.32	0.28	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+134	+92
Regional (28 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page