

SMITH FIELD, AR, USA

WMO: 723443

Lat: 36.191N

Lon: 94.491W

Elev: 1193

StdP: 14.07

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 53955

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.3	16.2	0.4	5.9	13.2	5.0	7.4	18.9	26.6	48.8	24.5	49.9	7.3	320	0.474

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.0	97.0	74.6	93.0	74.7	90.5	74.4	77.7	90.2	76.6	88.8	75.6	87.4	8.2	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.5	130.2	84.3	72.8	127.1	83.6	72.2	124.5	82.9	41.9	89.8	40.8	89.2	39.9	87.8	82.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.7	20.4	18.3	4.3	99.6	5.3	4.9	0.5	103.1	-2.6	106.0	-5.6	108.8	-9.4	112.3		
			2.9	79.3	4.9	1.5	-0.6	80.4	-3.5	81.3	-6.2	82.2	-9.8	83.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	58.6	36.8	41.0	49.2	58.4	66.7	74.3	79.2	78.4	70.3	59.7	48.9	39.4
	DBStd	17.09	11.29	11.31	10.60	8.85	7.21	5.35	4.92	5.28	7.19	8.70	9.48	10.19
	HDD50	1398	428	291	144	28	1	0	0	0	19	134	353	
	HDD65	3869	873	673	497	229	70	5	0	1	32	208	488	793
	CDD50	4550	21	39	119	281	518	730	906	881	610	321	99	25
	CDD65	1542	0	1	6	32	122	285	441	417	191	44	3	0
	CDH74	14679	0	6	35	214	894	2584	4687	4248	1640	353	18	0
	CDH80	6165	0	1	2	31	209	954	2247	2049	599	72	1	0
	WSAvg	7.9	8.8	9.1	9.7	10.0	8.0	7.1	6.2	5.9	6.3	7.2	8.4	8.5
	PrecAvg	46.0	2.6	2.3	3.7	4.6	5.9	4.6	3.8	3.0	4.3	3.9	3.8	3.1
Precipitation	PrecMax	67.0	6.8	6.2	9.3	12.4	11.5	12.3	10.7	5.7	10.6	9.9	9.7	12.5
	PrecMin	32.5	0.2	0.4	0.7	1.8	2.2	1.1	1.1	0.3	0.4	1.3	0.5	0.4
	PrecStd	8.6	1.8	1.6	1.9	2.5	2.2	2.6	2.2	1.5	2.2	1.9	2.8	2.3
	PrecStd	8.6	1.8	1.6	1.9	2.5	2.2	2.6	2.2	1.5	2.2	1.9	2.8	2.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	68.2	72.6	78.7	83.7	88.4	95.1	100.2	100.4	96.5	85.9	76.8	69.2	
	0.4% MCWB	57.3	59.4	62.7	66.4	71.7	75.6	73.7	74.5	72.8	69.8	62.2	60.3	
	2% DB	63.6	66.5	73.1	79.4	84.3	90.8	96.9	97.2	90.2	81.7	71.9	64.1	
	2% MCWB	54.8	56.4	59.9	64.0	70.9	74.8	75.1	74.2	72.0	66.3	60.0	56.6	
	5% DB	59.2	63.3	70.0	75.4	81.9	88.3	93.0	93.1	87.4	78.6	67.8	60.9	
	5% MCWB	51.9	54.0	57.6	62.0	69.6	74.1	75.4	74.2	71.5	64.3	58.9	53.3	
	10% DB	54.6	59.3	65.8	72.7	79.3	85.6	90.5	90.4	82.5	73.4	64.1	55.2	
	10% MCWB	47.3	51.0	56.0	60.6	67.7	73.1	75.4	74.0	69.3	62.7	55.8	48.4	
	0.4% WB	60.2	62.5	65.1	69.0	74.9	78.2	79.3	79.2	75.9	71.6	65.9	62.2	
	0.4% MCDB	66.1	69.6	75.4	79.4	84.0	89.9	89.9	91.5	87.7	81.6	72.6	67.4	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	56.7	59.0	62.1	66.6	73.0	76.6	77.8	77.5	74.6	69.0	62.6	58.3	
	2% MCDB	61.6	64.8	71.1	76.3	82.2	87.8	90.2	90.4	85.7	78.4	68.6	63.5	
	5% WB	52.6	55.7	59.6	64.5	71.1	75.2	76.8	76.2	73.0	66.8	59.9	54.3	
	5% MCDB	57.9	61.8	67.0	73.0	79.7	85.3	89.3	88.9	83.6	74.8	66.0	59.2	
	10% WB	47.5	51.5	56.9	62.8	69.1	73.9	75.8	75.1	71.2	64.4	57.1	50.2	
	10% MCDB	54.2	58.4	64.8	71.1	77.8	83.8	88.1	87.4	80.4	72.3	63.0	55.0	
Mean Daily Temperature Range	MDBR	18.8	19.4	20.0	20.8	19.1	18.9	20.0	20.5	20.2	21.8	19.7	17.8	
	5% DB MCDBR	23.9	24.0	23.7	22.8	20.8	21.6	23.3	24.9	23.5	24.4	23.1	23.6	
	5% DB MCWBR	17.0	17.1	15.0	13.7	11.4	10.1	8.8	9.1	10.5	13.2	15.5	17.2	
	5% WB MCDBR	20.2	20.9	20.0	19.3	18.4	19.0	20.5	20.6	19.2	20.0	20.4	19.9	
	5% WB MCWBR	16.3	16.7	14.5	13.4	10.9	10.2	9.2	8.9	9.8	12.3	16.0	16.4	
	5% WB MCWBR	16.3	16.7	14.5	13.4	10.9	10.2	9.2	8.9	9.8	12.3	16.0	16.4	
Clear-Sky Solar Irradiance	taub	0.303	0.306	0.342	0.379	0.422	0.424	0.443	0.444	0.388	0.345	0.313	0.292	
	taud	2.486	2.488	2.418	2.323	2.256	2.277	2.274	2.247	2.372	2.479	2.520	2.533	
	Ebn at Noon	285	298	294	286	274	273	266	264	274	279	279	282	
	Edh at Noon	26	29	35	40	43	43	43	43	36	29	25	23	
All-Sky Solar Radiation	RadAvg	781	948	1277	1607	1784	2039	2032	1842	1570	1166	842	666	
	RadStd	71	135	76	93	154	187	124	123	116	152	94	85	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page