

MONETT, MO, USA

WMO: 723490

Lat: 36.910N

Lon: 94.015W

Elev: 437

StdP: 96.18

Time Zone: -6.00 (NAC)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.9	-10.2	-17.8	0.8	-11.9	-15.2	1.1	-8.3	12.6	11.7	11.4	9.1	2.9	0	0.479

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.7	36.0	24.3	33.0	24.4	32.3	24.1	26.4	33.3	25.7	31.9	24.9	30.4	3.3	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.1	20.1	30.6	23.8	19.6	29.8	22.9	18.6	28.1	85.2	33.8	81.5	31.9	78.0	30.3	28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.7	9.1	8.1	DB	-17.2	35.8	2.8	1.0	-19.2	36.5	-20.8	37.0	-22.4	37.6	-24.4	38.3	(4)
(5)			WB	-18.1	27.3	2.9	0.7	-20.3	27.8	-22.0	28.2	-23.6	28.6	-25.7	29.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.0	1.4	3.4	8.9	13.7	18.2	24.0	25.7	24.8	21.2	14.3	8.4	3.5
	DBStd	9.83	6.43	6.73	6.09	4.81	4.65	2.98	3.04	3.29	3.92	5.22	5.39	5.59
	HDD10.0	909	272	203	93	21	3	0	0	0	0	18	89	211
	HDD18.3	2375	524	419	296	149	61	2	1	1	17	146	300	459
	CDD10.0	2375	6	17	59	132	259	419	486	458	337	152	41	9
	CDD18.3	798	0	1	4	10	58	171	228	201	104	22	1	0
	CDH23.3	7319	0	3	22	74	404	1546	2337	1947	843	136	6	0
CDH26.7	2954	0	0	1	5	77	588	1079	883	302	19	0	0	
Wind	WSAvg	3.5	3.9	4.2	4.3	4.3	3.4	3.1	2.6	2.7	2.7	3.3	3.7	3.6
Precipitation	PrecAvg	1213	69	60	94	117	162	137	108	75	142	90	87	70
	PrecMax	1610	200	140	219	250	333	252	222	167	348	278	216	172
	PrecMin	937	11	9	20	36	40	56	35	6	23	19	0	5
	PrecStd	189	43	38	50	56	68	66	42	37	75	59	65	44
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.8	22.4	26.1	27.4	30.3	33.9	37.7	38.9	34.0	28.7	24.0	19.9
		MCWB	13.9	15.7	17.5	18.8	21.8	25.6	24.6	25.4	23.2	21.6	17.9	15.1
	2%	DB	17.0	19.0	22.7	25.9	28.1	32.7	36.1	36.1	32.1	27.1	21.1	17.2
		MCWB	11.3	13.9	16.2	17.9	21.6	25.1	24.0	24.7	23.2	19.8	15.3	12.8
	5%	DB	13.7	17.1	20.8	23.1	27.4	32.0	33.8	32.9	30.2	24.9	18.9	14.1
		MCWB	9.2	13.0	14.6	16.7	21.0	24.7	24.5	24.0	22.8	18.3	14.8	9.9
	10%	DB	10.9	13.9	17.8	22.1	26.1	30.2	32.3	31.4	27.9	22.4	17.1	12.2
		MCWB	7.3	10.5	13.0	16.4	20.2	23.7	24.3	23.4	21.7	17.9	12.7	8.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.6	17.0	18.6	20.8	24.0	26.7	27.3	27.4	24.9	22.6	18.9	16.2
		MCDB	18.7	20.6	24.9	25.8	28.1	33.0	33.2	36.8	31.2	27.2	22.3	18.5
	2%	WB	11.9	15.3	17.1	19.4	22.9	25.8	26.4	26.4	24.0	21.4	17.1	13.9
		MCDB	14.8	18.4	22.2	23.5	27.2	31.6	33.4	33.7	30.0	24.7	19.3	15.9
	5%	WB	9.8	13.6	15.5	18.1	21.9	25.1	25.7	25.4	23.3	20.2	15.1	11.4
		MCDB	13.6	16.3	19.2	22.0	26.2	30.5	32.1	31.5	28.9	23.1	18.1	13.1
	10%	WB	7.5	10.7	14.0	17.2	20.8	24.2	24.9	24.4	22.5	18.8	13.1	9.5
		MCDB	9.9	14.0	17.5	20.5	24.4	29.0	30.6	29.6	27.3	22.1	16.2	11.5
Mean Daily Temperature Range	5% DB	MDBR	9.9	10.1	10.7	11.3	10.1	10.1	10.7	10.7	10.6	10.7	10.9	9.0
		MCDBR	14.0	13.5	13.2	12.6	11.4	11.1	13.0	13.2	11.7	12.2	12.8	12.6
		MCWBR	9.4	9.3	7.8	7.7	6.0	5.1	4.5	5.0	4.8	6.4	8.9	8.5
	5% WB	MCDBR	12.3	12.0	11.6	11.3	10.4	10.6	11.1	11.6	10.8	9.9	11.7	10.9
		MCWBR	9.4	9.1	7.9	7.8	6.0	5.5	5.0	5.4	4.8	6.2	9.1	9.1
Clear-Sky Solar Irradiance	taub	0.298	0.305	0.337	0.373	0.415	0.415	0.436	0.436	0.379	0.338	0.306	0.288	
	taud	2.467	2.460	2.411	2.324	2.264	2.290	2.284	2.257	2.386	2.479	2.515	2.517	
	Ebn at Noon	897	935	929	908	870	867	846	838	872	883	881	888	
	Edh at Noon	83	94	109	125	136	132	132	133	110	91	78	74	
All-Sky Solar Radiation	RadAvg	2.41	2.98	3.99	5.06	5.64	6.47	6.37	5.76	4.91	3.62	2.58	2.04	
	RadStd	0.22	0.42	0.24	0.30	0.46	0.53	0.39	0.39	0.38	0.44	0.28	0.25	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A
(47) Regional (26 neighbors)		(m) N/A	(n) N/A	(o) N/A	(p) N/A	(q) N/A	(r) N/A	(s) N/A	(t) N/A	(u) N/A

Nomenclature: See separate page