

CLINTON SHERMAN, OK, USA

WMO: 723526

Lat: 35.357N

Lon: 99.204W

Elev: 1922

StdP: 13.70

Time Zone: -6.00 (NAC)

Period: 96-19

WBAN: 03932

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.1	18.7	0.8	6.1	20.3	6.0	8.0	25.9	33.8	42.9	31.5	43.0	12.6	10	0.657

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.9	101.9	70.7	99.6	71.3	97.2	71.2	75.9	90.2	74.7	89.4	73.6	89.0	14.2	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
72.3	128.5	81.8	71.1	123.0	80.4	70.0	118.6	79.5	40.7	89.8	39.5	89.5	38.5	89.0	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
30.4	27.2	25.1	7.0	105.3	4.1	3.3	4.1	107.7	1.7	109.7	-0.6	111.5	-3.6	113.9		
			5.7	78.2	3.7	2.3	3.1	79.9	0.9	81.2	-1.2	82.4	-3.9	84.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.3	39.6	42.4	50.9	59.4	69.9	79.1	83.7	82.4	74.8	62.1	49.7	40.2
	DBStd	18.04	9.98	10.57	10.09	8.77	8.28	5.98	5.30	5.67	7.10	9.11	9.58	9.42
	HDD50	1185	342	252	111	22	1	0	0	0	0	16	118	323
	HDD65	3524	787	634	444	208	47	1	0	0	10	162	462	769
	CDD50	5308	20	38	140	304	619	873	1043	1006	744	391	111	19
	CDD65	2172	0	0	8	40	200	424	578	541	304	72	5	0
	CDH74	25544	3	20	102	425	2095	4872	7583	6659	3077	651	56	1
	CDH80	13410	0	3	19	119	919	2534	4415	3753	1437	203	8	0
Wind	WSAvg	13.1	13.1	13.6	14.6	14.6	13.3	13.8	12.1	11.2	12.0	13.3	13.4	12.9
Precipitation	PrecAvg	27.5	0.9	1.1	2.0	2.8	4.1	3.8	2.2	3.1	2.5	2.8	1.5	1.2
	PrecMax	45.1	2.8	3.0	5.5	7.8	13.1	9.0	5.2	8.5	6.9	6.0	5.7	2.8
	PrecMin	18.4	0.0	0.1	0.0	0.3	0.4	0.4	0.2	0.0	0.1	0.3	0.1	0.2
	PrecStd	7.0	0.7	0.8	1.6	1.9	2.8	2.2	1.5	2.0	1.5	1.5	1.4	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.5	77.1	82.0	88.9	98.6	102.9	106.0	105.7	100.3	90.5	80.6	69.6
		MCWB	52.2	54.1	58.2	63.2	68.4	69.9	70.4	70.9	69.4	65.5	60.9	52.2
	2%	DB	64.7	70.0	76.4	82.7	93.1	99.1	102.0	101.6	95.5	85.6	73.9	63.6
		MCWB	48.1	53.3	58.6	63.1	68.3	71.1	71.0	70.8	70.3	65.7	58.1	51.4
	5%	DB	60.5	63.8	72.1	79.1	89.8	95.7	99.7	99.3	91.6	81.2	69.8	59.2
		MCWB	46.4	50.7	57.8	61.6	67.8	71.0	71.5	71.6	69.7	63.6	56.5	48.3
	10%	DB	54.8	59.1	67.5	74.7	84.7	92.4	97.3	96.7	88.5	77.0	64.2	54.7
		MCWB	44.2	48.5	54.8	60.4	66.6	71.0	71.8	71.0	68.7	61.9	54.0	45.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.3	60.6	66.1	69.6	74.3	77.5	78.0	76.7	74.7	71.7	65.6	60.0
		MCDB	65.3	65.6	74.6	79.9	88.0	91.4	92.7	90.9	89.1	81.6	72.5	63.5
	2%	WB	51.5	56.1	63.0	67.4	72.3	75.5	76.0	75.2	73.0	69.5	61.2	54.2
		MCDB	60.8	65.0	70.6	76.6	85.7	89.0	91.0	89.4	87.0	78.1	69.2	59.5
	5%	WB	47.8	52.6	60.1	65.3	70.7	74.1	74.6	74.1	71.8	67.5	58.9	49.7
		MCDB	58.9	62.8	67.6	74.0	83.7	88.3	90.1	89.3	84.5	75.1	65.7	58.2
	10%	WB	44.8	48.9	56.5	62.9	69.1	72.9	73.5	73.1	70.7	65.2	56.1	45.7
		MCDB	54.4	58.9	66.4	71.1	81.4	87.1	89.6	88.7	83.2	73.7	63.7	53.9
Mean Daily Temperature Range	5% DB	MDBR	21.6	21.6	22.7	22.8	22.9	22.2	22.9	22.5	21.8	21.8	21.2	19.8
		MCDBR	29.8	29.9	28.6	28.2	27.7	25.9	26.2	26.0	25.3	26.6	27.2	26.7
		MCWBR	17.0	17.3	15.5	14.2	10.6	8.2	6.5	7.2	8.2	11.9	14.5	15.8
	5% WB	MCDBR	27.1	27.1	23.0	23.1	24.1	22.7	22.3	22.2	21.2	20.0	21.6	23.6
		MCWBR	16.7	17.5	14.4	13.8	11.0	9.4	7.4	7.5	7.9	11.5	14.2	16.1
Clear-Sky Solar Irradiance	taub	0.277	0.288	0.327	0.358	0.376	0.404	0.407	0.399	0.366	0.342	0.305	0.281	
	taud	2.537	2.514	2.419	2.362	2.382	2.342	2.362	2.335	2.404	2.456	2.497	2.525	
	Ebn at Noon	298	306	300	294	288	279	277	278	282	281	283	289	
	Edh at Noon	25	29	35	39	38	40	39	39	35	30	26	24	
All-Sky Solar Radiation	RadAvg	942	1149	1517	1866	2024	2240	2227	2013	1691	1275	981	801	
	RadStd	88	145	102	139	211	189	118	117	107	168	122	78	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	-1.37	N/A	N/A	N/A
(47)	Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page