

OKLAHOMA CITY ROGERS, OK, USA

WMO: 723530

Lat: 35.389N

Lon: 97.601W

Elev: 1285

StdP: 14.03

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13967

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.6	19.0	1.8	6.3	19.2	6.3	8.0	24.1	32.2	40.5	28.8	43.1	11.7	0	0.577

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.6	100.6	73.9	97.6	74.2	94.7	74.3	78.1	91.3	77.1	90.3	76.1	89.2	12.1	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.5	135.2	84.1	73.4	130.2	82.8	72.4	125.8	81.9	42.5	91.3	41.3	90.3	40.3	89.2	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.9	25.2	23.0	7.3	103.7	4.8	3.8	3.8	106.4	1.1	108.7	-1.6	110.8	-5.1	113.6
			6.0	79.8	4.5	1.5	2.7	80.9	0.1	81.8	-2.5	82.6	-5.7	83.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.3	39.2	43.2	52.0	60.4	69.3	77.9	82.5	81.8	74.0	62.3	50.7	40.8
	DBStd	17.40	10.22	11.17	10.57	8.29	7.30	5.05	4.70	5.05	7.09	8.53	9.27	9.46
	HDD50	1133	355	241	101	15	1	0	0	0	0	10	102	308
	HDD65	3398	799	612	415	181	42	1	0	0	13	152	434	749
	CDD50	5250	22	51	164	327	600	836	1007	985	720	391	123	24
	CDD65	2038	0	2	13	43	175	387	542	520	283	68	5	0
	CDH74	22356	3	24	129	408	1557	4045	6657	6120	2751	607	54	1
	CDH80	10850	0	5	23	91	521	1855	3660	3305	1220	165	5	0
Wind	WSAvg	11.3	11.6	12.1	13.2	13.6	11.8	10.9	9.5	9.1	9.5	10.9	11.6	11.2
Precipitation	PrecAvg	34.6	1.1	1.5	2.6	3.1	5.3	4.4	3.0	3.0	3.7	3.3	2.0	1.5
	PrecMax	58.5	3.7	4.6	8.0	7.6	19.5	14.6	9.8	10.0	11.9	13.2	8.0	8.1
	PrecMin	18.1	0.0	0.0	0.0	0.2	0.9	0.6	0.0	0.0	0.6	0.4	0.0	0.1
	PrecStd	8.2	0.9	1.1	1.8	1.8	3.8	2.9	2.2	2.1	2.5	2.5	1.9	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.8	77.3	83.1	87.6	93.9	99.3	104.5	104.7	101.0	89.1	80.0	70.6
		MCWB	53.1	57.4	62.2	65.4	71.9	74.3	73.0	73.3	72.0	68.7	63.4	57.1
	2%	DB	65.9	71.2	77.5	82.4	89.0	95.1	100.9	100.4	94.3	84.6	74.4	65.4
		MCWB	52.1	55.1	60.2	64.6	71.7	74.5	74.2	73.8	72.9	67.6	60.3	55.3
	5%	DB	60.9	65.7	73.3	78.7	85.7	92.1	97.8	97.5	90.6	80.8	70.0	60.5
		MCWB	49.5	53.7	58.8	63.1	70.3	74.1	74.7	74.1	72.2	65.9	58.8	50.8
	10%	DB	55.8	60.9	68.9	75.1	82.3	89.5	94.8	94.2	87.2	76.8	66.1	56.2
		MCWB	46.3	51.2	56.9	62.0	69.5	74.0	74.9	74.2	71.1	64.4	56.4	48.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.9	62.7	66.7	71.4	76.3	79.4	79.5	79.0	76.9	73.4	67.4	63.0
		MCDB	64.7	69.4	76.3	80.0	87.0	91.7	93.2	92.5	88.8	82.7	73.3	67.6
	2%	WB	55.0	59.5	64.2	68.6	74.3	77.5	78.1	77.5	75.2	71.3	63.6	57.4
		MCDB	61.7	65.7	73.2	76.8	84.6	89.1	92.0	91.3	87.8	79.3	70.8	61.8
	5%	WB	50.6	56.1	62.0	66.9	72.8	76.3	77.1	76.5	74.1	69.3	61.3	52.8
		MCDB	58.5	63.5	70.1	74.7	82.5	87.9	91.0	90.4	85.7	76.1	67.2	58.4
	10%	WB	46.7	51.6	59.0	64.6	71.1	75.0	76.1	75.3	72.9	67.0	58.4	48.3
		MCDB	55.0	60.9	67.0	72.1	79.9	86.3	89.7	89.2	83.6	74.0	64.6	55.2
Mean Daily Temperature Range	5% DB	MDBR	20.9	21.3	21.7	21.8	19.9	19.8	21.6	21.5	20.9	21.5	21.4	19.6
		MCDBR	29.4	29.3	27.4	26.3	23.1	23.0	26.0	26.3	25.0	25.6	26.8	26.8
		MCWBR	17.6	17.0	14.8	13.9	10.5	8.4	7.3	7.7	9.0	12.3	15.5	16.9
	5% WB	MCDBR	25.4	24.9	22.2	21.1	20.2	19.9	21.7	21.3	20.7	19.2	21.6	22.3
		MCWBR	17.3	17.1	13.6	13.5	10.8	9.1	8.0	7.8	8.3	11.3	15.5	17.3
Clear-Sky Solar Irradiance	taub	0.293	0.298	0.338	0.376	0.414	0.423	0.424	0.433	0.387	0.345	0.311	0.289	
	taud	2.508	2.509	2.419	2.327	2.294	2.309	2.337	2.256	2.364	2.473	2.504	2.520	
	Ebn at Noon	291	302	296	288	277	273	272	268	276	280	281	285	
	Edh at Noon	26	29	35	40	42	41	40	43	36	30	26	24	
All-Sky Solar Radiation	RadAvg	887	1075	1410	1743	1882	2144	2168	1971	1631	1240	934	748	
	RadStd	89	162	89	131	203	202	117	121	142	160	122	83	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page