

OKLAHOMA CITY POST, OK, USA

WMO: 723544

Lat: 35.534N

Lon: 97.647W

Elev: 395

StdP: 96.67

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 03954

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.8	-7.4	-17.0	0.9	-7.3	-14.0	1.2	-4.4	13.4	6.5	12.4	8.6	4.8	0	0.604

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	37.9	23.1	36.6	23.2	35.0	23.4	25.4	33.1	24.9	32.4	24.3	31.8	5.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.1	18.8	28.9	22.7	18.2	28.5	22.3	17.8	28.1	80.2	33.0	77.5	32.5	75.3	31.8	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.3	11.2	10.4	DB	-14.3	40.2	2.5	2.0	-16.1	41.6	-17.6	42.8	-19.0	44.0	-20.8	45.4	(4)
			WB	-15.0	26.7	2.3	1.3	-16.7	27.7	-18.0	28.4	-19.3	29.1	-20.9	30.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.4	4.0	6.3	11.1	15.9	20.9	25.8	28.6	28.0	23.6	16.9	10.3	4.8
	DBStd	9.92	5.81	6.36	6.03	4.88	4.26	3.09	2.95	3.06	4.15	4.94	5.39	5.50
	HDD10.0	646	199	136	58	10	1	0	0	0	0	7	61	175
	HDD18.3	1899	444	339	232	102	24	1	0	0	8	86	244	419
	CDD10.0	2982	13	31	93	186	339	474	576	557	407	222	70	14
	CDD18.3	1193	0	1	8	28	104	225	317	299	164	42	3	0
	CDH23.3	13502	1	12	71	239	938	2468	4084	3663	1644	353	27	1
	CDH26.7	6510	0	2	13	55	316	1129	2238	1948	711	94	2	0
Wind	WSAvg	5.3	5.2	5.4	5.9	6.1	5.6	5.4	4.9	4.6	4.6	5.1	5.3	5.0
Precipitation	PrecAvg	827	25	30	57	85	120	111	81	76	82	71	44	36
	PrecMax	1236	72	67	166	173	361	270	203	176	176	199	146	126
	PrecMin	515	0	0	0	7	29	21	6	0	15	12	0	0
	PrecStd	196	20	21	39	42	72	69	51	48	40	45	37	28
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.4	25.0	28.5	30.9	34.0	37.6	40.4	40.3	37.8	31.6	26.3	21.3
		MCWB	12.2	14.2	16.8	18.6	21.9	23.3	22.6	22.5	22.0	20.7	17.5	14.3
	2%	DB	18.7	22.0	25.2	28.0	32.0	35.3	38.2	37.8	34.3	29.1	23.4	18.4
		MCWB	11.0	13.1	15.9	18.1	21.9	23.4	23.2	23.0	22.7	19.7	15.7	12.8
	5%	DB	16.1	18.9	22.8	26.1	30.1	33.6	37.0	36.3	32.6	27.3	21.2	16.0
		MCWB	9.6	12.4	15.2	17.3	21.3	23.3	23.5	23.2	22.3	18.8	14.6	10.5
	10%	DB	13.2	16.3	20.6	24.0	28.1	32.3	35.1	34.5	30.9	25.1	18.8	13.6
		MCWB	7.9	10.8	14.2	16.6	20.7	23.1	23.7	23.2	21.8	17.6	13.6	9.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.1	17.0	19.5	21.6	24.5	26.2	26.3	26.0	24.9	23.1	19.4	17.2
		MCDB	18.4	20.6	24.9	27.4	30.7	33.9	34.3	33.8	32.1	27.9	23.6	19.5
	2%	WB	12.7	15.4	18.0	20.2	23.3	25.2	25.4	25.2	23.9	21.8	17.3	14.0
		MCDB	16.6	19.2	22.8	25.1	29.3	32.3	33.3	32.8	30.9	26.5	21.1	16.6
	5%	WB	10.2	13.4	16.7	19.2	22.5	24.5	24.9	24.5	23.2	20.7	16.0	11.5
		MCDB	14.9	17.9	21.2	23.8	28.2	31.3	32.7	32.2	29.8	24.9	19.5	14.7
	10%	WB	8.1	11.0	15.1	18.0	21.6	23.8	24.3	23.9	22.6	19.4	14.5	9.0
		MCDB	12.7	16.2	19.4	22.5	27.0	30.4	32.1	31.6	28.8	23.6	18.3	13.1
Mean Daily Temperature Range	5% DB	MDBR	11.5	11.6	11.8	11.8	10.8	10.5	11.1	11.0	11.1	11.5	11.6	10.6
		MCDBR	15.7	15.3	14.3	13.8	12.3	11.9	12.9	13.1	12.6	13.1	14.2	14.1
		MCWBR	9.6	9.0	7.8	7.3	5.4	4.3	3.6	3.9	4.5	6.4	8.2	9.0
	5% WB	MCDBR	13.8	13.0	11.7	11.2	10.7	10.4	11.1	10.7	10.6	10.3	11.7	11.9
	MCWBR	9.5	9.0	7.5	7.2	5.7	4.8	4.1	4.1	4.3	6.1	8.4	9.4	
Clear-Sky Solar Irradiance	taub	0.292	0.297	0.337	0.377	0.414	0.423	0.424	0.433	0.386	0.345	0.310	0.288	
	taud	2.507	2.508	2.417	2.324	2.291	2.308	2.334	2.253	2.365	2.470	2.505	2.521	
	Ebn at Noon	917	952	933	907	873	861	858	843	870	883	887	899	
	Edh at Noon	81	91	109	126	132	130	126	134	114	94	81	76	
All-Sky Solar Radiation	RadAvg	2.79	3.39	4.44	5.50	5.95	6.78	6.84	6.21	5.15	3.90	2.94	2.35	
	RadStd	0.28	0.51	0.28	0.41	0.64	0.63	0.37	0.38	0.44	0.50	0.38	0.26	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.48	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+85
Regional (36 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page