

SOCORRO, NM, USA

WMO: 723620

Lat: 34.022N

Lon: 106.903W

Elev: 4875

StdP: 12.29

Time Zone: -7.00 (NAM)

Period: 09-19

WBAN: 93040

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.1	21.4	-4.4	5.2	39.4	-0.6	6.4	42.9	27.5	45.3	24.6	45.6	6.7	330	0.497

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	30.9	99.1	60.1	96.7	60.0	94.6	59.8	66.0	80.3	65.1	80.0	64.2	80.2	9.5	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.9	103.0	69.2	61.4	97.5	69.0	59.9	92.3	69.2	33.6	80.2	32.8	79.0	32.0	79.2	69.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
24.6	20.4	17.9	DB	9.5	102.9	9.0	1.7	3.0	104.1	-2.3	105.1	-7.4	106.0	-14.0	107.3	(4)
			WB	7.9	68.0	8.3	1.5	1.9	69.0	-3.0	69.9	-7.7	70.7	-13.8	71.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	60.5	39.2	45.4	53.9	60.4	67.0	79.5	80.1	77.8	72.4	61.1	48.4	39.4	(6)
		DBStd	15.85	6.47	8.46	6.70	6.73	6.92	4.40	3.59	3.51	4.84	6.55	7.01	7.76	(7)
		HDD50	1001	337	166	38	7	1	0	0	0	7	112	333		(8)
		HDD65	3358	799	548	344	163	59	0	0	0	5	150	497	793	(9)
		CDD50	4825	4	38	160	320	529	886	932	861	673	352	65	5	(10)
		CDD65	1709	0	0	2	27	122	436	467	396	228	31	0	0	(11)
		CDH74	21457	0	8	173	654	2003	6067	5383	4234	2392	535	8	0	(12)
		CDH80	10714	0	0	18	143	814	3530	2921	2137	1036	115	0	0	(13)
(14)	Wind	WSAvg	7.4	6.9	7.4	8.3	9.2	8.9	7.7	6.8	6.3	6.7	6.8	7.1	6.9	(14)
(15)	Precipitation	PrecAvg	9.3	0.4	0.4	0.4	0.4	0.6	1.5	1.9	1.5	1.1	0.5	0.6		(15)
(16)		PrecMax	14.0	1.8	1.4	2.1	2.8	1.7	3.0	3.9	6.3	4.8	5.4	1.6	2.3	(16)
(17)		PrecMin	4.5	0.0	0.0	0.0	0.0	0.0	0.2	0.2	0.1	0.0	0.0	0.0		(17)
(18)		PrecStd	2.4	0.4	0.4	0.4	0.6	0.4	0.7	1.0	1.3	1.1	0.5	0.7		(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	66.2	75.0	82.3	87.9	94.7	102.4	100.7	98.8	95.0	87.5	75.1	66.3		(19)
(20)		0.4% MCWB	44.2	47.9	50.9	52.5	55.9	59.8	61.1	61.8	60.6	56.7	49.6	46.0		(20)
(21)		2% DB	60.8	70.9	78.9	84.0	91.1	100.0	98.0	95.5	92.0	83.0	71.8	62.1		(21)
(22)		2% MCWB	42.5	46.6	49.0	51.7	54.9	59.5	61.1	61.6	60.3	55.4	49.3	43.5		(22)
(23)		5% DB	56.8	66.6	75.0	81.1	88.1	97.7	95.8	93.3	89.9	80.3	67.2	57.2		(23)
(24)		5% MCWB	40.4	44.5	47.5	50.8	53.8	58.8	61.1	61.8	59.9	54.5	47.3	41.8		(24)
(25)		10% DB	52.5	62.2	71.1	78.0	84.7	95.2	93.3	90.8	86.7	76.8	62.8	52.7		(25)
(26)		10% MCWB	38.1	42.6	45.9	49.5	52.7	57.9	61.2	61.7	59.2	53.2	45.3	39.9		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	47.7	49.7	51.9	55.3	59.2	64.1	66.5	67.7	66.4	63.2	53.0	47.9		(27)
(28)		0.4% MCDB	61.1	71.9	76.3	76.4	85.4	88.0	79.3	82.7	77.9	72.4	65.3	61.5		(28)
(29)		2% WB	43.8	47.3	50.1	53.3	56.8	62.5	65.5	66.3	65.2	59.7	50.7	45.5		(29)
(30)		2% MCDB	56.7	67.5	75.1	76.0	82.3	87.1	79.7	81.6	77.3	71.3	64.0	58.5		(30)
(31)		5% WB	41.6	45.4	48.4	51.7	55.1	61.5	64.7	65.2	63.9	57.4	49.0	43.0		(31)
(32)		5% MCDB	54.4	64.9	72.1	76.7	82.0	86.7	80.6	80.6	76.5	71.6	63.4	54.5		(32)
(33)		10% WB	39.6	43.3	46.6	50.4	53.5	60.4	64.0	64.3	62.5	55.2	47.0	40.9		(33)
(34)		10% MCDB	50.7	59.9	68.9	75.3	80.2	86.3	81.3	80.2	76.4	71.7	61.7	51.5		(34)
(35)	Mean Daily Temperature Range	MDBR	24.8	27.6	30.2	30.2	30.2	30.9	26.5	26.3	26.4	27.9	26.6	23.4		(35)
(36)		5% DB MCDBR	30.9	33.6	35.6	33.9	33.9	32.4	29.3	29.2	30.2	31.6	31.4	29.2		(36)
(37)		5% DB MCWBR	16.7	16.4	16.5	14.4	13.8	11.9	7.1	7.6	9.7	12.9	15.2	15.7		(37)
(38)		5% WB MCDBR	26.8	32.2	33.2	31.7	31.1	29.4	25.1	25.1	23.2	25.7	27.5	25.5		(38)
(39)		5% WB MCWBR	14.8	15.8	15.4	13.1	12.2	9.4	5.6	6.6	7.4	10.8	14.1	14.0		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.240	0.246	0.267	0.289	0.306	0.327	0.368	0.344	0.312	0.275	0.253	0.243		(40)
(41)		taud	2.662	2.647	2.564	2.484	2.486	2.426	2.417	2.457	2.533	2.616	2.626	2.647		(41)
(42)		Ebn at Noon	318	325	323	317	310	301	288	295	302	309	310	311		(42)
(43)		Edh at Noon	22	25	30	34	35	37	37	35	31	26	23	22		(43)
(44)	All-Sky Solar Radiation	RadAvg	1081	1397	1828	2234	2470	2500	2215	2050	1839	1515	1177	966		(44)
(45)		RadStd	85	114	105	106	122	134	115	70	78	119	69	54		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page