

GALLUP, NM, USA

WMO: 723627

Lat: 35.514N

Lon: 108.794W

Elev: 6471

StdP: 11.57

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 23081

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	2.1	6.6	-8.4	4.4	22.4	-4.6	5.5	24.0	27.9	41.4	24.9	41.0	1.2	60	0.600

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.0	92.2	57.4	89.9	56.9	87.7	56.3	62.4	77.9	61.5	77.6	60.5	76.6	10.8	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.8	94.6	64.9	57.3	89.5	64.3	55.9	85.0	64.5	31.3	77.8	30.6	77.1	29.8	76.8	80.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.9	23.4	19.5	DB	-6.3	96.3	5.3	2.2	-10.1	97.8	-13.3	99.1	-16.2	100.4	-20.1	101.9	(4)
(5)			WB	-7.1	65.5	5.1	3.3	-10.8	67.9	-13.8	69.8	-16.7	71.6	-20.4	74.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.7	30.2	34.3	40.8	47.0	55.7	66.1	71.6	69.3	62.1	49.6	38.3	29.9		
	DBStd	15.85	7.45	7.10	6.47	6.62	6.44	5.44	3.40	3.41	5.37	6.78	7.22	7.54		
	HDD50	2562	612	440	288	132	25	0	0	0	2	89	352	622		
	HDD65	6056	1077	859	749	541	293	51	2	5	114	478	800	1087		
	CDD50	2436	0	0	4	41	201	482	668	598	364	76	2	0		
	CDD65	456	0	0	0	0	4	83	205	138	26	0	0	0		
	CDH74	9126	0	0	2	35	552	2577	2941	2044	895	80	0	0		
	CDH80	3576	0	0	0	2	117	1109	1351	779	213	5	0	0		
	WSAvg	6.9	5.3	6.7	7.9	9.7	9.0	8.3	6.5	5.8	5.9	6.0	5.7	5.4		
	PrecAvg	11.5	0.9	0.7	0.9	0.5	0.6	0.4	1.7	2.1	1.1	1.1	0.9	0.7		
(15) Precipitation	PrecMax	15.8	2.6	2.2	2.0	2.0	2.2	1.8	3.6	6.1	2.9	3.7	2.7	2.2		
	PrecMin	5.4	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.7	0.0	0.0	0.0	0.0		
	PrecStd	2.4	0.7	0.5	0.6	0.4	0.6	0.5	1.0	1.2	0.7	0.9	0.7	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.3	64.8	72.9	78.3	87.9	94.9	95.3	93.0	88.5	80.3	70.2	59.5		
		MCWB	41.1	43.3	46.1	48.8	54.4	57.2	58.4	59.0	57.6	52.1	46.6	41.5		
	2%	DB	54.5	60.9	68.7	74.0	83.0	91.8	92.6	89.9	84.9	76.2	66.0	54.8		
		MCWB	39.0	41.5	44.4	47.0	51.6	55.8	58.1	58.0	55.7	50.3	44.2	39.2		
	5%	DB	50.6	56.5	65.1	71.2	79.9	89.2	90.3	87.5	82.3	72.9	62.4	50.7		
		MCWB	37.3	39.5	42.9	45.6	49.9	54.7	57.7	57.8	55.2	48.8	43.1	37.5		
	10%	DB	46.4	51.5	61.2	67.9	76.8	86.7	87.8	84.7	79.7	69.5	57.5	46.2		
		MCWB	35.7	37.4	41.3	44.3	48.9	53.6	57.5	57.8	54.3	47.6	41.1	35.8		
	0.4%	WB	44.0	45.1	47.8	50.4	55.7	60.5	64.0	64.0	61.3	56.6	48.3	44.1		
		MCDB	54.0	59.7	68.7	72.7	82.9	82.2	77.4	78.5	77.7	68.3	64.2	53.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	41.0	42.6	45.4	48.3	53.2	58.9	62.5	62.5	59.7	53.3	46.1	41.1		
		MCDB	51.0	57.1	66.0	71.1	77.3	82.1	77.8	77.9	75.8	68.1	61.3	50.5		
	5%	WB	38.4	40.7	43.8	46.6	51.5	57.2	61.6	61.7	58.5	51.3	44.1	38.9		
		MCDB	48.3	54.5	62.2	68.7	74.4	81.4	78.1	77.2	73.9	66.5	59.3	48.7		
	10%	WB	36.2	38.5	41.9	44.9	50.1	55.6	60.6	60.7	57.2	49.3	42.1	36.4		
		MCDB	45.2	49.9	58.9	66.1	73.0	81.4	77.4	75.9	72.1	66.1	55.9	45.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	29.7	29.7	34.1	34.7	36.1	38.7	32.0	30.8	33.2	34.9	34.0	29.6		
		MCDBR	37.6	40.7	43.8	42.5	42.4	41.5	37.3	36.2	37.7	42.1	43.1	37.2		
		MCWBR	24.0	23.7	23.3	21.6	19.7	18.0	13.5	12.6	15.6	21.2	25.0	23.5		
		MCDBR	31.7	35.6	38.8	39.0	38.5	37.1	28.5	28.1	28.9	33.0	37.2	32.4		
	5% WB	MCWBR	20.7	21.2	21.0	20.0	17.8	16.1	9.3	9.6	11.8	16.8	22.1	21.1		
(40) Clear-Sky Solar Irradiance	taub		0.235	0.243	0.264	0.282	0.293	0.305	0.349	0.339	0.299	0.278	0.246	0.239		
	taud		2.651	2.634	2.564	2.500	2.514	2.464	2.433	2.425	2.541	2.566	2.622	2.638		
	Ebn at Noon		317	325	322	318	314	308	294	296	305	305	310	309		
	Edh at Noon		22	25	30	33	34	35	36	36	30	27	23	21		
(44) All-Sky Solar Radiation	RadAvg		999	1299	1764	2175	2443	2606	2203	2022	1822	1476	1119	878		
	RadStd		88	107	112	115	173	123	118	80	66	115	69	60		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.83	N/A	N/A	N/A	N/A	N/A	-148	-230	+139	+76
(47) Regional (8 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page