

CURTIS FIELD, TX, USA

WMO: 723628

Lat: 31.178N

Lon: 99.324W

Elev: 557

StdP: 94.81

Time Zone: -6.00 (NAC)

Period: 05-19

WBAN: 93942

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -5.9	(c) -3.0	(d) -13.6	(e) 1.2	(f) 1.3	(g) -12.0	(h) 1.4	(i) 4.2	(j) 12.0	(k) 11.8	(l) 10.9	(m) 12.0	(n) 3.3	(o) 340	(p) 0.471

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 12.7	(c) 37.9	(d) 21.7	(e) 37.3	(f) 21.8	(g) 36.2	(h) 21.7	(i) 24.4	(j) 31.3	(k) 23.9	(l) 30.7	(m) 23.5	(n) 30.3	(o) 3.9	(p) 140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.8	18.8	25.4	22.4	18.3	25.3	22.2	18.1	25.1	76.5	31.5	74.6	30.4	72.7	29.5	26.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.1	8.7	7.9	-8.8	39.3	1.9	1.9	-10.2	40.6	-11.3	41.8	-12.3	42.8	-13.7	44.2
			-9.8	25.4	1.8	0.5	-11.1	25.8	-12.2	26.1	-13.2	26.4	-14.6	26.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.1	8.6	10.4	15.4	19.4	23.1	27.3	28.3	29.0	25.1	19.7	13.7	9.5		
	DBStd	8.53	5.76	6.41	5.55	4.78	3.86	2.28	2.26	2.22	3.16	4.90	5.45	5.38		
	HDD10.0	294	97	67	19	3	0	0	0	0	0	3	27	78		
	HDD18.3	1184	306	228	121	44	8	0	0	0	1	45	154	277		
	CDD10.0	3634	53	78	185	284	407	519	567	588	452	302	138	62		
	CDD18.3	1481	3	5	29	74	157	269	309	329	203	86	14	3		
	CDH23.3	17127	49	89	294	794	1597	3158	3824	4289	2031	814	138	49		
	CDH26.7	8695	9	24	91	316	719	1650	2126	2469	963	293	24	10		
(14) Wind	WSAvg	3.8	3.9	4.2	4.4	4.6	4.2	4.1	3.4	3.1	3.1	3.5	3.7	3.7		
(15) Precipitation	PrecAvg	656	37	43	50	66	85	70	50	49	84	57	42	31		
	PrecMax	908	88	140	112	151	175	202	147	120	199	186	235	191		
	PrecMin	414	6	1	3	14	24	0	0	0	19	0	0	0		
	PrecStd	128	22	39	31	33	33	56	47	41	47	42	54	43		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.7	29.2	32.2	36.2	37.3	38.9	38.9	39.9	37.8	33.8	29.0	27.7		
		MCWB	13.9	14.7	16.9	17.5	20.8	21.5	21.2	22.0	20.6	19.7	17.9	14.2		
	2%	DB	24.0	26.1	28.9	32.8	34.2	37.2	37.5	38.0	35.2	32.0	27.2	24.0		
		MCWB	13.1	14.0	16.0	18.5	21.4	22.0	21.7	22.1	21.1	20.1	17.0	13.7		
	5%	DB	21.3	23.0	27.1	30.2	32.5	35.9	37.0	37.4	33.0	29.9	24.8	21.4		
		MCWB	12.4	13.3	16.0	18.3	20.9	21.7	21.8	22.1	20.9	19.5	16.1	13.4		
	10%	DB	17.9	21.0	23.9	27.7	31.0	33.8	35.2	36.1	32.2	27.8	22.5	18.6		
		MCWB	10.7	12.4	15.1	17.7	20.7	21.8	21.5	22.0	20.8	18.4	15.3	13.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.5	18.4	20.0	22.1	24.4	25.3	24.9	24.7	24.4	23.5	21.2	18.9		
		MCDB	20.7	24.0	25.9	28.4	32.3	32.7	31.9	31.8	30.5	27.4	22.9	22.1		
	2%	WB	15.4	17.3	19.0	21.2	23.3	24.2	24.1	24.1	23.6	22.3	19.3	17.1		
		MCDB	20.5	20.1	24.2	27.0	29.8	31.0	30.6	31.7	29.3	26.7	23.4	19.9		
	5%	WB	13.8	16.0	18.1	20.4	22.7	23.6	23.6	23.6	23.0	21.5	18.1	15.2		
		MCDB	18.8	20.6	22.4	25.9	28.6	30.3	30.3	31.5	28.3	26.0	22.1	18.7		
	10%	WB	11.8	14.1	17.3	19.6	21.9	23.0	23.1	23.1	22.5	20.7	17.0	13.4		
		MCDB	17.8	19.3	21.3	24.9	27.3	29.6	30.0	31.2	27.7	25.1	21.1	18.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.2	13.5	13.4	13.6	12.2	12.2	12.3	12.7	11.7	13.2	13.5	13.3		
		MCDBR	16.9	17.0	16.3	16.7	15.0	14.7	14.2	14.3	13.6	14.6	15.0	16.6		
	5% WB	MCWBR	9.2	9.2	7.3	7.3	5.3	4.1	3.8	3.8	4.4	6.0	7.7	9.1		
		MCDWR	14.5	13.9	12.1	12.3	11.9	11.7	11.9	12.5	10.7	11.4	12.7	13.2		
(40) Clear-Sky Solar Irradiance	taub		0.298	0.304	0.328	0.369	0.403	0.403	0.415	0.407	0.380	0.346	0.316	0.299		
	taud		2.535	2.527	2.471	2.377	2.336	2.379	2.393	2.400	2.418	2.504	2.519	2.538		
	Ebn at Noon		937	963	956	923	887	882	870	875	890	903	908	917		
	Edh at Noon		85	94	107	122	128	122	120	118	111	95	86	81		
(44) All-Sky Solar Radiation	RadAvg		3.19	3.86	4.91	5.90	6.14	6.92	6.83	6.33	5.28	4.29	3.34	2.86		
	RadStd		0.34	0.53	0.42	0.50	0.62	0.53	0.54	0.41	0.45	0.63	0.43	0.37		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (33 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+68

Nomenclature: See separate page