

ALBUQUERQUE INTL, NM, USA

WMO: 723650

Lat: 35.038N

Lon: 106.622W

Elev: 5312

StdP: 12.09

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 23050

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	19.0	22.4	-4.9	5.2	43.3	-1.0	6.3	43.5	31.8	38.1	26.6	39.6	6.5	10	0.515

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.9	95.6	59.8	93.4	59.6	91.2	59.4	65.2	81.3	64.4	80.5	63.7	79.9	9.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.5	99.5	68.2	60.1	94.8	69.0	58.6	89.5	70.0	33.0	80.4	32.2	80.5	31.6	79.4	69.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.4	24.9	20.8	DB	11.6	99.8	4.9	2.3	8.1	101.4	5.2	102.7	2.5	104.0	-1.1	105.6	(4)
(5)			WB	9.5	67.3	4.4	1.0	6.3	68.0	3.7	68.6	1.2	69.1	-2.0	69.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	58.5	38.0	42.5	50.0	57.0	66.4	76.8	79.2	77.1	70.7	58.6	46.6	37.6		
	DBStd	16.09	6.37	7.01	7.05	7.11	6.79	4.83	3.83	3.71	5.33	7.01	7.06	6.69		
	HDD50	1253	372	220	89	24	2	0	0	0	0	16	145	385		
	HDD65	3873	836	629	464	249	65	1	0	0	16	213	552	848		
	CDD50	4340	1	11	90	232	510	803	906	839	621	283	43	1		
	CDD65	1488	0	0	0	8	108	354	441	374	187	16	0	0		
	CDH74	15729	0	0	20	183	1378	4259	4587	3500	1614	188	0	0		
	CDH80	6916	0	0	0	17	449	2122	2257	1537	517	17	0	0		
(14) Wind	WSAvg	8.1	7.1	8.2	8.9	10.2	9.6	9.1	8.1	7.4	7.4	7.5	7.0	6.7		
(15) Precipitation	PrecAvg	8.9	0.4	0.4	0.5	0.5	0.5	0.6	1.5	1.5	1.1	0.9	0.5	0.5		
	PrecMax	13.1	1.4	1.8	2.3	3.0	2.5	3.1	3.5	3.7	4.0	3.1	1.9	1.5		
	PrecMin	4.8	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.1	0.0	0.0	0.0		
	PrecStd	2.2	0.4	0.4	0.5	0.6	0.6	0.6	0.9	0.9	0.7	0.8	0.4	0.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.7	68.4	76.8	82.3	92.0	99.3	98.4	95.8	91.2	82.1	70.5	61.1		
		MCWB	43.0	45.5	48.4	51.1	57.0	59.5	61.3	60.9	59.4	54.6	47.8	43.4		
	2%	DB	56.7	64.3	72.5	78.8	88.1	95.8	95.7	93.2	88.2	78.8	67.1	56.7		
		MCWB	40.6	43.6	46.8	49.8	54.5	58.2	60.6	61.1	58.7	53.6	46.5	41.5		
	5%	DB	53.4	60.4	69.0	75.8	85.0	93.3	93.4	90.8	85.7	75.8	63.5	53.1		
		MCWB	39.1	42.0	45.3	48.7	53.2	57.4	60.8	61.1	58.1	52.5	45.1	39.9		
	10%	DB	50.1	56.3	65.2	72.7	81.9	90.8	91.0	88.4	83.0	72.3	59.5	49.5		
		MCWB	37.4	40.2	43.6	47.3	52.3	57.0	61.0	61.2	57.6	51.2	43.3	37.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.1	47.4	50.5	54.1	59.7	64.3	66.4	66.3	64.1	60.9	51.0	46.2		
		MCDB	56.8	63.6	69.4	74.7	83.9	81.0	82.7	80.8	77.3	70.0	61.8	54.9		
	2%	WB	42.2	45.0	48.2	51.8	57.3	62.4	65.3	65.3	62.5	57.5	48.5	43.4		
		MCDB	52.9	59.9	67.6	72.6	79.9	82.9	81.9	81.3	76.3	71.6	61.4	53.9		
	5%	WB	40.3	43.2	46.4	50.1	55.6	61.1	64.4	64.4	61.6	55.4	46.7	41.1		
		MCDB	50.9	57.8	65.3	71.1	76.3	82.6	81.2	80.1	75.6	68.7	60.1	51.0		
	10%	WB	38.3	41.2	44.7	48.4	54.1	59.9	63.9	63.7	60.4	53.4	44.8	38.7		
		MCDB	48.7	54.5	63.1	69.4	75.2	82.2	80.8	79.2	75.5	67.0	58.2	48.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	20.8	22.7	24.9	25.1	25.6	26.2	22.9	22.2	22.3	22.5	21.5	19.4		
		MCDBR	25.3	28.7	29.5	28.8	28.7	28.7	25.6	24.9	25.1	26.1	25.7	23.7		
		MCWBR	13.9	14.5	13.3	12.6	11.8	10.7	7.4	6.9	8.5	11.0	12.3	13.1		
	5% WB	MCDBR	22.3	26.0	27.1	26.9	25.7	24.5	21.7	21.2	20.3	21.1	22.6	21.5		
		MCWBR	12.9	13.5	12.5	12.0	10.3	8.6	6.0	5.9	7.0	9.6	11.7	12.5		
(40) Clear-Sky Solar Irradiance	taub		0.242	0.250	0.275	0.291	0.310	0.332	0.368	0.350	0.311	0.283	0.257	0.245		
	taud		2.622	2.606	2.526	2.471	2.462	2.391	2.396	2.400	2.519	2.561	2.584	2.614		
	Ebn at Noon		315	322	319	315	308	300	288	292	302	304	305	307		
	Edh at Noon		23	26	31	35	36	38	38	37	31	27	23	22		
(44) All-Sky Solar Radiation	RadAvg		1033	1335	1778	2177	2445	2545	2266	2087	1844	1485	1133	908		
	RadStd		84	110	112	102	125	121	107	76	76	116	67	55		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+115	N/A

Nomenclature: See separate page