

FOUR CORNERS, NM, USA

WMO: 723658

Lat: 36.744N

Lon: 108.229W

Elev: 5495

StdP: 12.00

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 23090

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.1	13.3	-5.7	5.0	35.1	-1.4	6.2	34.9	26.5	39.7	23.9	38.3	5.2	80	0.570

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	29.6	96.1	59.4	93.5	58.9	91.3	58.7	64.6	81.2	63.6	81.2	62.5	80.6	11.3	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.1	98.9	67.1	59.0	91.6	67.4	56.9	84.8	68.6	32.6	80.1	31.7	80.2	30.9	80.3	71.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.2	21.6	18.7	DB	1.9	99.6	5.1	1.6	-1.7	100.8	-4.7	101.8	-7.6	102.7	-11.3	103.8	(4)
(5)			WB	1.0	66.6	4.9	1.8	-2.5	67.9	-5.4	68.9	-8.2	70.0	-11.7	71.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.6	31.5	36.9	44.8	51.4	60.7	71.4	77.4	74.7	66.6	53.4	41.3	31.9		
	DBStd	17.12	7.40	6.91	6.70	6.92	7.07	5.52	3.65	3.62	6.04	7.03	7.28	7.07		
	HDD50	2079	574	366	184	67	9	0	0	0	1	47	271	560		
	HDD65	5189	1039	786	625	410	167	13	0	0	50	362	712	1025		
	CDD50	3389	0	0	24	108	339	641	850	766	500	152	9	0		
	CDD65	1025	0	0	0	1	32	204	386	301	99	2	0	0		
	CDH74	14146	0	0	5	82	935	3472	4721	3401	1418	112	0	0		
	CDH80	6660	0	0	0	6	276	1742	2534	1615	476	11	0	0		
(14) Wind	WSAvg	8.0	7.1	7.9	8.7	9.7	9.0	8.7	8.2	7.6	7.5	7.6	7.4	7.0		
(15) Precipitation	PrecAvg	8.3	0.7	0.6	0.6	0.6	0.6	0.2	0.7	1.1	1.0	0.9	0.7	0.6		
	PrecMax	12.9	2.0	2.2	1.7	2.3	1.9	1.5	1.9	2.3	3.1	2.8	1.9	1.3		
	PrecMin	4.6	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.3	0.2	0.0	0.0	0.0		
	PrecStd	1.7	0.6	0.5	0.4	0.5	0.6	0.3	0.4	0.6	0.7	0.7	0.5	0.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.7	63.2	73.6	80.2	90.7	98.0	99.6	96.6	91.3	81.3	69.3	57.0		
		MCWB	40.7	43.8	47.2	50.5	56.4	59.0	60.4	60.3	58.9	54.0	46.5	41.3		
	2%	DB	51.6	59.3	69.9	76.3	86.3	94.8	96.9	93.7	88.2	77.4	64.4	52.1		
		MCWB	38.6	41.9	45.5	48.6	53.9	57.2	60.1	59.6	57.9	52.2	45.0	39.2		
	5%	DB	47.6	54.9	65.8	73.1	82.7	92.5	94.5	91.4	85.4	73.3	60.9	48.0		
		MCWB	36.9	40.1	43.9	47.4	52.4	56.5	59.8	59.8	56.7	50.3	43.6	37.4		
	10%	DB	44.2	51.1	61.9	69.8	79.6	90.0	92.0	89.1	82.3	70.0	56.3	44.5		
		MCWB	35.2	38.3	42.3	46.2	51.1	55.7	59.9	59.8	56.1	49.2	41.5	35.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.3	46.2	49.3	53.2	58.5	62.6	66.1	66.4	63.6	57.8	49.2	44.2		
		MCDB	51.5	59.4	67.7	73.6	86.1	84.8	80.9	81.7	80.7	70.6	62.7	53.0		
	2%	WB	40.4	43.4	46.8	50.4	55.8	60.7	64.5	64.9	61.7	55.2	46.6	41.2		
		MCDB	48.0	55.3	66.0	72.0	79.8	83.9	81.6	80.9	77.5	70.1	59.8	48.7		
	5%	WB	38.1	41.2	44.9	48.5	54.2	59.4	63.7	63.8	60.1	53.2	44.8	38.6		
		MCDB	45.3	52.9	62.7	69.3	77.0	84.1	82.1	80.2	76.3	67.1	57.8	46.2		
	10%	WB	36.1	39.2	43.2	46.9	52.5	58.0	62.7	62.7	58.8	51.1	42.7	36.2		
		MCDB	43.0	49.7	59.3	67.1	75.0	83.1	81.9	79.2	75.1	65.8	55.0	43.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	22.4	24.3	28.7	29.6	31.2	34.2	29.6	28.4	29.1	28.6	26.3	21.9		
		MCDBR	27.2	30.4	35.2	35.6	36.4	37.2	33.0	32.1	32.7	33.5	31.9	25.8		
		MCWBR	16.4	16.5	16.8	16.4	15.2	15.0	10.9	10.7	12.4	15.2	17.1	15.6		
	5% WB	MCDBR	22.9	27.0	31.5	32.5	31.9	26.3	25.4	25.5	27.2	28.1	22.6			
		MCWBR	14.3	15.2	15.7	15.6	13.6	12.7	7.5	7.7	9.8	12.9	15.6	14.3		
(40) Clear-Sky Solar Irradiance	taub		0.247	0.251	0.272	0.302	0.318	0.323	0.366	0.366	0.318	0.290	0.255	0.248		
	taud		2.597	2.594	2.532	2.431	2.423	2.396	2.364	2.333	2.471	2.526	2.584	2.592		
	Ebn at Noon		309	319	318	311	305	302	288	286	297	299	302	301		
	Edh at Noon		23	26	30	36	37	38	39	39	32	27	23	22		
(44) All-Sky Solar Radiation	RadAvg		935	1225	1697	2101	2394	2627	2336	2084	1821	1416	1054	815		
	RadStd		82	104	115	104	154	119	112	74	72	102	69	62		

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	-2.61	N/A	-0.70	N/A	N/A	N/A	N/A	N/A
(47)	Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page