

FOUR CORNERS, NM, USA

WMO: 723658

Lat: 36.744N

Lon: 108.229W

Elev: 1675

StdP: 82.76

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 23090

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.7	-10.4	-20.9	0.7	1.7	-18.6	0.9	1.6	11.9	4.3	10.7	3.5	2.3	80	0.570

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.4	35.6	15.2	34.2	15.0	33.0	14.8	18.1	27.3	17.6	27.3	16.9	27.0	5.1	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.2	14.1	19.5	15.0	13.1	19.7	13.8	12.1	20.4	58.0	26.7	55.8	26.8	53.9	26.8	22.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	11.2	9.7	8.4	DB	-16.7	37.6	2.8	0.9	-18.7	38.2	-20.4	38.8	-22.0	39.3	-24.0	39.9
(5)				WB	-17.2	19.2	2.7	1.0	-19.2	19.9	-20.8	20.5	-22.3	21.1	-24.3	21.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.0	-0.3	2.7	7.1	10.8	15.9	21.9	25.2	23.7	19.2	11.9	5.1	0.0	(6)
(7)		DBStd	9.51	4.11	3.84	3.72	3.84	3.93	3.06	2.03	2.01	3.36	3.91	4.04	3.93	(7)
(8)		HDD10.0	1155	319	203	102	37	5	0	0	0	1	26	151	311	(8)
(9)		HDD18.3	2883	577	437	347	228	93	7	0	0	28	201	396	569	(9)
(10)		CDD10.0	1883	0	0	13	60	188	356	472	426	278	84	5	0	(10)
(11)		CDD18.3	569	0	0	0	1	18	113	214	167	55	1	0	0	(11)
(12)		CDH23.3	7859	0	0	3	46	519	1929	2623	1889	788	62	0	0	(12)
(13)		CDH26.7	3700	0	0	0	3	153	968	1408	897	264	6	0	0	(13)
(14)	Wind	WSAvg	3.6	3.2	3.5	3.9	4.4	4.0	3.9	3.7	3.4	3.3	3.4	3.3	3.1	(14)
(15)	Precipitation	PrecAvg	210	17	15	14	14	14	6	18	28	26	23	17	15	(15)
(16)		PrecMax	328	52	57	43	58	49	37	49	59	79	72	48	34	(16)
(17)		PrecMin	117	0	0	0	1	0	0	3	7	6	0	1	0	(17)
(18)		PrecStd	44	15	13	10	12	15	8	11	15	19	19	12	10	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	17.3	23.1	26.8	32.6	36.6	37.6	35.9	32.9	27.4	20.7	13.9	(19)
(20)		MCWB	4.8	6.5	8.5	10.3	13.5	15.0	15.8	15.7	15.0	12.2	8.1	5.2	(20)	
(21)		2%	DB	10.9	15.1	21.1	24.6	30.1	34.9	36.1	34.3	31.2	25.2	18.0	11.2	(21)
(22)		MCWB	3.7	5.5	7.5	9.2	12.2	14.0	15.6	15.3	14.4	11.2	7.2	4.0	(22)	
(23)		5%	DB	8.7	12.7	18.8	22.8	28.2	33.6	34.7	33.0	29.7	22.9	16.1	8.9	(23)
(24)		MCWB	2.7	4.5	6.6	8.5	11.3	13.6	15.4	15.4	13.7	10.2	6.4	3.0	(24)	
(25)		10%	DB	6.8	10.6	16.6	21.0	26.5	32.2	33.3	31.7	27.9	21.1	13.5	7.0	(25)
(26)		MCWB	1.8	3.5	5.7	7.9	10.6	13.2	15.5	15.4	13.4	9.6	5.3	2.0	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.3	7.9	9.6	11.8	14.7	17.0	18.9	19.1	17.6	14.3	9.6	6.8	(27)
(28)		MDCB	10.8	15.2	19.8	23.1	30.1	29.3	27.2	27.6	27.1	21.5	17.1	11.7	(28)	
(29)		2%	WB	4.7	6.3	8.2	10.2	13.2	16.0	18.1	18.3	16.5	12.9	8.1	5.1	(29)
(30)		MDCB	8.9	13.0	18.9	22.2	26.6	28.8	27.5	27.2	25.3	21.2	15.5	9.3	(30)	
(31)		5%	WB	3.4	5.1	7.2	9.1	12.3	15.2	17.6	17.7	15.6	11.8	7.1	3.7	(31)
(32)		MDCB	7.4	11.6	17.1	20.7	25.0	29.0	27.8	26.8	24.6	19.5	14.3	7.9	(32)	
(33)		10%	WB	2.3	4.0	6.2	8.3	11.4	14.4	17.1	17.0	14.9	10.6	5.9	2.3	(33)
(34)		MDCB	6.1	9.8	15.2	19.5	23.9	28.4	27.7	26.2	24.0	18.8	12.8	6.4	(34)	
(35)	Mean Daily Temperature Range	MDBR	12.5	13.5	16.0	16.4	17.4	19.0	16.4	15.8	16.2	15.9	14.6	12.2	(35)	
(36)		5% DB	MCDBR	15.1	16.9	19.5	19.8	20.2	20.7	18.3	17.8	18.1	18.6	17.7	14.3	(36)
(37)		MCWBR	9.1	9.2	9.4	9.1	8.4	8.3	6.1	6.0	6.9	8.5	9.5	8.7	(37)	
(38)		5% WB	MCDBR	12.7	15.0	17.5	18.1	18.1	17.7	14.6	14.1	14.2	15.1	15.6	12.5	(38)
(39)		MCWBR	8.0	8.4	8.7	8.7	7.5	7.1	4.2	4.3	5.4	7.1	8.7	8.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.247	0.251	0.272	0.302	0.318	0.323	0.366	0.366	0.318	0.290	0.255	0.248	(40)	
(41)		taud	2.597	2.594	2.532	2.431	2.423	2.396	2.364	2.333	2.471	2.526	2.584	2.592	(41)	
(42)		Ebn at Noon	974	1006	1004	980	962	952	908	903	937	942	953	950	(42)	
(43)		Edh at Noon	72	82	96	112	116	119	122	123	101	86	72	68	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.95	3.86	5.35	6.62	7.55	8.28	7.37	6.57	5.74	4.46	3.32	2.57	(44)	
(45)		RadStd	0.26	0.33	0.36	0.33	0.49	0.38	0.35	0.23	0.23	0.32	0.22	0.20	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	-1.45	N/A	-0.39	N/A	N/A	N/A	N/A	N/A
(47)	Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page