

TAOS, NM, USA

WMO: 723663

Lat: 36.450N

Lon: 105.667W

Elev: 7091

StdP: 11.30

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 03012

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-0.2	3.2	-9.4	4.3	9.6	-6.2	5.1	14.6	25.1	35.2	21.8	32.8	5.0	10	0.627

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.0	89.0	56.4	86.3	55.6	83.8	55.1	60.3	78.4	59.2	77.9	58.2	76.5	12.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.9	83.7	63.5	53.9	80.8	63.5	52.1	75.4	63.8	30.0	79.3	29.2	76.8	28.4	76.4	64.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
25.4	21.7	18.8	-10.1	93.2	4.8	1.8	-13.6	94.5	-16.4	95.6	-19.2	96.6	-22.7	98.0		
			-10.5	61.9	4.5	1.5	-13.8	63.1	-16.4	64.0	-18.9	64.8	-22.2	65.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.9	26.2	31.2	38.7	44.9	53.7	63.9	68.4	66.3	59.3	47.3	35.8	26.2
	DBStd	16.10	7.61	7.65	6.84	6.49	6.51	4.92	3.04	3.22	4.94	7.03	7.27	7.70
	HDD50	3131	739	528	351	174	37	0	0	0	5	131	427	739
	HDD65	6833	1204	948	814	604	351	76	6	24	177	548	877	1204
	CDD50	1998	0	0	2	20	153	418	570	504	283	48	0	0
	CDD65	224	0	0	0	0	2	43	111	63	5	0	0	0
	CDH74	5248	0	0	0	6	268	1545	1772	1212	425	20	0	0
	CDH80	1604	0	0	0	0	47	538	624	335	60	0	0	0
	WSAvg	7.3	6.0	6.8	7.9	9.2	9.0	8.7	7.2	6.8	6.8	6.9	6.2	6.0
	PrecAvg	12.2	0.6	0.6	0.8	0.8	0.9	1.1	1.6	1.9	1.5	1.1	0.7	0.7
(15) Precipitation	PrecMax	16.9	1.7	1.5	2.7	2.1	2.1	3.6	3.1	5.2	2.8	2.8	2.0	1.8
	PrecMin	7.8	0.1	0.0	0.0	0.0	0.0	0.0	0.5	0.2	0.2	0.0	0.0	0.0
	PrecStd	2.5	0.5	0.4	0.6	0.6	0.7	0.9	0.7	1.1	0.8	0.7	0.5	0.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.3	59.2	70.0	73.7	84.4	91.4	91.2	90.0	84.2	76.8	65.2	54.6
		MCWB	37.6	40.4	44.7	46.7	51.9	55.7	57.7	57.0	55.0	49.8	43.1	38.4
	2%	DB	49.6	54.7	64.2	70.3	80.8	88.8	89.1	86.3	81.7	72.7	62.2	50.4
		MCWB	35.5	38.0	42.2	45.3	50.5	55.2	57.2	56.5	53.6	48.9	42.5	36.0
	5%	DB	45.5	51.5	61.2	66.5	76.7	85.9	86.4	83.7	79.3	69.9	57.2	45.8
		MCWB	33.6	36.9	40.8	43.9	48.7	53.8	56.6	56.4	53.2	47.7	40.2	34.0
	10%	DB	41.6	46.1	56.7	63.7	73.1	82.3	83.7	81.4	75.4	65.6	53.6	41.8
		MCWB	31.6	34.2	38.8	42.6	47.6	52.6	56.4	56.5	52.2	46.1	38.5	32.0
	0.4%	WB	39.4	41.9	45.6	49.1	54.4	58.6	62.0	61.8	58.6	54.3	45.6	40.2
		MCDB	50.1	55.6	66.2	68.7	77.4	82.2	79.0	78.8	75.0	67.6	61.4	50.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	36.7	39.2	43.4	46.8	52.2	57.1	60.5	60.2	56.8	51.1	43.1	37.4
		MCDB	46.3	51.9	62.4	66.2	74.3	81.0	79.1	77.7	74.3	66.8	59.5	46.9
	5%	WB	34.5	37.1	41.5	45.1	50.5	55.8	59.6	59.2	55.4	48.9	41.2	34.9
		MCDB	44.0	48.7	59.5	64.2	72.4	79.6	78.9	76.8	72.7	65.7	55.9	44.5
	10%	WB	32.4	35.1	39.5	43.4	49.0	54.4	58.7	58.1	54.1	47.0	38.9	32.5
		MCDB	41.1	45.6	55.2	62.5	70.3	77.7	77.5	75.2	71.2	63.4	51.7	41.4
	5% DB	MDBR	29.0	27.0	30.8	31.5	33.5	36.3	32.0	30.8	32.2	31.9	30.5	28.3
		MCDBR	33.3	34.0	38.6	38.6	39.5	40.9	36.6	35.5	36.6	38.2	37.7	33.1
		MCWBR	21.9	20.2	21.0	19.9	18.8	18.4	14.2	13.9	16.6	19.9	22.1	21.8
		MCDBR	30.3	29.4	35.7	35.3	35.6	35.2	30.5	29.1	30.2	32.4	34.1	29.8
(38) All-Sky Solar Radiation	5% WB	MCWBR	20.3	17.8	19.6	18.4	16.8	15.6	11.8	11.2	13.9	17.4	20.4	19.8
(40) Clear-Sky Solar Irradiance	taub		0.233	0.239	0.272	0.287	0.306	0.316	0.362	0.340	0.301	0.270	0.248	0.240
		taud	2.646	2.640	2.541	2.512	2.502	2.468	2.420	2.441	2.557	2.624	2.618	2.616
	Ebn at Noon		317	325	319	316	309	304	290	295	304	308	307	306
		Edh at Noon	22	25	30	33	34	35	36	35	30	25	22	21
(44) All-Sky Solar Radiation	RadAvg		989	1284	1685	2049	2282	2392	2047	1925	1759	1426	1076	865
	RadStd		62	94	129	115	160	138	111	97	97	98	65	48

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	+0.99	+1.30	N/A	N/A	N/A	N/A	
(47) Regional (13 neighbors)		+0.56	N/A	N/A	+0.77	N/A	N/A	N/A	N/A	+112	+45	

Nomenclature: See separate page