

WINSLOW, AZ, USA

WMO: 723740

Lat: 35.028N

Lon: 110.721W

Elev: 4886

StdP: 12.28

Time Zone: -7.00 (W07)

Period: 94-19

WBAN: 23194

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	11.9	15.6	-7.8	4.3	32.4	-3.8	5.4	34.0	30.8	49.1	26.4	47.4	3.2	120	0.562

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	29.6	98.5	60.9	96.3	60.4	94.0	59.9	66.1	81.8	65.1	81.8	64.2	81.4	10.7	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.5	101.5	69.4	60.9	96.0	69.4	59.2	90.1	69.9	33.4	80.9	32.6	80.8	31.9	80.9	72.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.7	24.9	20.7	5.0	102.6	4.2	2.1	2.0	104.1	-0.4	105.4	-2.8	106.6	-5.8	108.1
			3.4	68.8	4.1	1.5	0.4	69.8	-2.0	70.7	-4.3	71.5	-7.3	72.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.6	35.8	40.7	48.1	54.3	63.4	73.9	79.0	76.6	69.4	56.7	44.5	35.5		
	DBStd	16.52	7.25	7.35	6.94	7.04	6.74	5.54	3.65	3.68	5.38	7.26	7.62	7.41		
	HDD50	1541	443	267	119	38	3	0	0	0	0	26	193	452		
	HDD65	4369	906	679	525	324	110	6	0	0	22	268	614	915		
	CDD50	3939	1	8	59	169	417	718	898	824	583	232	28	2		
	CDD65	1293	0	0	0	4	60	273	433	359	155	9	0	0		
	CDH74	18688	0	1	45	290	1566	4734	5432	4096	2126	391	7	0		
	CDH80	9443	0	0	2	44	589	2689	3061	2099	883	76	0	0		
(14) Wind	WSAvg	7.9	6.1	7.5	8.7	10.6	10.0	9.6	8.4	7.4	7.2	7.0	6.4	6.1		
(15) Precipitation	PrecAvg	7.6	0.5	0.5	0.6	0.3	0.3	0.2	1.1	1.3	0.9	0.8	0.5	0.6		
	PrecMax	12.5	1.5	2.0	2.1	1.3	2.1	1.3	3.5	4.8	2.6	5.6	1.5	3.7		
	PrecMin	2.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0		
	PrecStd	2.0	0.4	0.4	0.5	0.3	0.5	0.3	0.9	0.9	0.7	1.0	0.4	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.3	71.4	79.2	84.7	93.5	101.5	102.0	98.6	94.0	86.0	74.9	65.1		
		MCWB	44.8	47.1	50.1	53.0	57.7	60.1	61.6	62.5	60.5	56.1	49.2	46.3		
	2%	DB	59.0	66.6	74.3	80.6	89.5	98.3	99.1	96.0	90.8	82.1	70.4	59.3		
		MCWB	42.6	44.8	47.8	50.9	55.4	59.1	61.7	61.8	59.3	54.6	47.7	42.9		
	5%	DB	54.6	62.0	70.6	77.3	86.4	96.0	96.7	93.6	88.2	78.5	66.4	54.1		
		MCWB	41.0	43.1	46.2	49.6	54.3	58.5	61.3	61.4	58.8	52.9	46.4	40.7		
	10%	DB	50.5	57.1	66.8	74.1	83.2	93.3	94.0	90.9	85.6	74.8	61.6	49.6		
		MCWB	38.7	41.2	44.6	48.0	52.9	57.3	61.1	61.4	58.2	51.6	44.6	38.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.0	49.0	51.2	54.3	59.8	63.7	67.4	67.3	65.5	60.2	52.0	48.3		
		MCDB	57.6	65.8	75.1	80.6	89.6	90.1	82.3	79.8	78.8	74.0	65.1	59.1		
	2%	WB	44.6	46.4	48.9	52.0	57.0	62.0	66.2	66.1	63.8	57.4	49.7	45.0		
		MCDB	54.8	62.8	70.6	77.4	84.0	89.9	82.5	81.1	78.1	74.7	65.5	55.6		
	5%	WB	42.0	44.3	47.3	50.4	55.4	60.5	65.3	65.1	62.4	55.3	47.6	42.2		
		MCDB	52.0	59.4	67.4	75.1	81.5	89.0	82.5	81.4	77.7	72.3	64.4	52.0		
	10%	WB	39.8	42.2	45.7	48.5	53.8	59.1	64.4	64.3	61.2	53.2	45.5	39.7		
		MCDB	49.6	55.3	64.1	72.1	79.2	87.9	82.2	80.7	77.3	70.9	60.4	48.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	27.8	29.6	32.2	32.8	33.7	35.8	29.6	28.2	30.4	32.4	31.1	26.2		
		MCDBR	33.5	37.0	38.5	38.5	38.2	38.8	34.1	32.3	34.0	37.2	36.8	32.4		
	5% WB	MCWBR	20.4	19.7	18.8	18.3	17.2	15.8	11.6	9.9	12.5	17.4	19.6	19.4		
		MCWBR	28.4	32.5	34.8	35.7	35.1	34.0	26.2	25.7	26.1	31.0	33.0	27.8		
(40) Clear-Sky Solar Irradiance	taub		0.248	0.255	0.279	0.296	0.307	0.313	0.365	0.360	0.325	0.294	0.253	0.247		
	taud		2.600	2.590	2.501	2.431	2.448	2.424	2.384	2.379	2.462	2.506	2.600	2.610		
	Ebn at Noon		312	320	317	314	309	305	289	289	297	299	307	306		
	Edh at Noon		23	27	32	36	36	37	38	37	33	29	23	22		
(44) All-Sky Solar Radiation	RadAvg		1017	1326	1802	2239	2508	2652	2206	2023	1876	1508	1149	897		
	RadStd		87	110	109	100	148	118	122	92	67	110	61	65		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.81	N/A	N/A	+0.99	N/A	N/A	N/A	N/A	+180	+110	(46)
(47)	Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+112	+47	(47)

Nomenclature: See separate page