

WINSLOW, AZ, USA

WMO: 723740

Lat: 35.028N

Lon: 110.721W

Elev: 1489

StdP: 84.67

Time Zone: -7.00 (W07)

Period: 94-19

WBAN: 23194

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-11.2	-9.1	-22.1	0.6	0.2	-19.9	0.8	1.1	13.8	9.5	11.8	8.6	1.4	120	0.562

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.4	37.0	16.0	35.7	15.8	34.4	15.5	18.9	27.7	18.4	27.7	17.9	27.4	4.8	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.9	14.5	20.8	16.1	13.7	20.8	15.1	12.9	21.1	59.7	27.2	58.0	27.1	56.3	27.2	22.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.8	11.1	9.3	-15.0	39.2	2.3	1.2	-16.7	40.1	-18.0	40.8	-19.3	41.4	-21.0	42.3		
			-15.9	20.4	2.3	0.8	-17.5	21.0	-18.9	21.5	-20.2	21.9	-21.8	22.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.7	2.1	4.9	8.9	12.4	17.4	23.3	26.1	24.8	20.8	13.7	7.0	1.9
	DBStd	9.18	4.03	4.08	3.85	3.91	3.75	3.08	2.03	2.04	2.99	4.03	4.23	4.12
	HDD10.0	856	246	148	66	21	2	0	0	0	0	14	107	251
	HDD18.3	2427	503	377	292	180	61	3	0	0	12	149	341	508
	CDD10.0	2188	1	4	33	94	232	399	499	458	324	129	16	1
	CDD18.3	718	0	0	0	2	33	152	241	199	86	5	0	0
	CDH23.3	10382	0	1	25	161	870	2630	3018	2276	1181	217	4	0
	CDH26.7	5246	0	0	1	24	327	1494	1701	1166	491	42	0	0
Wind	WSAvg	3.5	2.7	3.4	3.9	4.7	4.5	4.3	3.7	3.3	3.2	3.1	2.8	2.7
Precipitation	PrecAvg	193	12	12	15	7	8	4	29	33	22	21	13	16
	PrecMax	317	39	52	53	32	54	33	90	122	66	142	39	95
	PrecMin	62	0	0	0	0	0	0	0	2	0	0	0	0
	PrecStd	50	11	10	12	7	12	7	22	24	19	26	11	18
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.9	21.9	26.2	29.3	34.1	38.6	38.9	37.0	34.5	30.0	23.8	18.4
		MCWB	7.1	8.4	10.0	11.7	14.3	15.6	16.4	16.9	15.8	13.4	9.5	8.0
	2%	DB	15.0	19.2	23.5	27.0	32.0	36.9	37.3	35.6	32.7	27.8	21.4	15.2
		MCWB	5.9	7.1	8.8	10.5	13.0	15.1	16.5	16.6	15.2	12.6	8.7	6.1
	5%	DB	12.6	16.6	21.5	25.2	30.2	35.5	35.9	34.2	31.2	25.8	19.1	12.3
		MCWB	5.0	6.1	7.9	9.8	12.4	14.7	16.3	16.3	14.9	11.6	8.0	4.9
	10%	DB	10.3	14.0	19.4	23.4	28.4	34.1	34.5	32.7	29.8	23.8	16.4	9.8
		MCWB	3.7	5.1	7.0	8.9	11.6	14.1	16.2	16.3	14.6	10.9	7.0	3.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.4	9.4	10.7	12.4	15.4	17.6	19.7	19.6	18.6	15.7	11.1	9.0
		MCDB	14.2	18.8	23.9	27.0	32.0	32.3	27.9	26.6	26.0	23.3	18.4	15.1
	2%	WB	7.0	8.0	9.4	11.1	13.9	16.7	19.0	18.9	17.7	14.1	9.8	7.2
		MCDB	12.7	17.1	21.4	25.2	28.9	32.1	28.0	27.3	25.6	23.7	18.6	13.1
	5%	WB	5.6	6.8	8.5	10.2	13.0	15.8	18.5	18.4	16.9	12.9	8.7	5.6
		MCDB	11.1	15.2	19.6	23.9	27.5	31.7	28.1	27.4	25.4	22.4	18.0	11.1
	10%	WB	4.4	5.6	7.6	9.2	12.1	15.0	18.0	17.9	16.2	11.8	7.5	4.3
		MCDB	9.8	12.9	17.9	22.3	26.2	31.0	27.9	27.1	25.2	21.6	15.8	9.1
Mean Daily Temperature Range	5% DB	MDBR	15.4	16.5	17.9	18.2	18.7	19.9	16.4	15.6	16.9	18.0	17.3	14.6
		MCDBR	18.6	20.5	21.4	21.4	21.2	21.5	18.9	18.0	18.9	20.7	20.5	18.0
		MCWBR	11.3	11.0	10.4	10.1	9.6	8.8	6.4	5.5	6.9	9.7	10.9	10.8
	5% WB	MCDBR	15.8	18.1	19.4	19.9	19.5	18.9	14.6	14.3	14.5	17.2	18.3	15.5
		MCWBR	10.2	9.7	9.5	9.5	8.8	7.7	4.0	4.2	5.2	8.1	10.0	9.6
Clear-Sky Solar Irradiance	taub	0.248	0.255	0.279	0.296	0.307	0.313	0.365	0.360	0.325	0.294	0.253	0.247	
	taud	2.600	2.590	2.501	2.431	2.448	2.424	2.384	2.379	2.462	2.506	2.600	2.610	
	Ebn at Noon	984	1008	1000	989	975	963	911	912	935	944	968	965	
	Edh at Noon	74	84	100	113	113	116	120	118	103	90	73	69	
All-Sky Solar Radiation	RadAvg	3.21	4.18	5.68	7.06	7.91	8.36	6.95	6.38	5.92	4.75	3.62	2.83	
	RadStd	0.27	0.35	0.34	0.31	0.47	0.37	0.38	0.29	0.21	0.35	0.19	0.21	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.45	N/A	N/A	+0.55	N/A	N/A	N/A	N/A	+100	+61
(47)	Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+62	+26

Nomenclature: See separate page