

SEDONA, AZ, USA

WMO: 723756

Lat: 34.850N

Lon: 111.783W

Elev: 1471

StdP: 84.85

Time Zone: -7.00 (W07)

Period: 09-19

WBAN: 00375

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-2.6	-1.2	-18.9	0.8	5.0	-17.1	1.0	7.0	10.5	4.2	9.2	5.1	3.2	30	0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.5	37.1	16.4	35.9	16.1	34.1	16.1	19.5	27.6	18.9	27.8	18.4	27.8	3.7	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.5	15.0	21.6	17.0	14.5	21.7	15.9	13.5	22.2	62.6	27.7	60.4	27.1	58.1	27.9	21.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.9	8.5	7.6	-6.4	39.8	2.9	1.6	-8.5	40.9	-10.2	41.8	-11.8	42.7	-14.0	43.8		
(5)			-8.2	20.5	2.7	0.8	-10.1	21.1	-11.7	21.6	-13.2	22.1	-15.1	22.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.3	7.7	8.6	12.7	15.6	19.8	26.5	27.3	26.5	24.0	18.2	12.5	7.4		
	DBStd	8.21	3.84	4.72	3.98	4.23	4.31	3.32	2.43	2.68	2.98	3.91	4.45	4.06		
	HDD10.0	323	88	75	21	7	1	0	0	0	0	3	27	101		
	HDD18.3	1483	330	272	177	98	37	0	0	0	1	49	178	340		
	CDD10.0	2980	16	36	104	176	305	496	538	512	419	257	102	19		
	CDD18.3	1099	0	0	2	17	82	246	279	254	170	45	3	0		
	CDH23.3	11503	0	1	26	185	823	3067	2966	2614	1469	331	22	0		
	CDH26.7	5437	0	0	1	33	279	1661	1506	1287	607	64	1	0		
(14) Wind	WSAvg	3.4	3.2	3.3	3.4	3.9	3.9	3.6	2.9	3.0	3.3	3.4	3.5	3.1		
(15) Precipitation	PrecAvg	499	58	60	55	28	17	7	47	62	47	37	35	46		
	PrecMax	766	248	151	153	65	93	41	141	138	123	150	104	148		
	PrecMin	284	0	0	2	1	1	1	5	16	0	1	3	1		
	PrecStd	133	63	40	43	22	21	9	35	28	40	37	26	44		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.7	22.5	26.1	30.0	33.0	39.9	37.7	37.4	35.2	31.2	26.1	19.7		
		MCWB	8.0	9.1	10.9	12.2	13.8	16.6	17.3	17.5	16.4	14.0	10.6	8.1		
	2%	DB	17.1	21.0	23.1	27.4	32.0	37.3	36.3	36.0	33.0	27.9	22.9	17.3		
		MCWB	6.6	8.5	9.7	11.2	13.2	15.6	16.9	16.8	15.7	12.5	9.4	7.1		
	5%	DB	15.1	17.8	22.2	25.9	30.0	36.0	35.0	34.7	32.2	27.1	21.3	15.2		
		MCWB	5.8	7.3	9.2	10.4	12.7	15.2	16.9	16.9	15.5	12.1	9.2	6.2		
	10%	DB	12.9	16.0	20.0	23.0	27.7	34.1	33.0	32.7	30.3	25.2	19.1	12.8		
		MCWB	4.9	6.4	8.2	9.4	11.6	14.5	16.6	16.7	15.2	11.6	8.3	5.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.9	10.8	11.5	13.0	14.8	17.9	20.5	20.3	19.5	16.4	11.6	10.1		
		MCDB	14.3	19.3	24.9	26.6	28.1	33.1	27.5	28.7	26.4	18.5	21.1	14.5		
	2%	WB	8.0	9.1	10.4	11.7	14.0	16.9	19.7	19.5	18.3	14.6	10.7	8.8		
		MCDB	13.2	17.9	22.3	26.1	28.4	33.1	27.7	27.7	26.8	23.5	21.0	14.6		
	5%	WB	7.1	8.0	9.6	10.8	13.0	16.2	19.1	18.9	17.6	13.7	9.9	7.5		
		MCDB	12.7	16.3	20.7	24.0	27.1	32.6	27.9	27.7	26.8	23.3	19.6	12.5		
	10%	WB	6.1	7.0	8.7	10.1	12.2	15.4	18.5	18.3	16.8	12.7	9.0	6.6		
		MCDB	11.8	14.4	18.9	22.7	26.3	31.6	28.0	27.7	26.0	22.3	17.6	11.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.0	9.9	11.7	12.6	12.8	13.7	12.5	12.2	12.1	11.6	10.3	8.3		
		MCDBR	10.8	12.6	13.3	14.3	15.0	15.1	14.0	13.9	13.6	13.0	11.9	9.8		
	5% WB	MCWBR	6.2	6.4	6.3	6.5	6.2	5.7	4.7	4.6	5.1	5.6	5.7	5.7		
		MCWBR	9.3	11.4	12.3	13.4	13.9	13.7	12.0	11.6	11.2	11.0	10.9	8.5		
(40) Clear-Sky Solar Irradiance	taub		0.253	0.255	0.279	0.294	0.308	0.310	0.365	0.366	0.310	0.292	0.260	0.251		
		taud	2.639	2.653	2.568	2.515	2.518	2.506	2.449	2.430	2.591	2.582	2.638	2.649		
	Ebn at Noon		980	1010	1001	992	974	966	912	907	954	949	962	962		
		Edh at Noon	71	79	94	104	106	107	112	113	91	84	71	67		
(44) All-Sky Solar Radiation	RadAvg		3.20	4.12	5.63	7.04	7.90	8.40	6.79	6.29	5.89	4.73	3.62	2.85		
	RadStd		0.29	0.37	0.38	0.32	0.49	0.40	0.45	0.34	0.23	0.36	0.18	0.20		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (13 neighbors)		+0.33	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+85	+33	

Nomenclature: See separate page