

MCCURTAIN COUNTY AP, OK, USA

WMO: 723759

Lat: 33.909N

Lon: 94.859W

Elev: 144

StdP: 99.61

Time Zone: -6.00 (NAC)

Period: 05-19

WBAN: 53990

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.1	-3.0	-13.0	1.2	-0.9	-11.2	1.5	0.3	10.4	12.2	9.2	11.3	2.2	340	0.425

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.5	37.3	23.8	36.1	23.7	34.8	23.5	25.8	31.6	25.1	32.2	24.6	31.6	3.0	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.8	20.2	28.1	22.9	17.9	27.7	22.5	17.5	27.3	80.6	33.2	77.1	31.6	74.8	31.8	32.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.7	7.6	6.8	DB	-9.7	39.8	2.5	2.6	-11.6	41.7	-13.0	43.2	-14.5	44.7	-16.3	46.5	(4)
(5)			WB	-10.4	26.7	2.4	1.8	-12.1	27.9	-13.5	28.9	-14.8	29.9	-16.5	31.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.2	5.9	8.1	13.0	16.5	21.1	25.9	27.5	27.7	24.1	17.6	11.8	7.3	(6)	
	DBStd	8.76	5.11	5.46	5.15	4.14	3.62	2.24	2.30	2.46	3.29	4.69	4.90	4.91	(7)	
	HDD10.0	427	147	93	29	4	0	0	0	0	3	36	114		(8)	
	HDD18.3	1569	387	288	176	81	17	0	0	0	2	72	203	343	(9)	
	CDD10.0	3071	19	40	122	199	345	478	541	548	422	237	88	31	(10)	
	CDD18.3	1171	1	1	11	26	103	228	283	290	174	48	6	1	(11)	
	CDH23.3	12027	3	7	83	230	878	2316	3120	3250	1638	451	47	4	(12)	
(13) Wind	CDH26.7	5635	0	1	8	27	266	1063	1636	1752	745	132	6	0	(13)	
	WSAvg	2.9	3.1	3.4	3.6	3.5	3.0	2.5	2.3	2.2	2.3	2.6	2.9	2.9	(14)	
	PrecAvg	1389	99	97	133	118	147	106	88	71	113	136	116	123	(15)	
	PrecMax	1922	207	227	253	275	365	249	235	184	262	386	399	217	(16)	
	PrecMin	937	9	21	57	47	64	27	3	7	31	2	36	8	(17)	
	PrecStd	244	50	57	61	64	75	58	72	47	57	97	87	54	(18)	
	DB	22.7	24.1	27.9	29.0	32.5	36.4	38.8	38.7	37.5	32.1	27.5	22.9		(19)	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	MCWB	15.4	16.3	19.6	19.4	21.8	23.2	23.4	24.0	22.6	19.6	20.2	16.9		(20)	
	DB	20.1	22.2	26.0	27.4	31.2	34.9	37.1	37.4	34.8	30.1	24.8	21.0		(21)	
	MCWB	14.8	15.2	17.4	18.3	21.9	23.6	23.3	24.3	22.1	20.9	18.0	16.0		(22)	
	DB	17.4	20.0	23.0	26.1	29.9	32.9	35.3	36.2	32.6	27.7	22.3	17.9		(23)	
	MCWB	12.6	14.8	16.0	17.9	21.5	23.4	23.7	24.3	21.9	19.1	17.2	14.0		(24)	
	DB	15.1	17.5	22.0	24.8	27.8	32.3	33.8	34.9	31.3	26.1	20.2	16.1		(25)	
	MCWB	10.1	13.2	16.0	17.5	20.7	23.3	23.5	23.8	21.9	18.3	15.7	12.3		(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	18.4	19.0	22.2	21.8	24.1	25.6	25.8	29.6	24.7	23.4	22.7	18.9		(27)	
	MCDB	21.1	22.5	24.9	26.1	29.4	32.4	32.9	35.6	31.0	28.5	24.5	22.1		(28)	
	WB	16.1	17.5	19.0	20.6	23.2	25.0	25.2	27.7	23.9	22.3	20.1	17.2		(29)	
	MCDB	18.8	19.7	23.6	25.3	28.6	32.0	32.7	32.6	30.4	27.3	23.4	19.4		(30)	
	WB	13.7	15.8	17.8	19.7	22.5	24.5	24.7	25.6	23.4	21.4	18.1	15.3		(31)	
	MCDB	16.6	18.4	21.9	24.4	27.7	31.0	32.1	31.6	29.8	25.4	20.8	17.7		(32)	
	WB	10.9	14.0	16.7	18.9	21.8	23.9	24.2	24.8	22.7	20.4	16.5	12.7		(33)	
(34) Mean Daily Temperature Range	MCDB	14.1	17.3	20.5	22.9	26.8	30.0	31.6	31.9	28.9	23.7	19.5	15.1		(34)	
	MDBR	11.6	11.3	12.3	12.4	11.5	11.5	12.1	12.5	12.4	13.2	12.7	11.0		(35)	
	5% DB	15.7	14.6	14.0	14.0	12.9	12.7	14.0	14.6	14.6	14.6	14.2	14.4		(36)	
	MCWBR	10.4	9.5	7.8	6.9	5.3	4.1	3.8	4.3	4.6	6.3	8.5	9.9		(37)	
	5% WB	13.1	11.7	11.6	10.6	10.7	11.2	12.1	12.9	11.6	11.3	11.4	12.3		(38)	
	MCWBR	10.4	9.1	7.5	6.4	5.2	4.2	4.1	4.9	4.3	5.7	8.6	9.8		(39)	
	taub	0.319	0.328	0.357	0.392	0.427	0.442	0.460	0.457	0.401	0.357	0.335	0.317		(40)	
(41) Clear-Sky Solar Irradiance	taud	2.493	2.476	2.420	2.320	2.288	2.281	2.263	2.261	2.376	2.479	2.495	2.510		(41)	
	Ebn at Noon	894	922	918	895	864	846	828	826	861	878	867	875		(42)	
	Edh at Noon	85	96	110	128	133	134	136	134	114	95	85	80		(43)	
	RadAvg	2.64	3.02	4.18	5.16	5.65	6.33	6.34	5.89	4.96	3.88	2.81	2.29		(44)	
(45) All-Sky Solar Radiation	RadStd	0.25	0.46	0.32	0.34	0.53	0.65	0.41	0.44	0.45	0.55	0.35	0.30		(45)	

Historical Trends

		Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (31 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page