

FLAGSTAFF BELLEMONT, AZ, USA

WMO: 723760

Lat: 35.217N

Lon: 111.817W

Elev: 7157

StdP: 11.27

Time Zone: -7.00 (W07)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.0	13.5	-5.7	5.3	34.2	-1.6	6.6	32.9	26.5	39.5	24.1	36.5	4.9	80	0.553

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.0	95.0	58.1	92.8	57.8	90.6	57.6	63.7	79.1	62.6	79.5	61.8	79.7	11.6	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.1	101.7	67.2	58.4	95.4	67.7	56.2	88.1	69.2	32.7	77.7	31.8	78.8	31.0	79.3	67.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
25.4	21.6	18.7	1.6	98.9	5.6	2.0	-2.4	100.3	-5.7	101.5	-8.9	102.6	-12.9	104.1		
			0.6	64.9	5.2	1.2	-3.1	65.7	-6.2	66.4	-9.1	67.1	-12.8	67.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.4	30.9	36.4	44.8	52.0	60.1	71.4	77.1	74.4	66.6	53.4	41.2	31.4	
	DBStd	17.20	7.58	6.89	6.75	6.69	7.07	5.50	3.63	3.74	6.04	6.79	7.47	6.94	
	HDD50	2122	592	382	186	57	10	0	0	0	1	43	275	576	
	HDD65	5232	1057	801	626	390	178	13	0	0	51	360	715	1041	
	CDD50	3365	0	0	25	118	324	642	841	758	497	150	10	0	
	CDD65	1001	0	0	0	0	28	205	376	293	97	2	0	0	
	CDH74	13219	0	0	2	70	779	3307	4504	3225	1264	68	0	0	
	CDH80	5943	0	0	0	5	210	1590	2301	1448	383	6	0	0	
Wind	WSAvg	7.9	6.9	7.8	8.7	9.8	8.8	8.6	8.1	7.5	7.4	7.6	7.4	6.9	
Precipitation	PrecAvg	22.1	2.2	2.2	2.4	1.3	0.8	0.4	2.7	3.0	2.0	1.5	1.7	1.8	
	PrecMax	37.3	8.4	6.5	8.8	5.6	5.2	3.3	7.4	6.9	6.6	9.6	6.5	6.5	
	PrecMin	10.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	PrecStd	5.0	1.9	1.8	1.9	1.2	0.9	0.6	1.7	1.7	1.5	1.6	1.4	1.6	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.5	61.6	72.3	79.6	90.0	97.0	98.9	95.5	90.6	80.0	67.6	55.1	
		MCWB	40.1	42.3	45.6	48.6	54.5	57.2	59.1	58.7	57.4	52.0	45.7	40.1	
	2%	DB	49.9	57.8	68.4	75.9	85.3	94.1	95.7	93.0	87.3	75.7	63.4	50.2	
		MCWB	37.8	40.4	44.2	47.8	52.3	55.9	58.9	58.3	56.5	50.9	44.0	38.2	
	5%	DB	46.4	53.5	64.7	72.8	81.8	91.7	93.5	90.7	84.4	72.2	59.8	46.7	
		MCWB	35.8	38.6	42.6	46.4	50.6	55.0	59.1	58.5	55.7	49.4	42.5	36.5	
	10%	DB	43.0	49.8	60.9	69.3	78.5	89.1	91.1	88.1	81.5	68.7	55.9	43.0	
		MCWB	34.6	37.1	41.2	45.0	49.8	54.4	59.2	58.6	54.8	48.1	40.9	34.8	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.6	44.8	47.4	51.7	56.8	61.4	65.1	65.3	62.0	57.2	48.2	43.3
			MCDB	50.0	57.3	68.4	72.7	82.7	80.9	79.4	77.4	77.1	69.1	61.0	50.1
2%		WB	40.0	41.9	45.4	49.2	54.4	59.8	63.9	63.9	60.1	54.3	45.9	40.2	
		MCDB	46.6	53.0	64.6	71.5	78.5	82.7	79.9	77.8	75.9	67.4	58.9	47.1	
5%		WB	37.4	40.0	43.8	47.5	52.6	58.4	62.9	62.7	59.0	52.5	43.8	37.5	
		MCDB	44.1	50.9	61.8	69.2	75.8	82.7	80.4	78.1	75.5	65.7	57.3	44.9	
10%		WB	35.4	38.1	42.1	45.9	51.1	56.9	62.1	61.8	57.7	50.4	41.7	35.3	
		MCDB	42.1	48.2	58.4	66.8	74.0	82.2	80.8	78.3	74.3	64.5	54.0	42.3	
Mean Daily Temperature Range	5% DB	MDBR	20.3	22.1	26.3	28.3	29.9	33.0	28.0	26.7	27.4	26.2	23.5	19.3	
		MCDBR	24.0	28.4	32.5	34.4	35.3	35.9	31.8	30.8	30.7	31.0	29.1	23.3	
		MCWBR	14.1	14.9	14.8	15.3	13.8	13.2	9.5	9.7	11.3	13.2	14.9	13.7	
	5% WB	MCDBR	19.0	24.1	29.2	31.2	31.2	29.7	24.3	23.1	23.9	24.3	25.1	19.7	
		MCWBR	11.8	13.1	13.6	14.3	12.0	10.6	5.9	6.3	8.7	11.1	13.1	12.3	
Clear-Sky Solar Irradiance	taub	0.232	0.235	0.253	0.263	0.277	0.279	0.324	0.328	0.280	0.268	0.238	0.232		
	taud	2.683	2.695	2.627	2.589	2.596	2.583	2.531	2.499	2.662	2.629	2.683	2.683		
	Ebn at Noon	320	329	327	325	319	316	302	299	313	311	314	314		
	Edh at Noon	21	24	28	31	31	31	33	33	27	25	21	20		
All-Sky Solar Radiation	RadAvg	1005	1303	1781	2223	2484	2650	2142	1982	1862	1490	1137	893		
	RadStd	88	112	117	101	163	131	141	106	73	111	54	63		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (14 neighbors)		+0.59	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+180	+72

Nomenclature: See separate page