

FLAGSTAFF BELLEMONT, AZ, USA

WMO: 723760

Lat: 35.217N

Lon: 111.817W

Elev: 2182

StdP: 77.72

Time Zone: -7.00 (W07)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.8	-10.3	-21.0	0.8	1.2	-18.7	0.9	0.5	11.9	4.2	10.8	2.5	2.2	80	0.553

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.5	35.0	14.5	33.8	14.3	32.6	14.2	17.6	26.2	17.0	26.4	16.5	26.5	5.2	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.6	14.5	19.5	14.6	13.6	19.8	13.4	12.6	20.6	58.2	25.4	56.1	26.0	54.3	26.3	19.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.4	9.6	8.3	DB	-16.9	37.2	3.1	1.1	-19.1	38.0	-21.0	38.6	-22.7	39.2	-25.0	40.1	(4)
(5)			WB	-17.4	18.3	2.9	0.6	-19.5	18.7	-21.2	19.1	-22.8	19.5	-24.9	19.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.9	-0.6	2.4	7.1	11.1	15.6	21.9	25.1	23.6	19.2	11.9	5.1	-0.3		
	DBStd	9.55	4.21	3.83	3.75	3.71	3.93	3.05	2.02	2.08	3.36	3.77	4.15	3.86		
	HDD10.0	1179	329	212	103	32	6	0	0	0	1	24	153	320		
	HDD18.3	2907	587	445	348	217	99	7	0	0	28	200	397	578		
	CDD10.0	1869	0	0	14	66	180	357	467	421	276	83	6	0		
	CDD18.3	556	0	0	0	0	16	114	209	163	54	1	0	0		
	CDH23.3	7344	0	0	1	39	433	1837	2502	1792	702	38	0	0		
	CDH26.7	3302	0	0	0	3	117	883	1278	804	213	3	0	0		
(14) Wind	WSAvg	3.6	3.1	3.5	3.9	4.4	4.0	3.8	3.6	3.4	3.3	3.4	3.3	3.1		
(15) Precipitation	PrecAvg	561	55	55	60	34	20	11	68	76	50	37	42	45		
	PrecMax	947	214	164	224	142	131	83	188	176	167	243	166	166		
	PrecMin	260	0	0	0	0	0	0	0	0	0	0	0	0		
	PrecStd	128	49	45	48	30	23	15	44	42	39	41	35	41		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.5	16.4	22.4	26.5	32.2	36.1	37.2	35.3	32.6	26.7	19.8	12.8		
		MCWB	4.5	5.7	7.5	9.2	12.5	14.0	15.1	14.8	14.1	11.1	7.6	4.5		
	2%	DB	10.0	14.3	20.2	24.4	29.6	34.5	35.4	33.9	30.7	24.3	17.4	10.1		
		MCWB	3.2	4.7	6.8	8.8	11.3	13.3	14.9	14.6	13.6	10.5	6.6	3.4		
	5%	DB	8.0	12.0	18.2	22.6	27.7	33.1	34.2	32.6	29.1	22.3	15.5	8.2		
		MCWB	2.1	3.7	5.9	8.0	10.3	12.8	15.1	14.7	13.1	9.7	5.8	2.5		
	10%	DB	6.1	9.9	16.0	20.7	25.8	31.7	32.8	31.2	27.5	20.4	13.3	6.1		
		MCWB	1.4	2.8	5.1	7.2	9.9	12.4	15.1	14.8	12.7	8.9	5.0	1.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.9	7.1	8.6	10.9	13.8	16.3	18.4	18.5	16.7	14.0	9.0	6.3		
		MCDB	10.0	14.0	20.2	22.6	28.2	27.2	26.3	25.2	25.1	20.6	16.1	10.1		
	2%	WB	4.4	5.5	7.4	9.6	12.4	15.4	17.7	17.7	15.6	12.4	7.7	4.6		
		MCDB	8.1	11.7	18.1	22.0	25.9	28.2	26.6	25.5	24.4	19.7	14.9	8.4		
	5%	WB	3.0	4.5	6.5	8.6	11.5	14.6	17.2	17.1	15.0	11.4	6.5	3.1		
		MCDB	6.7	10.5	16.6	20.7	24.4	28.2	26.9	25.6	24.1	18.7	14.1	7.2		
	10%	WB	1.9	3.4	5.6	7.7	10.6	13.9	16.7	16.6	14.3	10.2	5.4	1.8		
		MCDB	5.6	9.0	14.7	19.3	23.3	27.9	27.1	25.7	23.5	18.1	12.2	5.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.3	12.3	14.6	15.7	16.6	18.3	15.5	14.9	15.2	14.5	13.1	10.7		
		MCDBR	13.3	15.8	18.0	19.1	19.6	20.0	17.7	17.1	17.1	17.2	16.2	13.0		
		MCWBR	7.9	8.3	8.2	8.5	7.7	7.4	5.3	5.4	6.3	7.4	8.3	7.6		
		MCDBR	10.6	13.4	16.2	17.3	17.3	16.5	13.5	12.8	13.3	13.5	14.0	10.9		
	5% WB	MCWBR	6.6	7.3	7.5	8.0	6.7	5.9	3.3	3.5	4.9	6.2	7.3	6.8		
(40) Clear-Sky Solar Irradiance	taub		0.232	0.235	0.253	0.263	0.277	0.279	0.324	0.328	0.280	0.268	0.238	0.232		
	taud		2.683	2.695	2.627	2.589	2.596	2.583	2.531	2.499	2.662	2.629	2.683	2.683		
	Ebn at Noon		1009	1036	1031	1025	1005	997	951	944	986	979	991	990		
	Edh at Noon		67	75	88	97	98	99	103	105	98	79	67	64		
(44) All-Sky Solar Radiation	RadAvg		3.17	4.11	5.62	7.01	7.83	8.35	6.75	6.25	5.87	4.70	3.58	2.81		
	RadStd		0.28	0.35	0.37	0.32	0.51	0.41	0.44	0.34	0.23	0.35	0.17	0.20		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)		+0.33	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+100	+40

Nomenclature: See separate page