

DENIO 52 WSW, NV, USA

WMO: 723850

Lat: 41.8484N

Lon: 119.6357W

Elev: 6500

StdP: 11.56

Time Zone: -8.00 (NAP)

Period: 08-19

WBAN: 04139

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	5.0	10.2	-4.2	5.6	21.1	-0.3	6.9	20.4	19.3	31.2	16.9	33.2	3.5	N/A	0.573

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.3	84.8	54.1	82.2	53.2	79.5	52.2	56.6	77.9	55.2	76.7	53.9	75.8	6.7	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
49.1	65.9	61.3	46.3	59.1	59.9	43.9	53.9	59.5	26.9	75.7	25.9	77.1	25.1	76.3	61.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
15.9	13.7	12.0	DB	-3.4	89.6	4.2	2.7	-6.4	91.6	-8.9	93.2	-11.2	94.7	-14.3	96.7
			WB	-3.1	59.3	4.5	1.1	-6.4	60.1	-9.0	60.7	-11.6	61.3	-14.8	62.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.4	29.8	28.5	33.1	38.1	45.8	54.6	64.4	63.7	56.4	44.3	34.8	26.5		
	DBStd	15.46	8.36	8.86	7.83	8.64	8.16	8.14	5.69	5.77	8.81	8.95	9.63	9.15		
	HDD50	3800	625	601	523	368	182	47	1	3	44	217	462	727		
	HDD65	7997	1090	1021	987	806	595	322	79	86	270	642	907	1192		
	CDD50	1406	0	0	1	12	52	184	448	429	235	40	5	0		
	CDD65	128	0	0	0	0	0	9	61	47	11	0	0	0		
	CDH74	2269	0	0	0	0	6	180	1034	827	214	8	0	0		
	CDH80	473	0	0	0	0	0	31	245	169	27	1	0	0		
(14) Wind	WSAvg	5.8	6.2	6.9	6.8	6.4	5.8	5.3	5.0	4.9	4.8	5.4	5.8	6.3		
(15) Precipitation	PrecAvg	10.4	1.5	1.2	1.1	0.9	1.0	0.6	0.2	0.2	0.4	0.7	0.9	1.5		
	PrecMax	18.7	4.9	4.1	2.4	2.5	3.2	2.4	1.0	0.8	2.1	2.5	2.0	4.1		
	PrecMin	6.6	0.2	0.2	0.2	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.1		
	PrecStd	3.0	1.0	0.9	0.6	0.5	0.7	0.6	0.2	0.2	0.4	0.6	0.4	1.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.8	53.3	59.4	69.1	74.2	84.5	88.2	87.4	83.4	74.5	62.2	50.1		
		MCWB	37.2	40.0	39.3	46.4	50.3	56.5	55.4	54.1	53.2	48.8	43.9	34.3		
	2%	DB	47.0	47.7	54.2	63.7	70.1	78.8	85.4	84.2	79.2	67.1	57.3	44.5		
		MCWB	35.1	36.7	39.4	44.7	48.4	53.6	54.4	53.1	50.7	45.6	41.6	34.2		
	5%	DB	43.4	43.6	49.7	59.2	66.2	75.2	82.9	81.6	76.4	62.6	52.4	41.4		
		MCWB	35.3	35.3	37.7	42.3	46.8	51.9	53.6	52.2	49.9	43.8	40.1	33.6		
	10%	DB	40.5	40.5	45.4	53.9	62.0	71.6	80.2	78.8	73.2	58.8	48.0	38.5		
		MCWB	33.3	34.2	36.3	40.0	45.0	49.9	52.8	51.4	49.1	42.3	37.5	32.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.4	40.8	44.2	48.3	51.4	58.9	58.8	56.3	55.4	49.7	45.8	39.4		
		MCDB	46.9	49.2	57.5	66.3	69.1	79.6	80.4	78.2	74.2	65.0	57.9	41.5		
	2%	WB	38.1	38.9	41.0	45.8	50.0	56.0	57.1	54.9	53.8	47.5	42.9	37.4		
		MCDB	43.3	46.0	50.5	61.0	66.3	76.3	78.6	78.7	72.3	64.0	53.2	40.7		
	5%	WB	36.2	37.1	39.2	43.5	48.3	53.5	55.6	53.8	52.1	45.6	40.7	35.4		
		MCDB	41.9	42.7	48.6	57.4	63.4	72.4	77.1	77.4	70.7	60.2	49.9	39.0		
	10%	WB	34.3	35.3	37.4	41.5	46.5	51.7	54.5	52.7	50.3	43.6	38.6	33.7		
		MCDB	39.8	40.8	46.0	52.9	60.3	70.6	76.6	75.8	70.3	56.4	46.8	38.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.8	13.1	15.8	20.1	21.8	25.1	28.3	27.9	25.3	20.7	15.6	12.9		
		MCDBR	16.6	15.9	21.4	26.8	26.9	29.3	30.0	29.9	27.6	24.7	19.8	15.9		
		MCWBR	10.5	9.4	11.8	13.6	13.2	13.0	12.0	11.6	12.2	11.9	10.4	9.8		
	5% WB	MCDBR	14.4	13.9	19.3	24.9	24.2	27.4	27.3	27.1	25.1	22.8	18.3	13.2		
		MCWBR	10.1	8.6	11.0	13.0	12.3	12.6	11.4	11.1	11.5	11.5	10.3	9.5		
(40) Clear-Sky Solar Irradiance	taub		0.235	0.243	0.247	0.269	0.279	0.279	0.286	0.281	0.267	0.255	0.240	0.235		
	taud		2.621	2.644	2.675	2.587	2.593	2.619	2.599	2.595	2.633	2.675	2.666	2.619		
	Ebn at Noon		303	316	324	319	316	314	311	311	312	306	299	294		
	Edh at Noon		20	23	25	30	30	30	30	29	26	22	19	18		
(44) All-Sky Solar Radiation	RadAvg		605	891	1305	1753	2124	2472	2506	2206	1761	1186	721	494		
	RadStd		98	124	113	151	191	138	111	107	87	84	62	99		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page