

DENIO 52 WSW, NV, USA

WMO: 723850

Lat: 41.8484N

Lon: 119.6357W

Elev: 1981

StdP: 79.68

Time Zone: -8.00 (NAP)

Period: 08-19

WBAN: 04139

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-15.0	-12.1	-20.1	0.8	-6.1	-18.0	1.0	-6.4	8.6	-0.5	7.6	0.7	1.5	N/A	0.573

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.7	29.3	12.3	27.9	11.8	26.4	11.2	13.6	25.5	12.9	24.9	12.2	24.4	3.0	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.5	9.4	16.3	7.9	8.4	15.5	6.6	7.7	15.3	44.7	24.3	42.3	25.1	40.4	24.6	16.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.1	6.1	5.4	-19.7	32.0	2.3	1.5	-21.4	33.1	-22.7	34.0	-24.0	34.8	-25.7	35.9		
(5)			-19.5	15.2	2.5	0.6	-21.3	15.6	-22.8	16.0	-24.2	16.3	-26.0	16.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.4	-1.2	-1.9	0.6	3.4	7.7	12.5	18.0	17.6	13.5	6.8	1.5	-3.0	(6)
(7)		DBStd	8.59	4.65	4.92	4.35	4.80	4.53	4.52	3.16	3.20	4.89	4.97	5.35	5.09	(7)
(8)		HDD10.0	2111	347	334	291	204	101	26	1	2	24	121	257	404	(8)
(9)		HDD18.3	4443	606	567	548	448	331	179	44	48	150	357	504	662	(9)
(10)		CDD10.0	781	0	0	1	7	29	102	249	238	131	22	3	0	(10)
(11)		CDD18.3	71	0	0	0	0	0	5	34	26	6	0	0	0	(11)
(12)		CDH23.3	1261	0	0	0	0	3	100	574	459	119	4	0	0	(12)
(13)		CDH26.7	263	0	0	0	0	0	17	136	94	15	1	0	0	(13)
(14)	Wind	WSAvg	2.6	2.8	3.1	3.0	2.8	2.6	2.4	2.2	2.1	2.4	2.6	2.8	(14)	
(15)	Precipitation	PrecAvg	263	39	30	28	23	26	16	6	9	18	23	39	(15)	
(16)		PrecMax	475	124	104	60	64	82	62	25	21	53	63	51	103	(16)
(17)		PrecMin	168	5	5	4	5	1	1	0	0	0	1	7	3	(17)
(18)		PrecStd	76	26	22	16	12	19	16	5	5	10	15	10	27	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.0	11.8	15.2	20.6	23.5	29.2	31.2	30.8	28.6	23.6	16.8	10.1	(19)
(20)			MCWB	2.9	4.4	4.0	8.0	10.2	13.6	13.0	12.3	11.8	9.3	6.6	1.3	(20)
(21)		2%	DB	8.3	8.7	12.3	17.6	21.2	26.0	29.7	29.0	26.2	19.5	14.1	6.9	(21)
(22)			MCWB	1.7	2.6	4.1	7.0	9.1	12.0	12.5	11.7	10.4	7.6	5.3	1.2	(22)
(23)		5%	DB	6.3	6.4	9.8	15.1	19.0	24.0	28.3	27.6	24.6	17.0	11.3	5.2	(23)
(24)			MCWB	1.8	1.8	3.2	5.7	8.2	11.1	12.0	11.2	10.0	6.6	4.5	0.9	(24)
(25)		10%	DB	4.7	4.7	7.5	12.2	16.6	22.0	26.8	26.0	22.9	14.9	8.9	3.6	(25)
(26)			MCWB	0.7	1.2	2.4	4.5	7.2	10.0	11.6	10.8	9.5	5.7	3.1	0.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.2	4.9	6.8	9.1	10.8	14.9	14.9	13.5	13.0	9.8	7.7	4.1	(27)
(28)			MCDWB	8.3	9.6	14.2	19.0	20.6	26.4	26.9	25.6	23.4	18.3	14.4	5.3	(28)
(29)		2%	WB	3.4	3.9	5.0	7.6	10.0	13.3	13.9	12.7	12.1	8.6	6.0	3.0	(29)
(30)			MCDWB	6.3	7.8	10.3	16.1	19.1	24.6	25.9	26.0	22.4	17.8	11.8	4.8	(30)
(31)		5%	WB	2.4	2.8	4.0	6.4	9.0	11.9	13.1	12.1	11.2	7.6	4.8	1.9	(31)
(32)			MCDWB	5.5	6.0	9.2	14.1	17.4	22.5	25.1	25.2	21.5	15.7	9.9	3.9	(32)
(33)		10%	WB	1.3	1.8	3.0	5.3	8.1	10.9	12.5	11.5	10.2	6.5	3.7	0.9	(33)
(34)			MCDWB	4.3	4.9	7.8	11.6	15.7	21.5	24.8	24.4	21.3	13.6	8.2	3.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.1	7.3	8.8	11.2	12.1	13.9	15.7	15.5	14.1	11.5	8.6	7.2	(35)
(36)			MCDBR	9.2	8.8	11.9	14.9	14.9	16.3	16.7	16.6	15.3	13.7	11.0	8.8	(36)
(37)			MCWBR	5.8	5.2	6.5	7.5	7.4	7.2	6.7	6.4	6.8	6.6	5.8	5.5	(37)
(38)		5% WB	MCDWB	8.0	7.7	10.7	13.9	13.4	15.2	15.2	15.1	13.9	12.7	10.2	7.3	(38)
(39)			MCWBR	5.6	4.8	6.1	7.2	6.8	7.0	6.3	6.2	6.4	6.4	5.7	5.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.235	0.243	0.247	0.269	0.279	0.279	0.286	0.281	0.267	0.255	0.240	0.235	(40)	
(41)		taud	2.621	2.644	2.675	2.587	2.593	2.619	2.599	2.595	2.633	2.675	2.666	2.619	(41)	
(42)		Ebn at Noon	956	995	1020	1007	996	991	981	981	982	965	943	926	(42)	
(43)		Edh at Noon	63	72	79	94	96	94	95	92	82	69	60	58	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.91	2.81	4.12	5.53	6.70	7.79	7.90	6.95	5.55	3.74	2.27	1.56	(44)	
(45)		RadStd	0.31	0.39	0.36	0.47	0.60	0.44	0.35	0.34	0.28	0.27	0.19	0.31	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (6 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page