

BAKER 5 W, NV, USA

WMO: 723880

Lat: 39.0118N

Lon: 114.2090W

Elev: 6617

StdP: 11.51

Time Zone: -8.00 (NAP)

Period: 04-19

WBAN: 53138

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	5.5	10.1	-4.5	5.5	20.2	-0.9	6.7	23.6	14.3	42.5	12.6	42.6	3.1	N/A	0.464

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.1	88.9	54.8	86.8	54.4	84.6	53.8	59.8	75.9	58.6	76.5	57.3	76.6	5.8	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.0	82.4	63.3	52.4	75.0	64.1	49.8	67.9	65.8	29.5	76.6	28.5	76.5	27.6	76.7	67.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.9	9.7	8.2	DB	-2.3	93.2	4.7	1.6	-5.7	94.4	-8.5	95.3	-11.1	96.2	-14.6	97.3	(4)
(5)			WB	-2.9	63.9	3.7	2.0	-5.5	65.3	-7.7	66.4	-9.8	67.5	-12.5	69.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.9	29.2	31.5	38.9	44.7	52.5	65.8	73.6	71.0	62.4	48.5	38.2	28.9		
	DBStd	17.61	9.22	9.14	8.43	8.10	8.27	8.19	4.51	4.62	8.00	8.67	9.58	10.00		
	HDD50	2954	646	518	356	200	69	5	0	0	13	131	363	653		
	HDD65	6529	1111	937	810	610	393	90	2	11	133	511	803	1118		
	CDD50	2541	0	0	12	39	147	478	732	652	385	86	10	0		
	CDD65	645	0	0	0	0	7	113	270	198	56	1	0	0		
	CDH74	6084	0	0	0	2	66	1212	2622	1766	410	6	0	0		
	CDH80	1862	0	0	0	0	4	362	942	501	53	0	0	0		
(14) Wind	WSAvg	4.1	3.5	3.7	4.2	4.6	4.3	4.6	4.4	4.4	4.4	3.9	3.7	3.4		
(15) Precipitation	PrecAvg	9.8	0.7	0.9	0.8	1.1	1.0	0.7	0.7	0.7	0.7	0.9	0.6	0.7		
	PrecMax	13.6	2.0	2.2	1.6	2.3	2.8	2.4	1.5	2.3	2.0	2.4	1.5	2.8		
	PrecMin	5.6	0.1	0.2	0.1	0.0	0.0	0.0	0.1	0.1	0.1	0.0	0.0	0.2		
	PrecStd	2.0	0.5	0.5	0.5	0.6	0.7	0.7	0.4	0.6	0.5	0.6	0.4	0.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.3	57.3	66.5	72.6	79.9	90.7	92.6	89.2	85.0	73.7	64.5	57.4		
		MCWB	37.8	39.9	44.1	47.9	50.2	54.8	55.5	54.7	53.0	49.4	43.3	37.6		
	2%	DB	49.4	53.1	61.3	66.9	75.6	87.2	89.8	87.0	81.3	69.9	60.0	52.0		
		MCWB	37.7	38.8	42.3	44.5	48.7	53.2	55.4	54.7	52.4	47.7	41.9	37.7		
	5%	DB	45.6	49.2	57.0	63.2	71.7	84.3	87.8	85.2	78.8	66.2	56.6	48.0		
		MCWB	35.0	37.6	40.4	43.5	47.6	52.2	55.1	53.9	51.7	46.0	40.4	36.4		
	10%	DB	42.3	46.0	53.4	59.8	68.0	81.3	85.7	83.1	76.0	62.4	52.7	44.1		
		MCWB	33.1	35.6	38.8	42.5	46.1	51.0	54.7	53.6	51.1	44.5	38.6	34.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.0	42.7	45.3	49.4	51.7	57.9	61.8	60.7	60.4	52.2	45.1	41.3		
		MCDB	50.8	54.9	65.3	68.0	68.8	83.2	73.4	74.2	70.2	66.3	61.1	51.5		
	2%	WB	38.4	40.6	43.4	47.0	50.1	56.2	60.1	59.3	57.5	49.9	43.0	39.4		
		MCDB	47.0	51.2	60.6	64.9	69.7	82.1	76.6	75.4	70.5	64.9	58.5	47.6		
	5%	WB	36.4	38.9	41.8	45.0	48.7	54.5	59.1	58.0	55.3	48.2	41.0	37.1		
		MCDB	44.5	49.4	56.5	61.2	67.7	80.0	77.5	76.2	69.0	62.8	54.6	47.2		
	10%	WB	34.3	37.2	40.1	43.4	47.5	52.9	57.9	56.8	53.7	46.4	39.2	34.8		
		MCDB	41.9	47.5	53.4	59.0	64.8	78.1	77.1	75.9	69.5	60.6	51.7	43.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.6	16.7	19.0	20.4	20.5	23.6	22.1	22.2	20.7	19.2	18.1	16.8		
		MCDBR	19.5	19.9	22.8	24.2	23.6	25.1	23.6	23.8	22.4	22.3	21.1	20.8		
		MCWBR	12.1	11.2	11.4	11.4	10.1	9.6	9.1	9.5	9.6	10.7	11.2	11.9		
	5% WB	MCDBR	18.0	18.3	21.6	22.7	21.4	24.0	21.1	21.3	18.6	18.6	20.5	18.8		
		MCWBR	11.7	10.7	11.4	11.2	9.7	9.2	8.5	9.0	9.0	9.4	11.2	11.4		
(40) Clear-Sky Solar Irradiance	taub		0.230	0.238	0.245	0.276	0.288	0.288	0.314	0.310	0.272	0.253	0.236	0.230		
	taud		2.629	2.609	2.632	2.505	2.511	2.539	2.500	2.495	2.604	2.645	2.648	2.626		
	Ebn at Noon		312	322	327	318	314	312	303	303	312	311	307	305		
	Edh at Noon		21	25	27	33	33	32	33	33	27	23	20	20		
(44) All-Sky Solar Radiation	RadAvg		804	1085	1531	1912	2184	2532	2252	2088	1799	1299	912	688		
	RadStd		71	106	88	122	202	188	140	140	109	98	51	63		

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page