

BAKER 5 W, NV, USA

WMO: 723880

Lat: 39.0118N

Lon: 114.2090W

Elev: 2017

StdP: 79.33

Time Zone: -8.00 (NAP)

Period: 04-19

WBAN: 53138

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-14.7	-12.2	-20.3	0.8	-6.6	-18.3	1.0	-4.7	6.4	5.8	5.6	5.9	1.4	N/A	0.464

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.3	31.6	12.7	30.5	12.5	29.2	12.1	15.4	24.4	14.8	24.7	14.1	24.8	2.6	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.8	11.8	17.4	11.3	10.7	17.8	9.9	9.7	18.8	50.7	24.8	48.4	24.7	46.3	24.8	19.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.3	4.3	3.7	DB	-19.1	34.0	2.6	0.9	-21.0	34.6	-22.5	35.2	-24.0	35.7	-25.9	36.3	(4)
(5)			WB	-19.4	17.7	2.1	1.1	-20.8	18.5	-22.1	19.1	-23.2	19.7	-24.7	20.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.4	-1.6	-0.3	3.8	7.0	11.4	18.8	23.1	21.7	16.9	9.2	3.5	-1.7	(6)	
	DBStd	9.78	5.12	5.08	4.68	4.50	4.60	4.55	2.51	2.57	4.44	4.82	5.32	5.55	(7)	
	HDD10.0	1641	359	288	198	111	38	3	0	0	7	73	202	363	(8)	
	HDD18.3	3627	617	521	450	339	218	50	1	6	74	284	446	621	(9)	
	CDD10.0	1412	0	0	7	22	82	266	407	362	214	48	6	0	(10)	
	CDD18.3	358	0	0	0	0	4	63	150	110	31	1	0	0	(11)	
	CDH23.3	3380	0	0	0	1	37	673	1457	981	228	3	0	0	(12)	
	CDH26.7	1034	0	0	0	0	2	201	523	278	29	0	0	0	(13)	
(14) Wind	WSAvg	1.8	1.5	1.7	1.9	2.0	1.9	2.1	1.9	2.0	1.9	1.7	1.7	1.5	(14)	
(15) Precipitation	PrecAvg	249	19	23	21	29	26	19	17	19	19	23	15	18	(15)	
	PrecMax	345	52	55	41	59	70	61	37	59	52	61	39	72	(16)	
	PrecMin	143	3	6	2	1	1	1	2	3	3	1	0	4	(17)	
	PrecStd	50	12	12	12	14	18	17	10	14	12	15	10	14	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.4	14.1	19.2	22.5	26.6	32.6	33.7	31.8	29.5	23.2	18.1	14.1	(19)	
		MCWB	3.2	4.4	6.7	8.8	10.1	12.7	13.1	12.6	11.7	9.7	6.3	3.1	(20)	
	2%	DB	9.6	11.7	16.3	19.4	24.2	30.7	32.1	30.6	27.4	21.1	15.6	11.1	(21)	
		MCWB	3.2	3.8	5.7	6.9	9.3	11.8	13.0	12.6	11.3	8.7	5.5	3.2	(22)	
	5%	DB	7.6	9.6	13.9	17.3	22.0	29.1	31.0	29.6	26.0	19.0	13.7	8.9	(23)	
		MCWB	1.7	3.1	4.7	6.4	8.6	11.2	12.9	12.2	10.9	7.8	4.7	2.4	(24)	
	10%	DB	5.7	7.8	11.9	15.4	20.0	27.4	29.8	28.4	24.5	16.9	11.5	6.7	(25)	
		MCWB	0.6	2.0	3.8	5.8	7.8	10.6	12.6	12.0	10.6	7.0	3.7	1.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.0	6.0	7.4	9.7	10.9	14.4	16.6	15.9	15.8	11.2	7.3	5.2	(27)	
		MCDB	10.5	12.7	18.5	20.0	20.5	28.4	23.0	23.5	21.2	19.1	16.2	10.8	(28)	
	2%	WB	3.6	4.8	6.3	8.3	10.0	13.5	15.6	15.2	14.2	9.9	6.1	4.1	(29)	
		MCDB	8.4	10.6	15.9	18.3	20.9	27.8	24.8	24.1	21.4	18.3	14.7	8.7	(30)	
	5%	WB	2.5	3.8	5.4	7.2	9.3	12.5	15.0	14.4	13.0	9.0	5.0	2.9	(31)	
		MCDB	7.0	9.6	13.6	16.2	19.9	26.6	25.3	24.5	20.5	17.1	12.6	8.5	(32)	
	10%	WB	1.3	2.9	4.5	6.4	8.6	11.6	14.4	13.8	12.1	8.0	4.0	1.6	(33)	
		MCDB	5.5	8.6	11.9	15.0	18.2	25.6	25.1	24.4	20.8	15.9	11.0	6.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.2	9.3	10.5	11.3	11.4	13.1	12.3	12.3	11.5	10.7	10.0	9.3	(35)	
		MCDBR	10.8	11.0	12.7	13.4	13.1	14.0	13.1	13.2	12.5	12.4	11.7	11.6	(36)	
	5% WB	MCWBR	6.7	6.2	6.3	6.4	5.6	5.3	5.0	5.3	5.4	5.9	6.2	6.6	(37)	
		MCWBR	10.0	10.2	12.0	12.6	11.9	13.4	11.7	11.8	10.3	10.3	11.4	10.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.230	0.238	0.245	0.276	0.288	0.288	0.314	0.310	0.272	0.253	0.236	0.230	(40)	
		taud	2.629	2.609	2.632	2.505	2.511	2.539	2.500	2.495	2.604	2.645	2.648	2.626	(41)	
	Ebn at Noon		985	1014	1030	1004	990	985	956	956	984	981	969	961	(42)	
		Edh at Noon	66	78	85	103	105	102	105	103	86	74	64	62	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.54	3.42	4.83	6.03	6.88	7.98	7.10	6.58	5.67	4.09	2.88	2.17	(44)	
	RadStd		0.22	0.33	0.28	0.38	0.64	0.59	0.44	0.44	0.34	0.31	0.16	0.20	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)			
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page