

VISALIA, CA, USA

WMO: 723896

Lat: 36.317N

Lon: 119.400W

Elev: 295

StdP: 14.54

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 93144

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	29.9	32.6	22.9	17.5	42.0	27.0	21.2	40.1	16.8	52.3	14.0	52.2	2.1	120	0.420

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.0	100.3	71.8	98.9	71.0	96.7	70.1	74.9	95.7	73.2	93.6	71.7	92.0	7.4	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.1	104.2	85.3	65.8	96.2	84.4	63.9	89.8	83.4	38.3	95.2	36.9	94.1	35.5	91.8	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.6	12.6	11.0	DB	26.8	105.7	2.9	2.0	24.7	107.2	23.0	108.3	21.4	109.5	19.3	110.9	(4)
(5)			WB	25.7	77.4	3.3	1.8	23.3	78.7	21.4	79.7	19.6	80.7	17.2	82.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.1	47.5	50.9	56.4	61.0	68.5	75.5	80.3	78.5	73.7	63.9	53.7	46.4	(6)	
	DBStd	12.91	5.02	4.87	5.47	6.57	6.40	5.95	4.35	4.32	5.42	5.72	5.48	5.26	(7)	
	HDD50	330	111	44	9	2	0	0	0	0	0	0	27	137	(8)	
	HDD65	2413	544	396	271	154	37	4	0	0	4	87	341	575	(9)	
	CDD50	5108	32	68	208	332	573	766	939	883	712	432	136	27	(10)	
	CDD65	1714	0	0	4	34	144	320	474	418	266	54	0	0	(11)	
	CDH74	23063	0	1	120	622	2052	4368	6296	5346	3339	889	30	0	(12)	
	CDH80	12346	0	0	18	200	923	2421	3696	3063	1737	287	1	0	(13)	
(14) Wind	WSAvg	4.5	3.4	4.0	4.5	5.5	6.2	6.3	5.4	4.8	4.3	3.7	3.1	3.3	(14)	
(15) Precipitation	PrecAvg	9.9	1.7	1.9	1.7	1.0	0.2	0.1	0.0	0.0	0.2	0.4	1.3	1.4	(15)	
	PrecMax	18.1	7.7	5.8	5.0	4.8	2.2	0.7	0.2	0.2	1.5	1.9	3.5	3.8	(16)	
	PrecMin	5.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	3.5	1.6	1.7	1.3	1.1	0.5	0.2	0.1	0.0	0.4	0.5	1.0	0.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.2	72.7	82.2	90.5	99.0	103.1	103.8	102.3	99.4	92.6	78.1	66.3	(19)	
		MCWB	54.6	59.3	62.6	63.9	69.2	72.4	73.5	73.2	70.0	66.6	59.9	55.5	(20)	
	2%	DB	63.2	67.9	77.2	85.2	93.1	99.6	100.3	99.4	96.8	87.6	73.4	62.9	(21)	
		MCWB	54.1	57.9	60.6	63.0	66.4	70.2	72.7	71.7	69.0	64.4	58.8	53.6	(22)	
	5%	DB	60.5	64.0	73.1	81.4	89.9	96.9	98.7	97.2	93.2	82.4	69.8	59.1	(23)	
		MCWB	53.6	55.4	58.7	60.9	64.8	68.9	72.0	70.7	68.0	62.3	57.6	52.0	(24)	
	10%	DB	56.8	61.2	70.0	76.7	84.7	92.7	96.3	93.9	90.5	79.3	65.5	55.7	(25)	
		MCWB	51.7	53.6	57.6	59.3	63.1	67.2	71.0	69.6	67.0	61.1	55.7	50.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.5	61.3	64.9	67.1	71.3	75.6	77.9	76.7	74.0	68.8	62.8	58.7	(27)	
		MCDB	63.2	69.0	78.5	84.8	95.3	98.6	98.6	97.1	93.1	86.8	73.2	63.4	(28)	
	2%	WB	56.0	59.0	62.3	64.3	68.3	72.8	75.3	74.1	71.2	66.2	60.6	55.5	(29)	
		MCDB	60.2	65.9	74.7	81.7	90.2	95.1	95.9	94.4	90.7	83.1	70.5	59.8	(30)	
	5%	WB	54.1	56.9	60.1	62.1	66.2	70.6	73.6	72.5	69.4	64.1	58.5	53.5	(31)	
		MCDB	58.1	63.1	71.3	78.5	86.4	91.9	93.9	92.6	89.8	80.0	67.7	57.6	(32)	
	10%	WB	52.4	54.5	58.0	60.1	64.2	68.6	72.1	71.0	68.0	62.2	56.5	51.3	(33)	
		MCDB	56.6	60.3	68.0	74.9	83.0	89.5	92.2	91.0	88.0	76.7	64.3	55.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	16.7	19.3	23.2	25.7	27.6	30.8	31.0	31.8	31.0	28.1	22.4	17.9	(35)	
		MCDBR	22.4	24.1	29.2	32.5	33.7	34.7	32.5	33.4	34.0	33.3	28.5	22.6	(36)	
	5% WB	MCWBR	15.2	15.5	15.5	14.4	12.8	12.0	11.2	11.7	12.5	14.5	15.8	14.9	(37)	
		MCWBR	17.6	22.0	26.7	30.5	32.0	32.8	30.5	31.9	31.9	29.7	25.1	16.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.366	0.377	0.376	0.386	0.386	0.377	0.402	0.377	0.376	0.395	0.376	0.364	(40)	
		taud	2.284	2.278	2.298	2.295	2.321	2.348	2.310	2.355	2.365	2.256	2.270	2.293	(41)	
	Ebn at Noon		256	270	282	284	285	286	278	284	278	259	250	248	(42)	
		Edh at Noon	32	36	39	41	41	40	41	38	36	36	32	30	(43)	
(44) All-Sky Solar Radiation	RadAvg		776	1123	1602	2034	2402	2676	2550	2352	1966	1433	978	716	(44)	
	RadStd		109	124	132	141	129	87	94	68	55	75	53	95	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.24	N/A	N/A	+0.86	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (21 neighbors)		+1.04	N/A	-1.94	+0.99	N/A	N/A	-52	-257	+351	+137

Nomenclature: See separate page