

POINT PIEDRAS BLANCAS, CA, USA

WMO: 723900

Lat: 35.666N

Lon: 121.285W

Elev: 69

StdP: 14.66

Time Zone: -8.00 (NAP)

Period: 90-05

WBAN: 93226

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	41.7	44.0	26.0	20.0	50.0	29.5	23.6	50.5	37.0	53.3	34.1	52.6	6.6	0	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	9.6	73.0	61.1	69.2	59.3	66.4	58.6	62.4	70.2	61.0	66.9	59.9	65.0	10.6	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.2	75.2	64.1	57.8	71.6	62.9	57.1	69.8	62.1	28.0	70.8	27.1	66.9	26.3	65.2	67.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
31.4	27.9	25.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	55.7	53.7	53.7	53.8	53.4	54.6	55.8	57.5	58.8	58.4	58.8	57.0	53.3
	DBStd	3.95	3.96	3.71	3.22	2.70	2.81	3.49	2.38	2.40	2.68	4.73	3.53	3.33
	HDD50	36	10	8	6	3	1	0	0	0	0	0	0	8
	HDD65	3401	351	316	348	348	322	281	234	193	200	204	241	363
	CDD50	2130	124	112	123	105	144	173	231	272	251	274	211	110
	CDD65	20	0	0	0	0	0	5	0	0	1	13	1	0
	CDH74	53	1	0	0	0	0	11	0	0	3	34	3	1
	CDH80	1	0	0	0	0	0	0	0	0	0	1	0	0
(14) Wind	WSAvg	10.6	8.6	9.7	11.0	12.7	13.0	13.2	10.8	10.8	10.5	9.1	8.5	8.9
(15) Precipitation	PrecAvg	17.6	3.5	3.4	2.6	1.2	0.6	0.1	0.0	0.0	0.1	0.9	1.8	3.3
	PrecMax	30.6	10.8	11.8	9.1	3.8	3.2	1.1	0.3	0.1	0.4	3.9	4.7	7.2
	PrecMin	7.6	0.4	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.2	0.2	0.2
	PrecStd	5.6	2.6	2.5	2.2	0.9	0.7	0.2	0.1	0.0	0.1	1.1	1.1	2.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.3	69.7	65.7	64.0	65.8	75.8	66.9	69.0	70.8	77.3	73.5	68.2
		MCWB	57.9	58.3	58.1	57.0	58.3	63.8	58.9	61.2	60.9	64.0	59.1	57.0
	2%	DB	65.2	63.4	62.9	62.0	63.3	66.5	65.0	66.5	66.7	74.4	68.4	61.4
		MCWB	55.0	56.2	56.4	56.2	57.2	59.1	58.6	59.5	59.4	62.4	56.7	54.3
	5%	DB	61.7	60.9	61.0	60.5	61.5	63.0	63.4	65.0	65.0	70.1	65.2	59.9
		MCWB	54.8	55.0	55.4	55.1	55.9	57.0	57.7	58.7	58.7	60.3	56.8	54.0
	10%	DB	59.5	58.9	59.2	58.9	59.7	61.0	62.0	63.6	63.3	66.3	62.9	58.4
		MCWB	53.8	54.1	54.4	54.0	54.6	55.3	57.0	58.5	57.9	58.8	55.5	53.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.2	60.3	59.2	58.3	60.1	63.9	61.2	62.4	62.6	64.5	61.6	58.5
		MCDB	66.7	67.2	63.5	62.4	64.4	75.1	64.6	66.5	68.1	75.6	66.9	65.2
	2%	WB	57.8	57.9	57.5	56.9	58.1	59.7	59.4	61.0	60.4	62.8	60.0	56.8
		MCDB	62.5	62.6	61.5	61.1	62.1	66.0	63.7	65.2	65.3	72.7	65.1	59.7
	5%	WB	56.4	56.1	56.3	55.5	56.6	57.6	58.4	59.9	59.3	61.0	58.7	55.6
		MCDB	60.2	59.6	59.9	59.6	60.4	62.6	62.6	63.8	63.8	68.7	63.4	58.3
	10%	WB	55.2	54.9	55.1	54.4	55.3	56.0	57.5	59.0	58.5	59.5	57.4	54.7
		MCDB	58.3	57.9	58.2	57.9	58.8	60.0	61.5	62.8	62.8	65.4	61.4	57.4
(35) Mean Daily Temperature Range	5% DB	MDBR	10.9	9.4	9.4	9.4	8.7	8.6	7.5	8.5	8.9	9.6	10.7	10.2
		MCDBR	13.9	12.3	12.0	11.8	11.3	11.7	9.8	11.2	12.0	16.4	14.7	11.8
		MCWBR	10.7	9.5	9.2	8.7	8.5	7.9	6.6	7.4	8.4	9.7	11.2	10.3
	5% WB	MCDBR	11.7	10.0	10.2	11.3	10.7	11.4	9.2	10.1	10.6	14.5	11.4	9.6
		MCWBR	9.7	8.2	8.3	8.6	8.1	7.7	6.4	6.9	7.4	9.4	9.5	9.1
(40) Clear-Sky Solar Irradiance	taub		0.312	0.323	0.333	0.347	0.363	0.339	0.364	0.341	0.350	0.344	0.316	0.317
	taud		2.577	2.553	2.523	2.473	2.443	2.521	2.481	2.534	2.501	2.528	2.567	2.571
	Ebn at Noon		284	293	298	297	292	297	289	295	288	281	279	274
	Edh at Noon		24	28	31	35	36	33	35	32	31	28	24	23
(44) All-Sky Solar Radiation	RadAvg		890	1164	1608	2010	2265	2383	2162	1965	1751	1345	1006	781
	RadStd		80	121	115	150	146	113	104	114	96	91	58	87

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)	+0.85	N/A	N/A	N/A	+0.90	N/A	N/A	N/A	-256	+304	+70

Nomenclature: See separate page