

POINT MUGU NAS, CA, USA

WMO: 723910

Lat: 34.117N

Lon: 119.117W

Elev: 4

StdP: 101.28

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 93111

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	3.9	5.1	-13.1	1.2	17.1	-10.0	1.6	18.3	12.8	17.3	11.7	16.2	2.2	10	0.434

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.9	28.1	16.5	26.3	17.3	24.8	17.4	21.1	24.8	20.3	24.0	19.6	23.1	5.6	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.8	14.5	23.3	18.8	13.6	22.7	17.9	12.9	21.4	61.2	24.2	58.3	24.0	55.7	23.3	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.3	8.5	7.4	DB	1.5	33.4	1.7	2.6	0.4	35.3	-0.6	36.8	-1.6	38.2	-2.8	40.1	(4)
(5)			WB	-0.3	22.3	1.8	1.5	-1.7	23.4	-2.7	24.2	-3.7	25.1	-5.1	26.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.6	13.3	12.8	13.5	13.9	15.1	16.9	18.6	19.0	18.7	17.5	15.3	12.9
	DBStd	3.36	3.39	2.92	2.51	2.30	1.67	1.56	1.72	1.94	2.23	2.62	3.03	2.95
	HDD10.0	17	4	4	2	1	0	0	0	0	0	0	1	5
	HDD18.3	1129	162	157	152	135	101	48	17	15	21	48	101	173
	CDD10.0	2075	108	84	110	118	159	206	266	278	261	231	160	94
	CDD18.3	147	7	3	2	2	1	5	24	34	32	21	11	3
	CDH23.3	717	48	28	23	29	9	12	47	100	139	161	94	27
	CDH26.7	137	10	7	5	6	2	2	3	7	19	48	24	4
Wind	WSAvg	3.1	3.4	3.4	3.3	3.5	3.2	3.0	2.8	2.7	2.6	2.8	3.0	3.3
Precipitation	PrecAvg	285	61	78	54	18	3	1	0	2	3	4	47	46
	PrecMax	522	294	421	185	107	37	7	5	31	22	21	163	135
	PrecMin	88	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	129	66	97	51	26	8	2	1	6	6	6	41	40
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.8	27.7	26.6	27.3	24.1	24.7	26.5	27.5	28.9	32.5	29.9	26.8
		MCWB	13.2	13.7	14.2	14.5	16.9	18.4	20.8	20.8	20.2	14.9	15.0	12.1
	2%	DB	24.1	22.6	22.4	22.8	21.4	22.6	24.6	25.6	26.6	27.6	25.9	22.6
		MCWB	12.1	12.4	13.2	14.6	16.4	17.9	20.0	20.0	20.4	15.6	13.5	11.6
	5%	DB	21.8	20.0	19.9	20.2	20.0	21.5	23.2	24.3	24.9	24.7	23.4	20.1
		MCWB	11.6	12.8	13.7	14.5	15.7	17.3	19.0	19.4	19.7	16.3	13.3	11.6
	10%	DB	19.3	17.8	17.9	18.4	18.9	20.7	22.4	23.1	23.4	22.5	21.1	18.3
		MCWB	11.5	12.5	13.7	14.1	15.2	16.9	18.5	18.8	18.9	16.7	13.7	11.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.3	16.4	16.9	16.9	18.6	19.7	22.4	21.5	22.1	21.2	18.2	16.8
		MCDB	19.3	20.7	20.6	21.7	21.7	22.9	23.9	25.9	26.6	24.8	23.2	19.0
	2%	WB	15.3	15.3	15.7	15.8	17.3	18.6	20.9	20.6	21.1	19.6	16.9	15.6
		MCDB	18.0	18.8	19.2	20.0	19.8	21.5	23.6	24.5	25.3	23.1	21.0	17.9
	5%	WB	14.6	14.5	15.0	15.2	16.5	17.8	19.8	19.9	20.2	18.4	16.1	14.6
		MCDB	17.4	17.6	18.1	18.8	19.1	20.5	23.0	23.7	24.2	22.0	19.8	17.2
	10%	WB	13.8	13.8	14.3	14.5	15.7	17.2	18.9	19.1	19.3	17.6	15.3	13.7
		MCDB	16.8	16.7	17.1	17.8	18.3	19.8	22.0	22.7	23.0	20.8	18.8	16.5
Mean Daily Temperature Range	5% DB	MDBR	10.0	9.3	8.8	9.0	7.8	7.3	7.3	7.9	8.5	9.6	10.7	10.4
		MCDBR	13.4	13.1	12.7	12.6	9.6	8.8	8.4	9.2	10.5	13.9	14.4	13.0
		MCWBR	6.8	7.1	7.2	7.1	5.7	5.2	4.6	5.1	5.7	7.3	7.6	7.4
	5% WB	MCDBR	9.8	9.4	9.0	10.1	8.5	7.9	7.7	8.7	9.6	10.0	10.9	9.7
		MCWBR	7.0	6.4	6.3	6.5	5.4	4.9	4.6	5.0	5.6	6.9	7.7	7.0
Clear-Sky Solar Irradiance	taub	0.309	0.320	0.334	0.375	0.394	0.390	0.418	0.387	0.381	0.360	0.314	0.316	
	taud	2.579	2.566	2.518	2.387	2.355	2.376	2.352	2.412	2.429	2.477	2.590	2.576	
	Ebn at Noon	909	934	943	912	892	891	864	889	880	874	896	879	
	Edh at Noon	78	88	100	119	125	122	124	115	108	95	77	75	
All-Sky Solar Radiation	RadAvg	3.12	4.00	5.34	6.61	7.17	7.41	7.32	6.93	5.92	4.52	3.50	2.83	
	RadStd	0.23	0.40	0.34	0.38	0.53	0.40	0.36	0.27	0.25	0.36	0.21	0.22	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (48 neighbors)	+0.63	N/A	-1.70	+0.70	N/A	N/A	N/A	-128	+233	+96

Nomenclature: See separate page