

CAMARILLO, CA, USA

WMO: 723926

Lat: 34.217N

Lon: 119.083W

Elev: 77

StdP: 14.66

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23136

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	37.7	40.0	5.6	7.3	65.5	11.3	9.8	64.1	33.6	63.0	30.2	64.5	2.7	70	0.409

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.7	87.8	63.0	83.7	62.9	80.9	63.4	69.6	80.1	68.4	78.5	67.2	76.9	12.9	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.8	95.4	75.5	64.2	90.0	73.0	63.3	87.2	71.6	33.7	80.4	32.6	78.7	31.7	76.9	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.9	20.0	16.3	DB	33.7	97.9	2.0	4.1	32.3	100.9	31.1	103.3	30.0	105.6	28.5	108.6	(4)
(5)			WB	29.5	71.9	2.2	1.8	27.9	73.2	26.6	74.2	25.4	75.2	23.8	76.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.7	56.0	55.6	57.5	59.0	61.7	64.9	68.3	68.8	68.1	64.8	59.9	55.3
	DBStd	6.81	6.05	5.36	4.64	4.62	3.79	3.09	3.41	3.34	4.28	5.36	5.78	5.25
	HDD50	28	8	7	2	1	0	0	0	0	0	0	1	9
	HDD65	1717	290	270	240	191	119	37	7	5	12	66	175	305
	CDD50	4294	195	163	234	270	361	447	568	582	543	459	299	173
	CDD65	508	12	6	6	10	15	34	109	122	105	61	23	5
	CDH74	3498	120	106	128	186	157	139	449	580	642	631	297	63
	CDH80	889	21	28	37	57	52	22	56	95	172	247	94	8
Wind	WSAvg	5.8	6.9	6.6	6.1	6.3	5.8	5.3	5.1	4.8	4.7	5.5	6.0	6.9
Precipitation	PrecAvg	15.0	3.5	3.9	2.4	0.7	0.4	0.1	0.0	0.0	0.1	0.5	1.1	2.2
	PrecMax	30.0	16.6	17.7	8.2	3.5	2.0	0.8	0.4	0.1	0.7	3.6	3.8	9.5
	PrecMin	4.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	6.9	3.5	3.7	2.1	0.8	0.5	0.2	0.1	0.0	0.1	0.8	0.9	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.8	84.4	84.9	87.8	86.1	83.4	85.0	87.3	90.5	94.7	89.6	80.9
		MCWB	54.8	56.5	57.6	59.8	60.5	67.0	69.2	69.1	67.4	61.3	59.8	54.7
	2%	DB	77.2	76.5	77.0	79.2	77.4	77.6	81.1	82.2	84.3	86.6	81.8	74.6
		MCWB	52.9	54.5	55.8	57.9	61.6	64.7	67.7	68.0	67.2	60.0	57.1	52.9
	5%	DB	72.6	70.6	71.6	73.3	73.0	74.7	78.8	79.5	80.8	80.5	76.4	69.9
		MCWB	52.6	53.4	55.7	57.2	60.7	63.8	67.0	67.2	66.4	60.4	55.6	52.2
	10%	DB	67.7	65.6	67.4	69.3	70.1	72.4	76.2	77.0	77.1	75.5	71.4	65.9
		MCWB	51.4	53.3	55.9	56.7	59.9	62.7	66.1	66.1	65.3	60.2	55.5	51.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.5	60.6	62.1	62.7	66.1	68.2	71.5	70.9	71.4	68.8	64.2	61.4
		MCDB	68.6	69.8	74.2	77.1	78.4	80.0	80.7	83.2	83.2	79.6	76.2	68.0
	2%	WB	58.7	58.8	59.9	60.5	63.7	66.1	69.3	69.2	69.3	66.3	62.0	59.2
		MCDB	65.2	67.0	69.7	72.0	73.9	75.9	78.3	80.1	79.9	76.6	72.0	65.1
	5%	WB	57.2	57.3	58.5	59.2	62.0	64.7	68.0	68.0	67.7	64.5	60.3	57.4
		MCDB	63.4	65.0	67.0	69.6	70.9	73.3	77.0	77.9	77.9	73.8	69.1	63.1
	10%	WB	55.7	55.9	57.2	57.8	60.4	63.3	66.5	66.7	66.3	62.9	58.9	55.5
		MCDB	62.9	62.8	64.6	66.8	68.3	71.2	75.2	75.9	75.6	71.6	67.0	61.6
Mean Daily Temperature Range	5% DB	MDBR	20.3	19.7	19.3	19.5	16.7	15.1	15.6	16.7	17.8	20.1	21.8	21.0
		MCDBR	27.3	28.4	28.6	28.5	23.1	19.0	18.4	20.3	23.2	29.9	30.0	26.7
		MCWBR	12.8	14.0	14.4	13.6	11.7	9.8	8.6	9.9	11.0	13.7	14.4	14.0
	5% WB	MCDBR	18.8	20.5	20.4	21.4	18.7	16.9	16.6	18.1	19.4	21.1	22.2	19.3
		MCWBR	12.0	12.1	12.1	11.5	10.1	9.1	8.3	9.5	9.7	12.0	13.9	13.0
Clear-Sky Solar Irradiance	taub		0.311	0.323	0.337	0.380	0.400	0.396	0.425	0.392	0.386	0.365	0.317	0.319
	taud		2.562	2.547	2.496	2.362	2.328	2.353	2.324	2.392	2.405	2.447	2.573	2.557
	Ebn at Noon		287	295	298	288	281	281	272	280	278	275	283	277
	Edh at Noon		25	29	32	39	41	40	41	37	35	31	25	24
All-Sky Solar Radiation	RadAvg		986	1264	1696	2101	2300	2404	2367	2237	1902	1446	1112	898
	RadStd		74	132	108	118	159	124	110	77	71	107	64	70

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.62	+1.30	-4.32	+2.47	N/A	N/A	N/A	-454	+693	+319
(47)	Regional (47 neighbors)	+1.13	N/A	-3.06	+1.26	N/A	N/A	N/A	-230	+419	+173

Nomenclature: See separate page