

OXNARD, CA, USA

WMO: 723927

Lat: 34.201N

Lon: 119.207W

Elev: 11

StdP: 101.19

Time Zone: -8.00 (NAP)

Period: 98-19

WBAN: 93110

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	4.9	6.1	-13.4	1.2	17.5	-10.2	1.6	16.4	12.7	16.3	11.6	16.9	2.6	50	0.437

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.9	28.0	15.6	26.0	15.9	24.2	16.6	20.4	24.1	19.6	23.1	18.9	22.3	5.5	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	13.8	22.7	18.0	12.9	21.4	17.4	12.5	20.5	58.8	24.0	56.0	23.2	53.6	22.3	23.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.7	8.6	7.5	DB	2.5	34.0	1.2	3.1	1.7	36.2	1.0	38.0	0.3	39.7	-0.6	41.9	(4)
(5)			WB	-0.2	21.0	1.2	1.1	-1.0	21.7	-1.7	22.4	-2.3	23.0	-3.1	23.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.9	13.5	13.1	13.8	14.4	15.7	17.3	19.0	19.0	18.8	17.5	15.2	13.1	(6)
	DBStd	3.23	3.15	2.77	2.42	2.24	1.70	1.27	1.66	1.54	2.18	2.67	2.79	2.68	(7)
	HDD10.0	11	3	3	1	1	0	0	0	0	0	0	0	4	(8)
	HDD18.3	1047	154	150	144	122	84	36	11	11	18	49	102	164	(9)
	CDD10.0	2153	112	88	118	131	177	219	279	278	263	232	157	99	(10)
	CDD18.3	149	5	3	3	3	3	5	32	30	31	23	9	2	(11)
	CDH23.3	609	45	30	29	30	29	7	38	38	102	169	74	17	(12)
	CDH26.7	147	7	7	7	9	11	1	2	2	22	57	19	2	(13)
(14) Wind	WSAvg	3.0	3.1	3.2	3.2	3.4	3.2	2.9	3.0	2.9	2.7	2.7	2.9	3.2	(14)
(15) Precipitation	PrecAvg	381	89	98	62	19	9	2	1	0	3	13	29	57	(15)
	PrecMax	761	422	450	209	88	52	20	10	2	18	92	96	241	(16)
	PrecMin	119	0	0	0	1	0	0	0	0	0	0	0	0	(17)
	PrecStd	174	88	94	54	20	13	4	2	1	3	20	24	57	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.6	27.6	27.0	27.0	27.0	23.8	26.2	26.6	29.1	32.6	29.3	25.8	(19)
		MCWB	12.7	13.2	13.7	14.4	14.4	18.0	20.2	20.0	19.3	15.3	14.3	11.8	(20)
	2%	DB	24.1	22.7	22.6	22.6	21.8	22.1	24.1	24.2	25.9	27.5	25.3	22.1	(21)
		MCWB	11.4	11.7	12.7	13.8	15.6	17.3	19.4	19.2	19.4	15.4	13.2	11.5	(22)
	5%	DB	21.3	19.8	19.6	20.0	19.9	21.1	23.0	23.0	23.9	24.5	22.4	19.4	(23)
		MCWB	11.3	12.0	13.0	13.5	15.0	16.7	18.7	18.6	18.7	15.8	12.8	11.3	(24)
	10%	DB	18.8	17.5	17.8	18.2	18.9	20.1	22.2	22.3	22.6	22.2	20.1	17.7	(25)
		MCWB	11.0	11.8	13.0	13.5	14.7	16.1	18.2	18.2	18.2	15.9	13.2	11.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.5	15.7	15.9	16.2	17.4	18.8	21.1	20.8	21.6	20.7	17.3	16.3	(27)
		MCDB	18.8	19.0	20.4	21.5	20.8	22.8	24.6	24.8	25.5	24.8	21.9	19.1	(28)
	2%	WB	14.7	14.7	15.1	15.2	16.5	17.9	20.1	19.8	20.5	18.9	16.3	15.0	(29)
		MCDB	17.8	17.9	18.8	19.6	19.6	21.0	23.5	23.4	24.0	22.8	20.1	17.6	(30)
	5%	WB	14.0	14.0	14.5	14.6	15.8	17.2	19.2	19.1	19.4	17.9	15.6	14.0	(31)
		MCDB	17.3	17.2	17.8	18.5	18.8	20.0	22.3	22.4	23.0	21.4	19.1	16.5	(32)
	10%	WB	13.2	13.2	13.8	14.0	15.2	16.7	18.6	18.5	18.7	17.1	14.9	13.2	(33)
		MCDB	16.4	16.3	16.9	17.5	18.2	19.4	21.6	21.6	22.1	20.4	18.3	15.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.5	8.8	8.2	8.0	6.8	5.8	5.9	6.3	7.1	8.6	9.6	9.4	(35)
		MCDBR	13.4	12.8	12.1	11.5	8.8	7.0	6.9	7.3	9.0	13.4	13.5	11.9	(36)
	5% WB	MCWBR	6.6	6.7	6.5	6.1	4.6	3.8	3.4	3.7	5.0	7.1	7.5	7.0	(37)
		MCWBR	8.9	9.0	8.7	8.8	7.3	6.3	6.5	7.0	7.6	9.3	9.8	8.7	(38)
(40) Clear-Sky Solar Irradiance	taub		0.308	0.319	0.331	0.376	0.397	0.390	0.420	0.388	0.382	0.359	0.313	0.315	(40)
		taud	2.578	2.566	2.522	2.381	2.343	2.374	2.342	2.405	2.422	2.472	2.588	2.573	(41)
	Ebn at Noon		910	935	945	911	890	892	863	888	879	874	896	879	(42)
		Edh at Noon	78	88	99	120	126	122	125	116	109	95	77	75	(43)
(44) All-Sky Solar Radiation	RadAvg		3.11	3.98	5.34	6.62	7.23	7.52	7.40	6.99	5.96	4.54	3.50	2.83	(44)
	RadStd		0.23	0.41	0.34	0.38	0.51	0.38	0.35	0.26	0.23	0.35	0.20	0.22	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.81	N/A	-2.66	+1.81	+0.80	N/A	N/A	-230	+316	+94	(46)
(47)	Regional (45 neighbors)	+0.64	N/A	-1.74	+0.67	N/A	N/A	N/A	-128	+234	+95	(47)

Nomenclature: See separate page