

PASO ROBLES, CA, USA

WMO: 723965

Lat: 35.670N

Lon: 120.628W

Elev: 247

StdP: 98.39

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 93209

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-2.7	-1.3	-8.8	1.8	9.6	-6.6	2.2	8.8	9.5	12.4	8.5	11.9	0.8	80	0.523

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.7	39.0	19.2	37.2	18.8	35.2	18.1	20.7	35.3	19.8	34.2	19.0	33.0	3.9	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.5	11.4	22.6	14.4	10.5	21.8	13.6	10.0	21.1	60.7	35.4	57.1	34.3	54.4	33.0	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.3	8.5	7.8	-5.3	42.7	2.0	1.6	-6.7	43.8	-7.9	44.7	-9.0	45.6	-10.4	46.7		
(5)			-6.1	22.9	2.0	1.8	-7.6	24.2	-8.7	25.3	-9.8	26.3	-11.3	27.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.9	9.4	10.3	12.4	14.2	17.7	21.0	23.4	23.3	21.3	16.9	12.0	8.7		
	DBStd	6.07	2.73	2.82	2.96	3.39	3.41	3.33	3.10	2.85	3.17	3.19	3.21	2.84		
	HDD10.0	163	43	29	11	5	0	0	0	0	0	0	16	59		
	HDD18.3	1451	277	226	186	129	54	12	1	1	9	67	191	298		
	CDD10.0	2318	25	36	84	131	239	329	414	412	339	213	76	18		
	CDD18.3	564	0	0	1	6	34	91	158	155	98	21	1	0		
	CDH23.3	9075	4	9	79	272	760	1515	2166	2115	1497	586	73	1		
	CDH26.7	4942	1	0	16	97	360	845	1276	1258	828	246	15	0		
(14) Wind	WSAvg	2.9	2.1	2.4	2.7	3.3	3.9	4.0	3.6	3.2	2.8	2.3	2.0	2.1		
(15) Precipitation	PrecAvg	316	65	69	55	22	3	0	1	1	4	11	36	47		
	PrecMax	621	310	224	229	115	43	3	8	23	34	62	133	172		
	PrecMin	121	0	0	0	0	0	0	0	0	0	0	0	0		
	PrecStd	123	62	67	47	26	8	1	2	4	8	14	33	38		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.0	24.8	28.7	33.1	37.2	40.1	41.4	41.3	39.5	35.5	28.7	21.9		
		MCWB	11.4	14.3	15.9	16.2	18.4	19.6	20.4	20.5	19.2	17.7	14.6	10.9		
	2%	DB	20.1	21.8	25.5	29.5	33.8	37.2	38.6	38.6	37.0	32.0	25.5	19.0		
		MCWB	11.6	13.4	14.8	15.6	17.2	18.5	19.4	19.0	18.4	16.1	13.9	11.0		
	5%	DB	17.6	18.9	22.8	26.5	30.8	34.7	36.4	36.4	34.6	29.4	22.4	17.0		
		MCWB	11.5	12.2	13.6	14.7	16.1	17.8	18.8	18.5	17.6	15.3	12.9	11.1		
	10%	DB	15.4	16.5	20.2	23.5	27.7	32.0	34.0	33.8	31.9	26.7	19.6	14.9		
		MCWB	10.9	11.4	12.8	13.5	15.3	17.0	18.1	17.9	17.2	14.7	12.1	10.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.4	16.0	17.5	18.3	19.8	21.6	22.0	22.0	21.4	19.3	16.3	15.3		
		MCDB	17.9	21.1	25.7	28.8	34.5	37.4	38.6	37.6	33.4	30.2	23.6	18.0		
	2%	WB	13.7	14.5	15.7	16.4	18.2	19.8	20.5	20.3	19.7	17.6	15.2	13.8		
		MCDB	16.7	19.0	23.4	26.8	31.7	34.3	35.4	35.7	32.3	28.5	22.1	16.0		
	5%	WB	12.6	13.3	14.5	15.2	16.9	18.6	19.6	19.3	18.6	16.4	14.1	12.5		
		MCDB	15.6	17.4	21.3	25.0	29.0	32.5	34.2	34.3	32.3	26.2	20.0	14.8		
	10%	WB	11.5	12.0	13.2	14.0	15.7	17.5	18.6	18.4	17.6	15.3	13.0	11.2		
		MCDB	14.6	15.7	19.0	22.5	26.2	30.4	32.7	32.3	30.6	24.7	18.3	13.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.5	13.1	15.0	16.9	18.2	20.3	20.7	21.2	20.8	19.1	16.1	13.6		
		MCDBR	17.9	18.2	20.1	22.5	23.9	24.9	24.5	25.1	25.0	24.0	21.1	17.2		
		MCWBR	10.6	10.4	10.4	10.4	9.7	9.3	8.7	8.9	9.8	10.6	10.7	10.4		
	5% WB	MCDBR	12.5	14.5	17.7	20.2	21.8	22.6	22.2	22.9	22.1	20.7	16.9	11.0		
		MCWBR	8.2	8.8	9.6	9.9	9.4	9.3	8.5	8.9	9.1	9.6	9.3	7.6		
(40) Clear-Sky Solar Irradiance	taub		0.301	0.314	0.320	0.337	0.354	0.340	0.362	0.339	0.345	0.335	0.308	0.305		
	taud		2.554	2.524	2.509	2.457	2.418	2.464	2.430	2.474	2.461	2.491	2.540	2.552		
	Ebn at Noon		908	933	953	946	928	937	914	932	912	893	890	878		
	Edh at Noon		78	90	99	110	117	111	114	107	103	92	78	74		
(44) All-Sky Solar Radiation	RadAvg		2.82	3.71	5.17	6.52	7.59	8.22	7.81	7.17	6.06	4.50	3.25	2.51		
	RadStd		0.26	0.41	0.40	0.47	0.38	0.28	0.23	0.19	0.18	0.25	0.17	0.26		

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	-2.04	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (29 neighbors)		+0.50	N/A	-0.97	+0.54	N/A	N/A	N/A	-148	+177	+42

Nomenclature: See separate page