

SALISBURY, MD, USA

WMO: 723980

Lat: 38.341N

Lon: 75.513W

Elev: 47

StdP: 14.67

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 93720

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.9	18.5	-0.7	5.3	17.8	4.2	6.8	21.8	26.9	40.0	24.5	36.7	5.8	330	0.469

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.3	93.1	76.1	90.6	75.4	88.3	74.4	79.1	88.1	77.9	86.4	76.8	84.6	9.6	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.8	139.6	82.7	75.4	133.3	81.4	74.5	129.3	80.7	42.5	88.0	41.2	86.2	40.1	84.7	86.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.5	19.1	17.2	DB	6.5	97.0	5.5	2.7	2.6	98.9	-0.6	100.5	-3.7	102.1	-7.7	104.0	
			WB	5.4	81.4	5.3	1.7	1.6	82.6	-1.5	83.6	-4.5	84.5	-8.3	85.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	56.9	36.3	38.5	45.1	55.3	63.8	72.8	77.5	75.6	69.6	58.6	48.0	40.8
	DBStd	16.53	10.95	9.69	9.31	8.72	7.98	6.51	5.39	4.85	6.29	8.30	8.65	9.40
	HDD50	1511	444	341	211	41	2	0	0	0	0	16	139	317
	HDD65	4225	889	743	618	313	124	14	1	0	27	234	511	751
	CDD50	4038	20	19	59	200	430	683	851	793	587	284	80	32
	CDD65	1275	0	0	1	22	87	247	387	328	163	37	2	1
	CDH74	11905	0	1	16	225	813	2355	3980	3008	1247	252	7	1
	CDH80	4361	0	0	1	51	229	881	1708	1098	341	52	0	0
Wind	WSAvg	7.1	8.2	8.4	8.9	8.7	7.2	6.5	5.8	5.3	5.9	6.3	6.9	7.2
Precipitation	PrecAvg	45.3	3.7	3.3	4.4	3.3	3.5	3.6	4.4	5.3	3.9	3.3	3.1	3.7
	PrecMax	69.6	8.6	6.9	9.1	6.3	7.0	9.3	10.4	12.4	9.4	9.1	7.0	8.3
	PrecMin	33.9	0.5	1.0	0.6	0.6	0.3	0.4	0.9	0.4	0.5	0.1	0.1	0.7
	PrecStd	7.6	1.9	1.6	2.0	1.3	1.9	1.9	2.2	3.1	2.3	2.3	1.8	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.1	70.1	76.8	85.5	89.8	95.0	97.6	94.9	90.9	85.4	74.3	70.3
		MCWB	61.3	61.1	61.8	68.7	72.9	75.9	77.3	77.3	74.8	71.2	63.9	63.7
	2%	DB	63.8	64.4	71.1	80.7	85.7	90.9	93.8	91.3	87.2	80.5	70.5	65.9
		MCWB	59.0	56.3	59.4	65.2	70.5	74.7	76.7	76.4	73.2	69.5	62.7	61.6
	5%	DB	59.5	59.7	66.0	75.4	82.2	88.1	91.3	88.6	84.0	76.1	67.2	61.4
		MCWB	54.6	53.1	57.1	63.4	69.4	73.7	75.9	75.2	72.2	67.3	61.1	57.4
	10%	DB	54.3	55.0	61.7	71.2	78.8	85.4	88.8	86.0	81.1	72.8	63.4	56.8
		MCWB	49.6	48.6	54.1	60.7	67.3	72.5	75.3	74.1	70.5	65.0	58.0	52.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.9	63.3	64.6	71.0	75.3	78.3	81.1	80.3	78.3	75.3	68.0	65.9
		MCDB	66.3	67.2	73.1	81.0	84.3	88.8	91.2	89.0	85.0	80.0	70.9	69.1
	2%	WB	59.9	58.6	61.9	67.7	73.0	77.0	79.5	78.7	76.3	72.3	65.3	62.1
		MCDB	63.3	63.0	67.9	76.7	82.0	86.8	89.1	86.9	82.2	77.8	69.1	65.1
	5%	WB	55.5	54.6	58.9	65.2	71.2	75.9	78.3	77.5	75.1	69.7	62.3	57.9
		MCDB	59.1	58.5	64.7	73.2	79.4	84.7	87.2	85.0	80.1	74.4	65.7	60.7
	10%	WB	50.2	49.5	55.2	62.5	69.3	74.6	77.2	76.3	73.5	66.9	58.7	53.4
		MCDB	53.6	54.0	60.7	69.3	77.0	82.3	85.5	83.1	78.2	71.0	62.6	56.1
Mean Daily Temperature Range	5% DB	MDBR	17.7	19.0	20.2	22.0	21.1	19.9	19.3	19.2	19.7	21.3	20.7	18.4
		MCDBR	22.8	24.7	26.6	26.7	24.0	22.4	21.4	20.8	22.0	23.7	23.8	21.8
		MCWBR	18.7	18.8	17.0	14.5	12.0	9.4	8.0	8.7	10.4	13.5	16.4	18.5
	5% WB	MCDBR	21.7	22.9	23.1	22.5	21.4	19.6	18.6	17.7	16.5	19.0	19.4	20.0
		MCWBR	19.1	19.8	17.5	14.0	11.5	9.0	7.8	8.3	8.9	12.2	15.8	18.4
Clear-Sky Solar Irradiance	taub	0.316	0.320	0.355	0.393	0.441	0.483	0.508	0.502	0.408	0.360	0.327	0.315	
	taud	2.481	2.464	2.408	2.317	2.216	2.147	2.094	2.096	2.340	2.472	2.515	2.520	
	Ebn at Noon	274	288	287	281	268	256	248	246	266	270	268	266	
	Edh at Noon	25	29	34	40	45	48	50	49	36	29	24	23	
All-Sky Solar Radiation	RadAvg	694	955	1282	1634	1849	2020	1953	1751	1428	1081	781	610	
	RadStd	60	98	107	115	197	150	94	109	140	111	69	56	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.97	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+286	N/A
(47)	Regional (73 neighbors)	+0.85	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+268	+166

Nomenclature: See separate page