

SALISBURY, MD, USA

WMO: 723980

Lat: 38.341N

Lon: 75.513W

Elev: 14

StdP: 101.15

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 93720

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.0	-7.5	-18.1	0.8	-7.9	-15.4	1.0	-5.7	12.0	4.4	11.0	2.6	2.6	330	0.469

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.7	33.9	24.5	32.6	24.1	31.3	23.6	26.1	31.2	25.5	30.2	24.9	29.2	4.3	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.9	19.9	28.1	24.1	19.0	27.5	23.6	18.5	27.0	81.0	31.1	78.0	30.1	75.4	29.3	30.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.1	8.5	7.7	-14.1	36.1	3.0	1.5	-16.3	37.2	-18.1	38.1	-19.8	38.9	-22.1	40.0		
(5)			-14.8	27.4	2.9	0.9	-16.9	28.1	-18.6	28.6	-20.3	29.2	-22.4	29.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.8	2.4	3.6	7.3	12.9	17.7	22.7	25.3	24.2	20.9	14.8	8.9	4.9		
	DBStd	9.18	6.08	5.39	5.17	4.84	4.43	3.62	2.99	2.69	3.50	4.61	4.81	5.22		
	HDD10.0	839	247	189	117	23	1	0	0	0	0	9	77	176		
	HDD18.3	2347	494	413	343	174	69	8	1	0	15	130	284	417		
	CDD10.0	2243	11	11	33	111	239	379	473	441	326	158	44	18		
	CDD18.3	708	0	0	1	12	48	137	215	182	91	21	1	1		
	CDH23.3	6614	0	1	9	125	452	1308	2211	1671	693	140	4	1		
	CDH26.7	2423	0	0	1	28	127	489	949	610	189	29	0	0		
(14) Wind	WSAvg	3.2	3.7	3.8	4.0	3.9	3.2	2.9	2.6	2.4	2.6	2.8	3.1	3.2		
(15) Precipitation	PrecAvg	1151	94	85	111	85	88	92	112	135	99	84	79	95		
	PrecMax	1769	218	176	231	160	177	236	265	314	240	232	177	212		
	PrecMin	861	12	26	16	14	8	10	23	9	13	3	2	18		
	PrecStd	193	47	40	51	33	48	47	56	78	59	58	45	49		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.1	21.2	24.9	29.7	32.1	35.0	36.5	34.9	32.7	29.7	23.5	21.3		
		MCWB	16.3	16.2	16.5	20.4	22.7	24.4	25.2	25.2	23.8	21.8	17.7	17.6		
	2%	DB	17.7	18.0	21.7	27.1	29.8	32.7	34.3	32.9	30.7	27.0	21.4	18.9		
		MCWB	15.0	13.5	15.2	18.4	21.4	23.7	24.8	24.7	22.9	20.9	17.1	16.5		
	5%	DB	15.3	15.4	18.9	24.1	27.9	31.2	32.9	31.5	28.9	24.5	19.6	16.4		
		MCWB	12.6	11.7	13.9	17.4	20.8	23.2	24.4	24.0	22.4	19.6	16.2	14.1		
	10%	DB	12.4	12.8	16.5	21.8	26.0	29.7	31.6	30.0	27.3	22.7	17.4	13.8		
		MCWB	9.8	9.2	12.3	15.9	19.6	22.5	24.0	23.4	21.4	18.3	14.4	11.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.7	17.4	18.1	21.7	24.0	25.7	27.3	26.9	25.7	24.1	20.0	18.8		
		MCDB	19.1	19.5	22.8	27.2	29.1	31.6	32.9	31.6	29.5	26.6	21.6	20.6		
	2%	WB	15.5	14.8	16.6	19.8	22.8	25.0	26.4	25.9	24.6	22.4	18.5	16.7		
		MCDB	17.4	17.2	19.9	24.9	27.8	30.5	31.7	30.5	27.9	25.4	20.6	18.4		
	5%	WB	13.1	12.6	14.9	18.4	21.8	24.4	25.7	25.3	23.9	20.9	16.8	14.4		
		MCDB	15.1	14.7	18.2	22.9	26.4	29.3	30.7	29.4	26.7	23.6	18.7	16.0		
	10%	WB	10.1	9.7	12.9	17.0	20.7	23.7	25.1	24.6	23.0	19.4	14.8	11.9		
		MCDB	12.0	12.2	16.0	20.7	25.0	28.0	29.7	28.4	25.7	21.7	17.0	13.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.9	10.6	11.2	12.2	11.7	11.1	10.7	10.7	10.9	11.8	11.5	10.2		
		MCDBR	12.7	13.7	14.8	14.8	13.3	12.4	11.9	11.6	12.2	13.1	13.2	12.1		
	5% WB	MCWBR	10.4	10.5	9.4	8.0	6.7	5.2	4.5	4.8	5.8	7.5	9.1	10.3		
		MCWBR	12.1	12.7	12.9	12.5	11.9	10.9	10.4	9.8	9.2	10.5	10.8	11.1		
(40) Clear-Sky Solar Irradiance	taub		0.316	0.320	0.355	0.393	0.441	0.483	0.508	0.502	0.408	0.360	0.327	0.315		
	taud		2.481	2.464	2.408	2.317	2.216	2.147	2.094	2.096	2.340	2.472	2.515	2.520		
	Ebn at Noon		865	909	905	885	845	807	782	776	838	852	845	840		
	Edh at Noon		80	92	108	126	142	152	159	155	115	91	77	73		
(44) All-Sky Solar Radiation	RadAvg		2.19	3.01	4.04	5.15	5.83	6.37	6.16	5.52	4.50	3.41	2.46	1.92		
	RadStd		0.19	0.31	0.34	0.36	0.62	0.47	0.29	0.34	0.44	0.35	0.22	0.18		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.54	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+159	N/A
(47) Regional (73 neighbors)		+0.47	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+149	+92

Nomenclature: See separate page