

ACCOMACK COUNTY AP, VA, USA

WMO: 724026

Lat: 37.647N

Lon: 75.761W

Elev: 47

StdP: 14.67

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 03716

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.1	23.2	0.7	5.7	26.2	7.1	7.9	26.5	28.1	36.3	25.5	35.0	8.6	0	0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.7	93.1	78.2	90.9	77.4	89.5	76.8	81.4	88.2	80.0	86.9	78.5	85.5	7.8	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.4	153.0	84.4	78.6	148.9	84.0	76.5	138.6	82.6	44.9	87.4	43.4	85.5	42.1	86.5	94.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.3	19.6	17.3	13.5	97.8	4.1	3.0	10.5	100.0	8.1	101.7	5.8	103.4	2.8	105.6		
			DB													
			WB	11.6	83.8	4.4	3.7	8.4	86.5	5.8	88.7	3.3	90.8	0.1	93.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	59.2	39.6	41.3	47.2	56.9	66.2	74.7	79.2	77.0	71.2	61.4	50.6	43.5
	DBStd	16.04	10.19	9.44	9.10	8.82	7.75	6.41	5.15	5.06	5.95	8.16	8.60	9.14
	HDD50	1169	352	272	167	29	0	0	0	0	0	6	96	247
	HDD65	3655	787	663	556	273	81	7	0	0	15	168	438	667
	CDD50	4512	30	29	79	236	503	740	904	836	635	361	113	46
	CDD65	1525	0	1	3	30	119	297	439	371	201	58	5	1
	CDH74	13915	0	2	18	209	913	2735	4714	3579	1394	339	9	3
	CDH80	4940	0	0	1	47	257	1000	1974	1280	319	62	0	0
(14) Wind	WSAvg	7.2	8.5	8.7	9.0	8.7	7.4	6.3	5.6	5.0	5.8	6.7	7.4	7.6
(15) Precipitation	PrecAvg	44.9	3.3	3.0	4.4	3.5	3.6	3.9	4.7	4.9	4.3	3.7	3.0	4.0
	PrecMax	60.7	7.0	7.8	9.8	5.1	7.0	8.4	12.0	10.1	12.9	6.9	8.1	8.1
	PrecMin	36.0	1.4	0.4	0.5	0.9	0.8	1.5	0.7	1.9	0.6	0.1	0.2	1.7
	PrecStd	6.7	1.3	1.7	2.0	1.2	1.5	1.7	2.6	2.5	3.0	2.0	2.0	1.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.6	71.6	77.0	85.2	90.5	96.6	97.4	94.8	90.0	85.6	74.9	72.4
		MCWB	61.3	63.1	64.0	70.9	73.9	78.0	79.7	79.6	76.4	72.9	65.2	64.2
	2%	DB	63.8	65.5	71.8	80.5	86.2	91.3	93.4	91.3	86.2	81.4	71.7	66.2
		MCWB	58.7	58.7	60.9	67.1	71.8	76.1	78.6	78.6	75.6	71.3	64.7	61.1
	5%	DB	60.8	61.0	66.0	75.0	82.1	89.5	91.2	89.8	83.7	78.1	67.7	63.0
		MCWB	56.5	54.6	58.1	64.9	70.8	75.4	77.9	78.2	74.4	70.2	62.3	58.4
	10%	DB	55.4	56.5	62.8	71.7	79.3	85.7	89.8	86.8	81.4	74.5	64.1	58.7
		MCWB	51.1	50.6	55.8	62.7	69.0	74.0	77.4	76.4	72.7	68.0	59.6	54.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.4	64.6	66.3	73.5	77.8	80.9	84.0	83.4	79.4	76.8	68.5	66.6
		MCDB	65.6	69.2	73.7	81.0	85.4	90.9	92.2	90.7	83.4	80.5	72.0	70.0
	2%	WB	60.2	59.8	63.0	69.4	74.6	78.7	81.7	81.3	77.7	74.4	65.9	62.9
		MCDB	63.3	63.9	68.2	76.9	82.0	87.5	89.2	87.0	83.5	78.7	69.4	64.8
	5%	WB	57.0	55.9	59.9	66.5	72.7	77.4	80.3	79.8	76.2	72.2	63.5	59.2
		MCDB	60.2	59.3	65.3	72.9	80.1	85.4	88.0	85.6	81.6	75.8	65.7	62.3
	10%	WB	52.7	51.3	56.2	63.8	70.6	76.0	78.8	78.3	74.8	69.2	60.9	55.0
		MCDB	55.5	55.5	61.3	68.8	77.6	83.1	86.6	84.5	79.6	73.6	64.0	57.9
(35) Mean Daily Temperature Range	5% DB	MDBR	15.1	16.5	16.9	18.3	18.0	17.2	16.7	16.8	16.6	17.8	17.4	15.8
		MCDBR	19.0	21.9	22.6	22.1	20.6	19.7	18.5	18.0	17.6	19.5	19.4	18.7
		MCWBR	15.6	16.6	15.1	12.4	10.2	8.0	7.6	7.9	8.8	11.0	13.7	16.4
		MCDBR	18.3	20.4	20.1	20.2	18.3	16.8	16.8	15.4	14.9	15.1	16.9	17.8
	5% WB	MCWBR	16.4	17.5	16.0	13.2	10.5	7.6	7.9	7.5	8.3	10.2	14.5	17.1
(40) Clear-Sky Solar Irradiance	taub		0.314	0.321	0.350	0.391	0.435	0.480	0.511	0.503	0.409	0.359	0.327	0.316
	taud		2.530	2.501	2.456	2.350	2.263	2.186	2.116	2.123	2.373	2.513	2.548	2.555
	Ebn at Noon		278	290	290	282	270	257	248	246	266	272	271	269
	Edh at Noon		25	29	33	39	43	46	49	48	36	28	24	23
(44) All-Sky Solar Radiation	RadAvg		710	965	1306	1662	1878	2044	1964	1774	1442	1113	806	628
	RadStd		59	99	104	114	179	140	93	101	124	113	67	52

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (68 neighbors)	+0.85	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+281	+180

Nomenclature: See separate page