

ACCOMACK COUNTY AP, VA, USA

WMO: 724026

Lat: 37.647N

Lon: 75.761W

Elev: 14

StdP: 101.15

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 03716

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.2	-4.9	-17.4	0.8	-3.2	-13.8	1.1	-3.1	12.6	2.4	11.4	1.7	3.9	0	0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.3	33.9	25.7	32.7	25.2	31.9	24.9	27.5	31.2	26.7	30.5	25.8	29.7	3.5	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.4	21.9	29.1	25.9	21.3	28.9	24.7	19.8	28.1	86.6	30.8	83.0	29.7	80.1	30.3	34.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.4	8.8	7.8	-10.3	36.6	2.3	1.7	-11.9	37.8	-13.3	38.7	-14.5	39.7	-16.2	40.9		
(5)			-11.4	28.8	2.5	2.1	-13.1	30.3	-14.6	31.5	-16.0	32.6	-17.7	34.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	15.1	4.2	5.2	8.4	13.8	19.0	23.7	26.2	25.0	21.8	16.4	10.3	6.4	(6)
(7)		DBStd	8.91	5.66	5.25	5.05	4.90	4.30	3.56	2.86	2.81	3.30	4.53	4.78	5.08	(7)
(8)		HDD10.0	649	196	151	93	16	0	0	0	0	0	3	53	137	(8)
(9)		HDD18.3	2031	437	368	309	152	45	4	0	8	93	243	371	(9)	
(10)		CDD10.0	2507	17	16	44	131	279	411	502	464	353	201	63	26	(10)
(11)		CDD18.3	847	0	1	2	17	66	165	244	206	112	32	3	1	(11)
(12)		CDH23.3	7731	0	1	10	116	507	1519	2619	1988	774	188	5	2	(12)
(13)		CDH26.7	2744	0	0	1	26	143	556	1097	711	177	34	0	0	(13)
(14)	Wind	WSAvg	3.2	3.8	3.9	4.0	3.9	3.3	2.8	2.5	2.2	2.6	3.0	3.3	3.4	(14)
(15)	Precipitation	PrecAvg	1141	85	75	112	88	91	99	120	124	110	93	77	101	(15)
(16)		PrecMax	1543	177	199	250	129	179	214	306	256	328	176	206	207	(16)
(17)		PrecMin	915	36	11	13	24	20	37	18	49	14	2	4	43	(17)
(18)		PrecStd	171	32	43	51	31	39	43	67	63	75	51	51	42	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.9	22.0	25.0	29.6	32.5	35.9	36.3	34.9	32.2	29.8	23.9	22.4	(19)
(20)			MCWB	16.3	17.3	17.8	21.6	23.3	25.6	26.5	26.5	24.6	22.7	18.4	17.9	(20)
(21)		2%	DB	17.7	18.6	22.1	26.9	30.1	32.9	34.1	32.9	30.1	27.4	22.1	19.0	(21)
(22)			MCWB	14.9	14.8	16.1	19.5	22.1	24.5	25.9	25.9	24.2	21.9	18.2	16.2	(22)
(23)		5%	DB	16.0	16.1	18.9	23.9	27.8	32.0	32.9	32.1	28.7	25.6	19.9	17.2	(23)
(24)			MCWB	13.6	12.5	14.5	18.3	21.6	24.1	25.5	25.7	23.5	21.2	16.8	14.7	(24)
(25)		10%	DB	13.0	13.6	17.1	22.0	26.3	29.9	32.1	30.4	27.4	23.6	17.8	14.8	(25)
(26)			MCWB	10.6	10.3	13.2	17.0	20.5	23.3	25.2	24.7	22.6	20.0	15.3	12.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.5	18.1	19.1	23.1	25.4	27.2	28.9	28.6	26.4	24.9	20.3	19.2	(27)
(28)			MCDWB	18.7	20.6	23.2	27.2	29.7	32.7	33.5	32.6	28.5	27.0	22.2	21.1	(28)
(29)		2%	WB	15.7	15.4	17.2	20.8	23.6	25.9	27.6	27.4	25.4	23.6	18.8	17.1	(29)
(30)			MCDWB	17.4	17.7	20.1	25.0	27.8	30.9	31.8	30.6	28.6	25.9	20.8	18.2	(30)
(31)		5%	WB	13.9	13.3	15.5	19.2	22.6	25.2	26.8	26.6	24.6	22.3	17.5	15.1	(31)
(32)			MCDWB	15.6	15.2	18.5	22.7	26.7	29.7	31.1	29.8	27.6	24.3	18.7	16.9	(32)
(33)		10%	WB	11.5	10.7	13.5	17.7	21.5	24.5	26.0	25.7	23.8	20.7	16.0	12.8	(33)
(34)			MCDWB	13.1	13.0	16.3	20.5	25.3	28.4	30.3	29.2	26.5	23.1	17.8	14.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.4	9.2	9.4	10.2	10.0	9.5	9.3	9.2	9.9	9.7	8.8	(35)	
(36)			MCDBR	10.6	12.2	12.5	12.3	11.5	11.0	10.3	10.0	9.8	10.8	10.8	10.4	(36)
(37)			MCWBR	8.7	9.2	8.4	6.9	5.7	4.4	4.2	4.4	4.9	6.1	7.6	9.1	(37)
(38)		5% WB	MCDWB	10.1	11.3	11.2	11.2	10.2	9.3	9.3	8.5	8.3	8.4	9.4	9.9	(38)
(39)			MCWBR	9.1	9.7	8.9	7.3	5.8	4.2	4.4	4.1	4.6	5.7	8.1	9.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.314	0.321	0.350	0.391	0.435	0.480	0.511	0.503	0.409	0.359	0.327	0.316	(40)	
(41)		taud	2.530	2.501	2.456	2.350	2.263	2.186	2.116	2.123	2.373	2.513	2.548	2.555	(41)	
(42)		Ebn at Noon	876	913	914	889	851	811	781	777	840	859	853	849	(42)	
(43)		Edh at Noon	78	90	104	122	135	146	156	152	112	89	76	71	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.24	3.04	4.12	5.24	5.92	6.44	6.19	5.59	4.55	3.51	2.54	1.98	(44)	
(45)		RadStd	0.19	0.31	0.33	0.36	0.56	0.44	0.29	0.32	0.39	0.35	0.21	0.16	(45)	

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days			
				99% DB	99% DP	1% DB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (68 neighbors)		+0.47	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+156	+100

Nomenclature: See separate page