

SHENANDOAH VALLEY, VA, USA

WMO: 724105

Lat: 38.264N

Lon: 78.896W

Elev: 366

StdP: 97.00

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 93760

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.9	-8.9	-20.2	0.7	-8.0	-17.3	0.9	-5.1	9.1	5.7	8.3	5.9	1.2	310	0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	33.9	23.2	32.6	22.9	31.3	22.5	25.5	30.6	24.7	29.8	23.9	28.9	3.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.0	19.7	27.9	22.9	18.5	26.8	22.5	17.9	26.3	80.4	30.5	76.7	30.1	73.7	28.5	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.9	6.9	5.6	-16.6	35.9	3.7	1.7	-19.3	37.2	-21.5	38.2	-23.6	39.1	-26.3	40.4		
(5)			-16.6	26.4	2.9	1.4	-18.7	27.4	-20.4	28.2	-22.0	29.1	-24.1	30.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	13.2	1.8	3.2	7.3	12.9	18.0	22.4	23.6	19.8	13.6	7.5	3.5	(6)	
(7)		DBStd	9.23	6.09	5.67	5.51	4.71	4.14	3.16	2.57	2.77	3.61	4.51	4.90	5.22	(7)
(8)		HDD10.0	941	265	198	121	22	1	0	0	0	17	106	212		(8)
(9)		HDD18.3	2489	514	423	344	171	59	6	1	1	27	158	326	460	(9)
(10)		CDD10.0	2111	9	9	36	110	248	372	445	421	294	127	30	11	(10)
(11)		CDD18.3	618	0	0	1	9	48	128	187	163	71	11	1	0	(11)
(12)		CDH23.3	6019	1	1	24	169	512	1220	1789	1496	654	141	11	2	(12)
(13)		CDH26.7	2287	0	0	3	41	151	468	766	604	222	31	1	0	(13)
(14)	Wind	WSAvg	1.8	2.2	2.3	2.4	2.3	1.9	1.7	1.4	1.3	1.4	1.6	1.8	1.7	(14)
(15)	Precipitation	PrecAvg	1012	69	60	93	78	93	93	105	93	108	68	69	78	(15)
(16)		PrecMax	1527	190	171	178	125	162	207	200	175	327	225	129	136	(16)
(17)		PrecMin	745	20	13	21	27	36	14	22	46	11	0	13	45	(17)
(18)		PrecStd	196	47	37	38	30	41	55	37	36	83	55	36	26	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.1	21.6	26.3	30.9	32.3	34.8	36.4	35.3	33.0	29.5	24.7	22.1	(19)
(20)			MCWB	15.3	14.3	16.1	18.8	21.5	23.2	23.3	24.4	22.0	20.9	16.9	16.3	(20)
(21)		2%	DB	17.6	17.9	22.8	27.6	30.1	32.7	33.9	33.4	31.3	27.2	21.8	17.7	(21)
(22)			MCWB	13.3	11.4	14.3	17.1	20.8	22.8	23.3	23.8	21.5	19.1	15.0	13.2	(22)
(23)		5%	DB	14.3	15.8	20.0	25.2	28.0	31.3	32.5	32.1	29.1	24.2	18.9	15.0	(23)
(24)			MCWB	10.9	10.3	13.0	16.1	19.9	22.5	23.2	23.2	20.9	17.7	14.1	11.6	(24)
(25)		10%	DB	11.5	12.7	17.5	22.5	26.4	29.3	31.1	30.1	27.4	22.3	17.0	12.4	(25)
(26)			MCWB	8.0	7.9	11.4	14.8	18.9	21.5	23.0	22.4	20.3	16.6	12.4	9.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.8	15.6	17.7	20.8	23.4	25.6	26.4	27.4	24.9	22.9	19.1	17.6	(27)
(28)			MCD B	19.0	19.8	23.7	27.3	29.3	30.4	32.2	31.7	29.3	27.7	22.3	20.3	(28)
(29)		2%	WB	14.6	13.1	15.8	18.9	22.1	24.5	25.3	25.8	23.5	21.1	17.1	14.4	(29)
(30)			MCD B	17.3	16.5	21.0	24.7	27.6	30.0	30.7	30.5	27.9	24.6	20.1	17.4	(30)
(31)		5%	WB	11.5	10.8	14.1	17.5	21.2	23.7	24.5	24.8	22.5	19.4	15.0	12.0	(31)
(32)			MCD B	14.0	14.3	18.6	22.5	26.6	29.0	29.9	29.5	26.7	22.9	18.1	14.2	(32)
(33)		10%	WB	8.1	8.4	12.0	16.0	20.1	22.7	23.7	23.8	21.5	17.7	12.8	9.2	(33)
(34)			MCD B	10.7	12.3	16.3	21.2	24.8	27.7	28.9	28.3	25.5	20.9	16.1	11.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.6	11.5	12.6	13.8	12.8	12.2	12.0	12.1	12.5	13.2	12.7	11.0	(35)
(36)			MCDBR	13.7	15.9	17.0	17.9	15.4	14.4	14.2	14.4	15.7	16.6	16.5	14.5	(36)
(37)			MCWBR	10.1	10.7	9.8	9.2	7.5	6.1	5.4	5.8	7.2	9.2	10.9	10.4	(37)
(38)		5% WB	MCD BR	12.5	13.5	14.9	14.6	13.5	12.8	12.1	12.2	11.9	13.3	13.4	12.7	(38)
(39)			MCWBR	10.2	10.3	9.5	8.3	7.0	6.0	5.4	5.8	6.2	8.2	10.1	10.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.294	0.315	0.346	0.391	0.430	0.478	0.492	0.505	0.394	0.350	0.315	0.295	(40)	
(41)		taud	2.499	2.422	2.394	2.293	2.203	2.104	2.091	2.025	2.331	2.447	2.505	2.525	(41)	
(42)		Ebn at Noon	894	913	915	887	855	811	795	773	851	861	859	867	(42)	
(43)		Edh at Noon	78	96	109	129	144	159	159	166	116	93	78	71	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.16	2.96	3.95	4.96	5.46	6.01	5.75	5.21	4.33	3.36	2.46	1.90	(44)	
(45)		RadStd	0.18	0.35	0.23	0.39	0.47	0.39	0.34	0.25	0.51	0.39	0.20	0.16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		-0.44	N/A	N/A	-0.98	-0.87	-0.98	N/A	N/A	N/A	-71
(47) Regional (43 neighbors)		+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+128	+73

Nomenclature: See separate page