

CAPITAL CITY, KY, USA

WMO: 724233

Lat: 38.185N

Lon: 84.903W

Elev: 245

StdP: 98.42

Time Zone: -5.00 (NAE)

Period: 97-19

WBAN: 53841

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.1	-10.3	-18.8	0.7	-11.3	-16.1	0.9	-9.1	10.3	11.4	9.0	9.8	2.0	290	0.439

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	33.2	23.2	32.2	23.2	31.1	22.8	25.4	30.8	24.7	29.8	24.0	28.7	3.3	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.7	19.1	28.3	22.9	18.2	27.2	22.5	17.7	26.7	78.6	30.7	75.8	29.8	73.0	28.8	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.5	7.5	6.6	-17.7	35.0	3.9	2.0	-20.5	36.5	-22.8	37.7	-24.9	38.8	-27.7	40.3		
			-18.1	26.6	3.7	0.9	-20.8	27.2	-23.0	27.7	-25.1	28.2	-27.8	28.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.3	0.8	2.7	7.4	13.6	18.4	22.6	24.5	24.1	20.5	13.9	7.6	3.1	(6)
	DBStd	9.72	6.75	6.25	5.90	5.05	4.26	3.08	2.55	2.62	3.92	4.98	5.18	5.87	(7)
	HDD10.0	1009	295	214	123	23	2	0	0	0	0	19	107	227	(8)
	HDD18.3	2513	543	437	342	156	54	6	1	1	22	155	323	473	(9)
	CDD10.0	2221	10	11	41	130	262	379	450	436	317	139	34	12	(10)
	CDD18.3	683	0	1	2	13	56	135	192	178	89	17	1	0	(11)
	CDH23.3	6214	0	1	17	116	485	1206	1757	1601	863	164	5	0	(12)
	CDH26.7	2218	0	0	1	13	119	417	686	620	325	37	1	0	(13)
Wind	WSAvg	2.7	3.3	3.2	3.3	3.3	2.6	2.4	2.0	2.0	2.0	2.4	2.7	3.0	(14)
Precipitation	PrecAvg	1137	78	79	113	99	121	111	111	91	86	68	86	92	(15)
	PrecMax	1486	155	210	364	214	288	257	215	220	307	180	208	249	(16)
	PrecMin	820	10	16	30	20	33	12	11	11	13	2	11	13	(17)
	PrecStd	180	40	42	68	51	56	51	53	44	61	39	41	49	(18)
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.8	21.6	25.9	28.1	31.0	33.1	35.1	35.2	34.3	29.8	23.7	19.9	(19)
		MCWB	15.1	15.6	17.2	17.8	21.9	23.0	25.0	23.4	21.7	20.3	17.0	15.6	(20)
	2%	DB	17.0	17.9	22.6	26.4	29.2	31.9	32.9	33.0	32.4	27.4	21.1	17.1	(21)
		MCWB	14.4	13.0	15.2	17.6	20.7	23.1	24.1	23.0	21.8	19.5	15.1	13.9	(22)
	5%	DB	14.2	15.7	19.8	24.4	28.0	30.9	32.0	31.7	30.6	25.0	18.6	14.5	(23)
		MCWB	12.0	11.8	13.6	16.5	20.3	22.6	23.9	23.0	21.4	17.8	14.2	12.0	(24)
	10%	DB	11.9	12.8	17.3	22.5	26.5	29.2	30.6	30.2	28.1	22.5	16.4	12.4	(25)
		MCWB	9.1	9.1	12.3	15.6	19.7	21.9	23.3	22.5	20.4	17.0	12.5	10.0	(26)
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.5	16.5	18.1	20.2	23.5	25.4	26.8	25.8	24.4	22.9	18.5	16.6	(27)
		MCDB	17.7	20.6	24.1	26.2	28.5	30.7	31.6	31.3	30.2	28.4	22.4	19.2	(28)
	2%	WB	14.5	14.6	16.4	19.0	22.3	24.5	25.6	25.1	23.5	20.9	16.8	14.5	(29)
		MCDB	16.4	17.3	21.0	24.3	27.5	29.7	31.0	30.3	29.1	24.6	19.7	16.4	(30)
	5%	WB	12.5	12.3	15.0	17.8	21.4	23.8	25.0	24.2	22.6	19.4	14.9	12.4	(31)
		MCDB	14.3	14.9	18.9	22.3	26.3	28.7	30.2	29.1	27.7	23.5	17.7	14.1	(32)
	10%	WB	9.3	9.3	13.1	16.6	20.4	23.0	24.2	23.6	21.8	17.8	12.9	10.1	(33)
		MCDB	11.6	12.6	16.9	20.8	24.9	27.7	28.7	28.1	26.3	21.3	15.9	12.2	(34)
Mean Daily Temperature Range	5% DB	MDBR	9.1	10.0	11.2	12.0	11.3	10.9	10.5	11.1	12.3	12.0	11.0	8.8	(35)
		MCDBR	10.7	13.3	14.0	14.2	12.9	12.5	12.1	12.9	14.9	14.4	13.7	11.2	(36)
		MCWBR	8.7	10.0	8.5	7.7	6.0	5.5	4.7	4.9	5.9	7.3	9.1	9.1	(37)
	5% WB	MCDBR	10.0	12.0	11.7	11.5	10.8	10.5	10.3	10.1	11.3	11.5	11.2	10.1	(38)
		MCWBR	8.7	10.1	7.8	7.3	5.8	5.3	4.8	4.6	5.3	6.7	8.8	8.9	(39)
Clear-Sky Solar Irradiance	taub	0.310	0.324	0.353	0.394	0.438	0.451	0.474	0.468	0.413	0.356	0.324	0.302	(40)	
	taud	2.464	2.403	2.387	2.269	2.192	2.193	2.136	2.145	2.271	2.430	2.476	2.490	(41)	
	Ebn at Noon	871	903	907	884	848	834	810	806	832	854	847	855	(42)	
	Edh at Noon	81	98	110	132	145	145	153	148	123	95	80	74	(43)	
All-Sky Solar Radiation	RadAvg	1.91	2.61	3.69	4.92	5.51	6.18	5.86	5.49	4.53	3.37	2.32	1.65	(44)	
	RadStd	0.20	0.37	0.34	0.36	0.51	0.33	0.34	0.31	0.46	0.37	0.26	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (25 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page