

OWENSBORO-DAVISS COUNTY AP, KY, USA

WMO: 724237

Lat: 37.750N

Lon: 87.167W

Elev: 123

StdP: 99.86

Time Zone: -6.00 (NAC)

Period: 06-19

WBAN: 53803

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.7	-9.9	-18.3	0.8	-10.9	-15.8	1.0	-9.2	11.8	6.1	10.6	5.2	2.9	310	0.465

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	34.9	25.3	33.7	24.9	32.6	24.6	27.1	32.7	26.4	31.9	25.7	30.5	4.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.6	21.2	30.4	24.9	20.3	29.6	24.3	19.5	28.8	85.9	32.7	82.7	31.8	79.5	30.4	30.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.1	8.6	7.6	-15.9	36.8	3.0	2.0	-18.1	38.3	-19.8	39.4	-21.5	40.6	-23.8	42.0		
(5)			-16.4	28.4	3.0	0.9	-18.6	29.1	-20.4	29.6	-22.1	30.1	-24.3	30.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.6	0.8	2.9	9.0	14.9	20.4	25.1	26.0	25.6	22.0	15.1	8.1	4.1		
	DBStd	10.21	6.39	6.72	6.11	5.18	4.37	2.80	2.65	2.65	3.86	5.22	5.29	5.58		
	HDD10.0	921	293	214	94	16	0	0	0	0	0	12	95	197		
	HDD18.3	2319	544	432	294	124	33	1	0	0	11	131	307	442		
	CDD10.0	2586	6	15	63	164	323	452	497	483	359	169	39	14		
	CDD18.3	942	0	1	4	22	97	203	239	224	120	29	1	0		
	CDH23.3	9143	0	1	36	197	829	2011	2443	2226	1112	282	7	0		
	CDH26.7	3756	0	0	4	37	278	862	1082	957	451	84	1	0		
(14) Wind	WSAvg	3.4	4.0	4.0	4.1	4.0	3.5	3.1	2.5	2.4	2.6	3.2	3.4	3.8		
(15) Precipitation	PrecAvg	1192	81	94	121	117	117	93	97	86	89	73	102	96		
	PrecMax	1485	195	279	450	310	302	214	213	279	188	194	252	186		
	PrecMin	704	16	16	21	27	35	25	28	9	9	2	25	22		
	PrecStd	173	46	57	74	64	60	45	45	61	51	44	51	46		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.8	21.8	27.2	29.6	32.9	35.4	37.5	37.1	35.2	31.9	24.3	20.6		
		MCWB	15.8	16.6	19.0	20.0	23.7	25.7	27.7	26.2	23.3	22.5	16.9	17.1		
	2%	DB	15.7	18.9	23.9	27.8	30.9	34.0	34.6	34.6	33.3	29.1	21.5	17.5		
		MCWB	13.7	15.2	17.1	19.1	22.1	24.6	26.2	25.2	23.5	20.3	15.9	15.4		
	5%	DB	13.2	16.4	21.3	25.9	29.7	32.8	33.3	33.0	31.7	26.7	18.9	15.2		
		MCWB	11.4	13.3	15.9	18.3	21.8	24.3	25.8	25.0	23.1	18.9	14.5	13.2		
	10%	DB	10.4	13.6	18.5	23.6	28.3	31.5	32.0	31.5	29.4	24.0	16.6	12.8		
		MCWB	8.2	10.6	13.8	17.0	21.1	23.6	25.1	24.3	21.8	18.1	12.9	10.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.4	17.7	19.7	22.0	24.9	27.0	28.4	27.9	26.4	23.7	19.1	17.8		
		MCDB	17.9	20.6	25.3	27.4	30.6	32.8	34.4	33.9	29.4	29.6	22.2	19.6		
	2%	WB	14.1	15.8	18.0	20.7	23.8	26.2	27.3	26.8	24.9	22.4	17.2	15.8		
		MCDB	15.5	18.3	22.5	25.6	29.1	32.2	33.0	32.6	30.4	27.2	19.9	17.1		
	5%	WB	11.8	13.9	16.7	19.4	22.9	25.4	26.7	26.0	24.1	20.7	15.3	13.4		
		MCDB	12.9	15.9	20.2	23.5	27.9	30.7	32.1	31.2	29.9	23.8	18.0	14.6		
	10%	WB	8.4	10.5	14.8	18.1	21.9	24.7	25.8	25.3	23.0	19.0	13.3	10.8		
		MCDB	9.9	13.0	18.1	22.0	26.6	29.8	30.5	29.7	27.6	22.7	16.2	12.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.8	9.3	10.2	11.4	10.4	10.5	10.1	10.6	11.4	11.7	10.6	8.3		
		MCDBR	11.9	12.6	13.1	13.6	12.0	12.0	11.7	12.2	13.6	14.2	13.4	11.4		
	5% WB	MCWBR	10.2	9.8	8.2	7.0	5.2	4.8	4.8	5.1	5.5	6.6	8.5	9.5		
		MCWBR	11.0	11.6	11.6	11.0	10.6	10.8	10.8	10.9	11.2	11.8	10.9	10.3		
(40) Clear-Sky Solar Irradiance	taub	taub	0.317	0.326	0.365	0.407	0.434	0.451	0.476	0.486	0.414	0.363	0.331	0.310		
		taud	2.460	2.411	2.365	2.252	2.225	2.197	2.141	2.103	2.298	2.431	2.472	2.486		
	Ebn at Noon	Ebn at Noon	866	904	896	873	852	834	810	791	834	850	842	850		
		Edh at Noon	83	98	113	134	141	145	152	154	120	95	81	75		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.99	2.68	3.75	4.97	5.57	6.33	6.05	5.59	4.64	3.47	2.38	1.72		
	RadStd	RadStd	0.21	0.33	0.35	0.30	0.49	0.38	0.38	0.30	0.35	0.37	0.25	0.16		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB		1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (31 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+115	+81

Nomenclature: See separate page