

HUNTINGBURG, IN, USA

WMO: 724365

Lat: 38.249N

Lon: 86.954W

Elev: 161

StdP: 99.40

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 53896

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.7	-11.0	-18.5	0.7	-12.0	-16.1	0.9	-9.9	11.7	4.9	10.6	5.1	2.9	290	0.463

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	33.6	24.4	32.4	24.2	31.3	23.8	26.3	31.5	25.5	30.6	24.7	29.5	3.9	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.8	20.3	29.5	23.9	19.1	28.4	22.9	18.0	27.2	82.3	31.7	79.0	30.3	75.4	29.7	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.8	8.5	7.6	-18.5	35.0	3.2	1.3	-20.8	35.9	-22.7	36.6	-24.5	37.3	-26.8	38.3	DB WB
			-18.2	27.5	3.1	1.1	-20.5	28.3	-22.3	28.9	-24.1	29.5	-26.4	30.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	13.4	0.4	2.6	7.4	13.5	18.6	23.1	24.8	24.2	20.5	14.3	7.7	3.0	(6)
(7)		DBStd	9.89	6.73	6.42	6.07	5.02	4.32	3.18	2.70	2.68	3.94	4.95	5.45	5.74	(7)
(8)		HDD10.0	1019	305	219	123	23	1	0	0	0	15	107	226		(8)
(9)		HDD18.3	2513	555	441	340	158	52	4	0	1	22	146	321	475	(9)
(10)		CDD10.0	2260	8	11	43	127	268	393	458	440	316	147	38	10	(10)
(11)		CDD18.3	712	0	0	3	12	60	147	200	182	88	19	1	0	(11)
(12)		CDH23.3	6372	0	0	15	88	454	1308	1866	1636	839	160	5	0	(12)
(13)		CDH26.7	2340	0	0	1	7	111	487	754	628	317	34	0	0	(13)
(14)	Wind	WSAvg	3.3	4.0	4.0	4.0	4.0	3.3	2.8	2.4	2.2	2.5	3.1	3.6	3.7	(14)
(15)	Precipitation	PrecAvg	1261	104	83	114	126	147	117	101	77	97	93	102	111	(15)
(16)		PrecMax	1566	171	161	274	263	302	185	174	162	260	190	173	217	(16)
(17)		PrecMin	957	35	35	59	54	41	59	39	12	7	22	36	55	(17)
(18)		PrecStd	173	37	35	56	49	73	39	39	44	69	47	38	40	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.0	20.9	26.0	27.7	31.1	33.9	36.2	35.1	34.1	29.8	23.8	19.0	(19)
(20)			MCWB	15.1	15.8	17.9	19.0	22.7	23.7	25.8	25.3	22.7	22.2	17.2	15.9	(20)
(21)		2%	DB	16.1	17.6	22.4	26.2	29.1	32.5	33.1	32.9	32.4	27.4	21.0	16.5	(21)
(22)			MCWB	13.8	13.3	15.6	18.1	21.6	23.5	25.4	24.6	22.6	19.4	15.8	13.8	(22)
(23)		5%	DB	13.6	15.2	19.2	23.9	27.8	31.3	32.3	32.1	30.2	24.9	18.2	13.7	(23)
(24)			MCWB	11.6	11.8	13.9	16.9	20.8	23.1	25.3	24.3	21.8	18.0	14.3	11.2	(24)
(25)		10%	DB	11.0	12.4	17.3	22.2	26.2	29.6	31.0	30.2	27.9	22.6	16.4	12.0	(25)
(26)			MCWB	8.7	9.0	12.6	16.0	19.8	22.6	24.6	23.6	20.4	17.0	12.5	9.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.1	16.7	18.5	20.7	24.0	25.8	27.9	27.0	24.9	23.1	18.8	16.7	(27)
(28)			MADB	17.4	19.8	24.4	26.3	29.0	31.1	32.8	32.7	31.4	28.9	22.0	18.6	(28)
(29)		2%	WB	14.2	14.6	16.7	19.2	22.8	24.9	26.8	25.9	23.8	21.2	16.8	14.4	(29)
(30)			MADB	16.0	17.0	20.9	24.0	27.7	30.2	31.6	31.3	30.0	25.0	19.6	16.5	(30)
(31)		5%	WB	12.0	12.2	15.0	18.1	21.8	24.1	25.8	25.2	22.8	19.4	15.1	11.8	(31)
(32)			MADB	13.4	14.7	18.7	22.4	26.5	29.4	30.8	30.2	28.1	23.2	18.1	13.3	(32)
(33)		10%	WB	8.5	9.1	12.9	16.8	20.6	23.3	25.1	24.3	21.7	17.9	13.0	9.3	(33)
(34)			MADB	10.3	12.1	16.8	21.0	25.0	28.2	29.8	28.7	26.1	21.5	15.8	11.5	(34)
(35)	Mean Daily Temperature Range	MDBR	8.4	9.1	10.2	11.3	10.5	10.7	10.3	11.0	12.2	11.5	9.7	7.9	(35)	
(36)		5% DB	MADB	10.2	12.0	12.8	13.0	11.7	12.1	11.7	12.4	14.3	13.5	11.9	10.1	(36)
(37)			MCWBR	9.0	9.5	8.3	7.8	6.1	5.3	5.2	5.6	6.3	7.2	8.4	8.6	(37)
(38)		5% WB	MADB	9.6	11.1	11.1	10.6	10.1	10.3	10.2	10.5	12.0	10.8	10.4	9.3	(38)
(39)			MCWBR	9.0	9.8	8.0	7.3	5.8	5.1	5.3	5.3	5.9	6.5	8.5	8.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.312	0.324	0.360	0.406	0.437	0.451	0.470	0.477	0.417	0.359	0.327	0.308	(40)	
(41)		taud	2.467	2.407	2.376	2.248	2.207	2.194	2.149	2.120	2.275	2.440	2.476	2.483	(41)	
(42)		Ebn at Noon	869	903	900	872	849	834	814	798	828	851	842	847	(42)	
(43)		Edh at Noon	81	98	112	135	143	145	151	151	122	94	80	75	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.94	2.65	3.72	4.91	5.48	6.30	6.03	5.58	4.61	3.39	2.31	1.65	(44)	
(45)		RadStd	0.21	0.32	0.35	0.30	0.49	0.40	0.38	0.32	0.37	0.36	0.25	0.16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page