

TERRE HAUTE, IN, USA

WMO: 724373

Lat: 39.452N

Lon: 87.309W

Elev: 175

StdP: 99.24

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 03868

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.0	-13.5	-21.4	0.6	-15.9	-18.5	0.7	-12.8	10.9	0.5	9.9	-1.2	2.9	310	0.484

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	33.4	24.3	32.2	24.1	31.0	23.3	26.1	31.4	25.3	30.3	24.4	29.1	4.0	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.5	19.9	29.3	23.7	18.9	28.4	22.8	18.0	27.2	81.8	31.5	78.0	30.1	74.5	29.1	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	8.4	7.6	-21.2	35.2	4.1	2.0	-24.1	36.6	-26.5	37.7	-28.8	38.8	-31.7	40.3		
(5)			-21.6	27.6	4.0	1.1	-24.4	28.4	-26.7	29.1	-28.9	29.7	-31.8	30.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.2	-1.8	0.6	6.0	12.4	17.9	22.8	24.1	23.3	19.6	13.1	6.4	0.9		
	DBStd	10.39	6.85	6.42	6.04	5.01	4.55	3.38	3.03	2.81	3.96	4.96	5.31	6.01		
	HDD10.0	1269	369	269	154	31	2	0	0	0	0	23	134	287		
	HDD18.3	2869	623	498	383	187	65	6	1	2	32	174	359	540		
	CDD10.0	2062	4	5	31	103	248	383	438	411	287	121	25	5		
	CDD18.3	619	0	0	2	8	53	139	181	154	69	13	0	0		
	CDH23.3	5799	0	0	13	75	475	1275	1747	1411	677	124	2	0		
	CDH26.7	2078	0	0	1	7	130	477	696	506	233	28	0	0		
(14) Wind	WSAvg	3.3	4.0	4.0	4.0	4.1	3.4	2.8	2.4	2.1	2.3	3.0	3.6	3.6		
(15) Precipitation	PrecAvg	1012	54	55	92	99	110	91	120	90	85	59	87	73		
	PrecMax	1392	150	139	180	179	299	195	278	253	197	116	295	206		
	PrecMin	673	7	11	24	19	36	7	18	14	5	9	12	9		
	PrecStd	194	37	33	45	42	65	43	65	63	50	26	58	46		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.1	19.2	25.4	27.6	31.7	34.5	36.5	34.1	33.5	29.7	22.7	17.9		
		MCWB	14.7	14.5	17.0	18.8	22.0	23.7	25.6	24.8	22.7	21.1	16.3	15.1		
	2%	DB	14.0	16.1	22.0	25.8	29.6	32.6	33.7	32.5	31.4	26.8	19.6	15.0		
		MCWB	12.2	12.4	15.4	17.6	21.0	23.5	25.2	24.7	22.7	19.1	15.2	12.7		
	5%	DB	11.3	13.0	18.8	23.4	28.0	31.3	32.2	31.1	29.5	24.0	17.4	12.4		
		MCWB	9.7	10.0	13.6	16.4	20.3	23.0	24.8	23.9	21.7	17.7	13.8	10.5		
	10%	DB	7.8	10.1	16.2	21.3	26.2	29.6	30.5	29.6	27.4	22.1	15.1	9.4		
		MCWB	5.8	7.2	11.7	15.2	19.5	22.0	23.7	23.0	20.3	16.8	11.6	7.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.0	15.9	18.1	20.6	23.8	25.9	27.5	27.0	24.9	22.3	18.2	15.6		
		MCDB	16.7	18.4	24.5	26.0	28.8	31.9	32.6	31.8	30.6	27.7	20.8	17.7		
	2%	WB	12.7	13.2	16.1	18.9	22.5	25.0	26.5	25.8	23.8	20.6	16.2	13.0		
		MCDB	14.1	15.3	20.4	23.3	27.9	30.8	31.8	30.7	29.4	24.5	18.4	14.4		
	5%	WB	10.0	10.4	14.5	17.5	21.5	24.1	25.6	24.9	22.7	19.1	14.4	10.6		
		MCDB	11.0	12.9	18.1	21.6	26.5	29.3	30.5	29.6	27.4	22.8	17.1	12.2		
	10%	WB	5.9	7.2	12.3	16.2	20.4	23.2	24.7	24.0	21.6	17.3	12.0	7.6		
		MCDB	7.7	9.9	15.7	20.3	24.7	28.0	29.2	28.1	25.8	20.8	14.6	8.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.5	9.2	10.4	11.7	11.2	10.8	11.0	11.5	12.9	12.0	10.0	8.1		
		MCDBR	10.7	13.0	13.7	14.0	13.0	12.5	12.2	12.5	14.7	14.5	12.6	10.8		
		MCWBR	9.4	10.2	8.7	8.0	6.3	5.3	5.4	5.8	6.7	7.9	9.2	9.4		
		MCDBR	10.3	12.0	11.9	11.4	11.2	10.5	10.8	10.8	12.2	11.8	11.2	10.0		
	5% WB	MCWBR	9.7	10.4	8.3	7.6	6.2	5.1	5.5	5.6	6.2	7.0	9.2	9.2		
(40) Clear-Sky Solar Irradiance	taub		0.305	0.319	0.355	0.407	0.438	0.447	0.464	0.473	0.430	0.362	0.321	0.301		
	taud		2.450	2.396	2.368	2.227	2.191	2.202	2.151	2.114	2.217	2.412	2.475	2.479		
	Ebn at Noon		867	902	899	869	845	835	817	798	810	840	839	845		
	Edh at Noon		80	97	111	137	145	143	150	151	128	95	78	73		
(44) All-Sky Solar Radiation	RadAvg		1.79	2.62	3.68	4.76	5.43	6.23	6.04	5.52	4.61	3.25	2.17	1.53		
	RadStd		0.20	0.29	0.31	0.33	0.49	0.37	0.37	0.34	0.33	0.33	0.23	0.17		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (39 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+105	N/A

Nomenclature: See separate page