

KIRKSVILLE, MO, USA

WMO: 724455

Lat: 40.097N

Lon: 92.543W

Elev: 294

StdP: 97.84

Time Zone: -6.00 (NAC)

Period: 98-19

WBAN: 14938

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.0	-15.2	-22.6	0.5	-16.8	-20.2	0.6	-14.3	11.1	0.8	10.2	0.4	3.3	300	0.523

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	33.9	24.4	32.3	24.3	30.9	23.5	26.1	31.4	25.2	30.5	24.4	29.1	4.3	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.5	20.2	29.4	23.7	19.2	28.5	22.8	18.2	27.4	82.5	31.6	78.6	30.2	75.1	29.2	28.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.2	8.8	8.0	DB	-22.7	36.0	3.3	2.1	-25.1	37.5	-27.0	38.8	-28.8	40.0	-31.2	41.5	(4)
(5)			WB	-23.0	27.4	3.2	0.7	-25.3	27.9	-27.1	28.3	-28.9	28.7	-31.2	29.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.3	-3.1	-1.3	5.3	11.7	16.9	22.0	24.3	23.3	19.2	12.2	5.6	-0.8	(6)	
	DBStd	10.89	6.59	6.78	6.11	5.37	4.58	3.38	3.19	3.05	4.35	5.34	5.74	6.29	(7)	
	HDD10.0	1474	407	319	172	43	4	0	0	0	1	38	154	336	(8)	
	HDD18.3	3135	664	548	405	207	82	8	1	2	41	201	383	592	(9)	
	CDD10.0	1962	1	4	26	93	219	360	442	411	276	106	22	2	(10)	
	CDD18.3	582	0	0	1	7	39	118	184	155	67	11	1	0	(11)	
	CDH23.3	5402	1	0	6	80	315	1050	1854	1399	608	87	1	0	(12)	
	CDH26.7	1953	0	0	0	10	66	352	764	538	204	18	0	0	(13)	
(14) Wind	WSAvg	3.8	4.3	4.3	4.5	4.6	3.9	3.4	2.9	2.8	3.1	3.7	4.2	4.1	(14)	
(15) Precipitation	PrecAvg	1046	30	48	66	107	132	144	124	101	106	77	65	43	(15)	
	PrecMax	1670	74	108	156	186	293	307	392	212	314	225	222	105	(16)	
	PrecMin	646	3	9	12	40	33	24	20	5	14	9	5	3	(17)	
	PrecStd	265	19	22	36	35	68	76	106	50	72	51	48	27	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.1	19.5	24.0	28.0	31.2	33.9	37.1	35.8	33.1	29.0	22.5	17.4	(19)	
		MCWB	10.6	12.4	16.5	18.8	22.7	24.7	23.8	24.0	23.4	20.7	15.3	14.3	(20)	
	2%	DB	12.0	15.3	21.1	25.8	28.4	31.9	34.3	33.3	31.2	25.7	19.8	14.1	(21)	
		MCWB	7.5	10.3	14.5	17.2	21.0	24.0	24.9	24.0	22.6	18.4	14.2	10.7	(22)	
	5%	DB	8.9	11.8	18.1	23.4	26.8	30.4	32.5	31.6	29.1	23.1	17.3	10.6	(23)	
		MCWB	5.6	8.3	13.0	16.0	20.0	23.3	25.0	23.9	21.8	17.7	12.6	7.8	(24)	
	10%	DB	5.9	8.4	15.3	21.2	25.0	28.7	30.9	29.8	27.1	21.1	14.5	8.0	(25)	
		MCWB	3.3	5.2	10.7	15.0	18.7	22.3	23.9	23.0	20.4	16.3	10.5	5.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.1	14.5	17.8	20.2	23.9	26.2	27.3	27.2	24.9	22.3	17.2	15.2	(27)	
		MCDB	14.4	18.0	22.6	26.1	29.0	31.6	32.3	32.3	31.0	27.1	20.4	17.2	(28)	
	2%	WB	8.2	11.0	15.7	18.6	22.3	25.1	26.4	25.7	23.8	20.5	15.2	11.5	(29)	
		MCDB	11.1	13.9	19.4	24.2	27.1	30.3	31.9	30.8	29.4	23.8	18.9	13.4	(30)	
	5%	WB	5.5	8.2	14.0	17.2	21.1	24.1	25.5	24.8	22.8	18.7	13.2	8.0	(31)	
		MCDB	8.8	11.6	17.4	22.1	25.4	28.8	30.9	29.7	27.3	21.8	16.4	10.0	(32)	
	10%	WB	3.3	5.2	11.0	15.6	19.9	23.1	24.7	23.8	21.6	16.9	11.0	5.6	(33)	
		MCDB	5.7	8.3	14.7	20.1	23.8	27.8	29.5	28.2	25.5	20.4	14.0	8.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.5	10.0	11.1	11.8	11.0	10.8	11.0	11.3	12.3	11.4	10.7	9.1	(35)	
		MCDBR	13.4	14.3	14.7	14.7	12.6	12.1	12.3	13.3	13.5	13.6	13.6	12.4	(36)	
	5% WB	MCWBR	9.8	10.3	9.0	8.6	6.7	6.0	5.1	5.7	6.2	7.6	9.0	9.6	(37)	
		MCWBR	12.5	13.2	12.9	12.6	11.1	10.9	10.7	11.0	11.4	10.9	12.4	11.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.291	0.311	0.333	0.391	0.422	0.423	0.438	0.434	0.387	0.344	0.298	0.292	(40)	
		taud	2.454	2.382	2.409	2.256	2.233	2.269	2.225	2.258	2.336	2.457	2.524	2.471	(41)	
	Ebn at Noon		880	906	922	883	859	856	838	832	851	858	867	849	(42)	
		Edh at Noon	78	97	106	132	138	134	139	131	113	90	73	72	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.95	2.84	3.73	4.83	5.61	6.27	6.25	5.49	4.74	3.23	2.20	1.70	(44)	
	RadStd		0.21	0.25	0.28	0.35	0.42	0.59	0.42	0.30	0.31	0.36	0.20	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (33 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page