

JEFFERSON CITY, MO, USA

WMO: 724458

Lat: 38.591N

Lon: 92.156W

Elev: 573

StdP: 14.39

Time Zone: -6.00 (NAC)

Period: 97-19

WBAN: 03963

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.2	11.6	-4.2	4.5	9.0	0.1	5.6	13.9	24.6	36.5	21.7	32.6	6.5	290	0.459

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.7	95.4	76.1	92.6	75.5	90.4	74.8	79.4	89.8	78.0	88.4	76.8	86.8	7.8	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.5	141.3	84.9	75.0	134.0	83.7	73.4	126.9	82.2	43.2	90.2	41.8	88.9	40.5	86.7	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.8	18.4	16.3	-1.6	99.5	5.3	3.3	-5.4	101.8	-8.5	103.8	-11.5	105.6	-15.4	108.0		
			-2.3	81.6	5.2	2.3	-6.1	83.3	-9.1	84.6	-12.0	85.9	-15.8	87.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	56.7	32.4	36.3	46.3	57.2	66.2	75.1	78.7	77.0	69.6	58.0	46.3	35.8
	DBStd	18.56	11.47	11.47	11.00	9.26	8.22	6.15	5.55	5.55	7.15	9.30	9.84	10.59
	HDD50	1866	555	403	203	35	2	0	0	0	0	31	182	455
	HDD65	4522	1011	804	587	264	89	6	0	1	34	257	563	906
	CDD50	4303	9	19	87	253	504	752	891	836	589	277	72	14
	CDD65	1486	0	0	6	31	126	309	426	373	173	39	3	0
	CDH74	14986	0	3	65	349	1148	3074	4678	3685	1596	361	27	0
	CDH80	6137	0	0	6	73	361	1258	2164	1608	575	90	2	0
Wind	WSAvg	6.7	7.6	7.9	8.3	8.6	7.2	6.4	5.1	4.7	5.0	6.0	6.9	7.3
Precipitation	PrecAvg	39.8	1.8	1.9	3.0	3.9	5.0	4.3	3.5	3.4	4.0	3.3	3.1	2.4
	PrecMax	66.1	7.2	5.2	10.6	12.3	10.2	11.2	13.4	10.2	12.8	9.0	9.8	8.0
	PrecMin	26.4	0.0	0.0	0.8	0.7	1.9	0.6	0.2	0.1	0.4	0.2	0.6	0.4
	PrecStd	9.4	1.5	1.3	1.8	2.0	2.3	2.8	2.4	2.6	3.1	1.9	2.2	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.7	72.7	80.2	86.5	90.6	95.7	100.4	99.1	93.2	87.4	77.8	69.3
		MCWB	56.8	58.8	62.9	66.2	71.5	75.4	75.1	76.0	74.1	71.3	62.0	61.6
	2%	DB	61.3	66.1	75.3	81.9	87.5	92.2	96.2	95.1	90.1	82.1	72.2	63.0
		MCWB	51.9	54.9	60.2	63.7	71.1	75.0	76.7	75.7	73.8	66.9	59.1	55.2
	5%	DB	55.3	61.3	70.2	78.5	84.1	90.1	92.9	91.5	86.7	78.1	67.5	57.1
		MCWB	47.3	51.0	57.6	62.3	69.8	74.3	76.3	75.1	72.3	64.8	57.3	49.5
	10%	DB	49.6	54.6	64.9	74.1	81.1	87.7	90.4	88.5	82.7	73.5	63.0	52.3
		MCWB	43.1	46.4	54.9	60.6	68.0	73.4	75.9	74.5	70.3	63.2	54.2	46.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.3	61.2	65.9	69.1	75.3	79.3	81.3	81.3	77.4	73.5	65.2	62.1
		MCDB	65.8	68.8	76.3	80.3	85.6	89.4	89.8	89.8	88.5	82.8	73.4	68.5
	2%	WB	53.5	57.3	62.6	66.8	73.5	77.5	79.7	79.1	75.5	70.7	61.8	56.9
		MCDB	58.0	64.2	71.6	77.3	84.3	88.1	90.1	89.5	85.9	78.5	69.1	62.0
	5%	WB	47.9	52.1	59.7	64.7	71.4	76.0	78.4	77.4	74.1	68.0	58.9	51.3
		MCDB	54.4	59.6	68.2	74.6	80.8	86.2	88.8	87.5	83.0	74.4	65.8	55.7
	10%	WB	43.0	46.4	56.1	62.5	69.5	74.7	77.3	75.9	72.5	65.1	55.2	46.5
		MCDB	49.4	54.2	63.5	71.8	78.0	84.5	87.5	85.6	80.4	72.5	62.3	51.2
Mean Daily Temperature Range	5% DB	MDBR	18.1	19.1	20.7	21.7	20.0	18.6	18.7	19.4	21.5	21.5	20.3	17.4
		MCDBR	27.8	28.9	27.7	27.5	23.0	21.1	21.4	23.0	23.8	25.9	27.7	25.4
		MCWBR	19.4	19.1	15.3	14.1	10.6	8.3	7.4	8.4	9.9	13.0	17.2	18.0
	5% WB	MCDBR	24.5	26.6	22.9	21.4	20.0	18.3	18.8	19.4	19.9	20.2	23.0	22.7
		MCWBR	18.7	19.3	14.6	12.8	10.2	8.5	8.3	8.5	9.1	11.8	16.5	18.2
Clear-Sky Solar Irradiance	taub	0.302	0.317	0.344	0.393	0.434	0.436	0.457	0.462	0.394	0.350	0.310	0.298	
	taud	2.463	2.414	2.401	2.273	2.220	2.253	2.199	2.195	2.354	2.468	2.523	2.498	
	Ebn at Noon	279	288	290	280	270	269	261	257	270	273	274	272	
	Edh at Noon	26	30	34	42	45	43	45	44	36	29	24	23	
All-Sky Solar Radiation	RadAvg	679	896	1200	1578	1794	2041	2005	1773	1529	1086	747	580	
	RadStd	79	96	113	101	159	167	134	100	102	118	77	60	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	-2.50	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (22 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+148

Nomenclature: See separate page